



# ANALYTICAL REPORT

## PREPARED FOR

Attn: Mr. Kirk Moline  
CT Male Associates DPC  
50 Century Hill Dr  
Latham, New York 12110

Generated 10/24/2023 8:47:55 PM

## JOB DESCRIPTION

Hoosick Falls WTP

## JOB NUMBER

410-147466-1

## Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

Analytical test results meet all requirements of the associated regulatory program (i.e., NELAC (TNI), DoD, and ISO 17025) unless otherwise noted under the individual analysis.

## Authorization



Generated  
10/24/2023 8:47:55 PM

---

Authorized for release by  
Kelly Tessier, Project Manager  
[kelly.tessier@et.eurofinsus.com](mailto:kelly.tessier@et.eurofinsus.com)  
(717)205-7820

## Compliance Statement

Analytical test results meet all requirements of the associated regulatory program (e.g., NELAC (TNI), DoD, and ISO 17025) unless otherwise noted under the individual analysis. Data qualifiers are applied to note exceptions. Noncompliant quality control (QC) is further explained in narrative comments.

- QC results that exceed the upper limits and are associated with non-detect samples are qualified but further narration is not required since the bias is high and does not change a non-detect result. Further narration is also not required with QC blank detection when the associated sample concentration is non-detect or more than ten times the level in the blank.
- Matrix QC may not be reported if insufficient sample or site-specific QC samples were not submitted. In these situations, to demonstrate precision and accuracy at a batch level, a LCS/LCSD is performed, unless otherwise specified in the method.
- Surrogate and/or isotope dilution analyte recoveries (if applicable) which are outside of the QC window are confirmed unless attributed to a dilution or otherwise noted in the narrative.

Regulated compliance samples (e.g. SDWA, NPDES) must comply with the associated agency requirements/permits.

Measurement uncertainty values, as applicable, are available upon request.

Test results relate only to the sample tested. Clients should be aware that a critical step in a chemical or microbiological analysis is the collection of the sample. Unless the sample analyzed is truly representative of the bulk of material involved, the test results will be meaningless. If you have questions regarding the proper techniques of collecting samples, please contact us. We cannot be held responsible for sample integrity, however, unless sampling has been performed by a member of our staff. Times are local to the area of activity. Parameters listed in the 40 CFR Part 136 Table II as "analyze immediately" and tested in the laboratory are not performed within 15 minutes of collection.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**WARRANTY AND LIMITS OF LIABILITY** - In accepting analytical work, we warrant the accuracy of test results for the sample as submitted. The foregoing express warranty is exclusive and is given in lieu of all other warranties, expressed or implied, except as otherwise agreed. We disclaim any other warranties, expressed or implied, including a warranty of fitness for particular purpose and warranty of merchantability. In no event shall Eurofins Lancaster Laboratories Environmental, LLC be liable for indirect, special, consequential, or incidental damages including, but not limited to, damages for loss of profit or goodwill regardless of (A) the negligence (either sole or concurrent) of Eurofins Lancaster Laboratories Environmental and (B) whether Eurofins Lancaster Laboratories Environmental has been informed of the possibility of such damages. We accept no legal responsibility for the purposes for which the client uses the test results. Except as otherwise agreed, no purchase order or other order for work shall be accepted by Eurofins Lancaster Laboratories Environmental which includes any conditions that vary from the Standard Terms and Conditions, and Eurofins Lancaster Laboratories Environmental hereby objects to any conflicting terms contained in any acceptance or order submitted by client.

  
\_\_\_\_\_



# Table of Contents

Cover Page . . . . .	1
Table of Contents . . . . .	4
Definitions/Glossary . . . . .	5
Case Narrative . . . . .	6
Detection Summary . . . . .	7
Client Sample Results . . . . .	8
Surrogate Summary . . . . .	13
Isotope Dilution Summary . . . . .	14
QC Sample Results . . . . .	15
QC Association Summary . . . . .	18
Lab Chronicle . . . . .	19
Certification Summary . . . . .	21
Method Summary . . . . .	22
Sample Summary . . . . .	23
Chain of Custody . . . . .	24
Receipt Checklists . . . . .	25

# Definitions/Glossary

Client: CT Male Associates DPC  
Project/Site: Hoosick Falls WTP

Job ID: 410-147466-1

## Qualifiers

### LCMS

Qualifier	Qualifier Description
U	Indicates the analyte was analyzed for but not detected.

## Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
α	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

# Case Narrative

Client: CT Male Associates DPC  
Project/Site: Hoosick Falls WTP

Job ID: 410-147466-1

---

**Job ID: 410-147466-1**

---

**Laboratory: Eurofins Lancaster Laboratories Environment Testing, LLC**

**Narrative**

---

**Job Narrative  
410-147466-1**

Analytical test results meet all requirements of the associated regulatory program listed on the Accreditation/Certification Summary Page unless otherwise noted under the individual analysis. Data qualifiers are applied to indicate exceptions. Noncompliant quality control (QC) is further explained in narrative comments.

Matrix QC may not be reported if insufficient sample or site-specific QC samples were not submitted. In these situations, to demonstrate precision and accuracy at a batch level, a LCS/LCSD may be performed, unless otherwise specified in the method. Surrogate and/or isotope dilution analyte recoveries (if applicable) which are outside of the QC window are confirmed unless attributed to a dilution or otherwise noted in the narrative.

Regulated compliance samples (e.g. SDWA, NPDES) must comply with the associated agency requirements/permits.

**Receipt**

The samples were received on 10/18/2023 9:35 AM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice. The temperature of the cooler at receipt time was 0.1°C

**PFAS**

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.



# Detection Summary

Client: CT Male Associates DPC  
Project/Site: Hoosick Falls WTP

Job ID: 410-147466-1

## Client Sample ID: GAC MIDFLUENT

Lab Sample ID: 410-147466-1

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Perfluorobutanoic acid	3.3		1.7	ng/L	1		537 (Mod)	Total/NA

## Client Sample ID: GAC PV-01 75

Lab Sample ID: 410-147466-2

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Perfluorobutanoic acid	6.8		1.7	ng/L	1		537 (Mod)	Total/NA

## Client Sample ID: GAC PV-02 25

Lab Sample ID: 410-147466-3

No Detections.

## Client Sample ID: FTB01-231017

Lab Sample ID: 410-147466-4

No Detections.

## Client Sample ID: LTB01-231017

Lab Sample ID: 410-147466-5

No Detections.

This Detection Summary does not include radiochemical test results.

Eurofins Lancaster Laboratories Environment Testing, LLC

# Client Sample Results

Client: CT Male Associates DPC  
Project/Site: Hoosick Falls WTP

Job ID: 410-147466-1

**Client Sample ID: GAC MIDFLUENT**

**Lab Sample ID: 410-147466-1**

Date Collected: 10/17/23 09:30

Matrix: Water

Date Received: 10/18/23 09:35

**Method: EPA 537 (Mod) - EPA 537 Version 1.1 modified**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
6:2 Fluorotelomer sulfonic acid	1.7	U	1.7	ng/L		10/19/23 15:38	10/21/23 17:38	1
8:2 Fluorotelomer sulfonic acid	1.7	U	1.7	ng/L		10/19/23 15:38	10/21/23 17:38	1
<b>Perfluorobutanoic acid</b>	<b>3.3</b>		1.7	ng/L		10/19/23 15:38	10/21/23 17:38	1
Perfluorodecanesulfonic acid	1.7	U	1.7	ng/L		10/19/23 15:38	10/21/23 17:38	1
Perfluoroheptanesulfonic acid	1.7	U	1.7	ng/L		10/19/23 15:38	10/21/23 17:38	1
Perfluorooctanesulfonamide	1.7	U	1.7	ng/L		10/19/23 15:38	10/21/23 17:38	1
Perfluoropentanoic acid	1.7	U	1.7	ng/L		10/19/23 15:38	10/21/23 17:38	1

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
M2-6:2 FTS	112		40 - 200	10/19/23 15:38	10/21/23 17:38	1
M2-8:2 FTS	103		37 - 200	10/19/23 15:38	10/21/23 17:38	1
13C4 PFBA	93		22 - 174	10/19/23 15:38	10/21/23 17:38	1
13C5 PFPeA	113		33 - 196	10/19/23 15:38	10/21/23 17:38	1
13C8 PFOS	109		59 - 155	10/19/23 15:38	10/21/23 17:38	1
13C8 FOSA	101		10 - 155	10/19/23 15:38	10/21/23 17:38	1
13C3 PFHxS	112		48 - 169	10/19/23 15:38	10/21/23 17:38	1

**Method: EPA 537.1 - EPA 537.1, Ver 1.0 Nov 2018**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
NEtFOSAA	1.7	U	1.7	ng/L		10/19/23 15:39	10/24/23 03:59	1
NMeFOSAA	1.7	U	1.7	ng/L		10/19/23 15:39	10/24/23 03:59	1
Perfluorobutanesulfonic acid	1.7	U	1.7	ng/L		10/19/23 15:39	10/24/23 03:59	1
Perfluorodecanoic acid	1.7	U	1.7	ng/L		10/19/23 15:39	10/24/23 03:59	1
Perfluorododecanoic acid	1.7	U	1.7	ng/L		10/19/23 15:39	10/24/23 03:59	1
Perfluoroheptanoic acid	1.7	U	1.7	ng/L		10/19/23 15:39	10/24/23 03:59	1
Perfluorohexanesulfonic acid	1.7	U	1.7	ng/L		10/19/23 15:39	10/24/23 03:59	1
Perfluorohexanoic acid	1.7	U	1.7	ng/L		10/19/23 15:39	10/24/23 03:59	1
Perfluorononanoic acid	1.7	U	1.7	ng/L		10/19/23 15:39	10/24/23 03:59	1
Perfluorooctanesulfonic acid	1.7	U	1.7	ng/L		10/19/23 15:39	10/24/23 03:59	1
Perfluorooctanoic acid	1.7	U	1.7	ng/L		10/19/23 15:39	10/24/23 03:59	1
Perfluorotetradecanoic acid	1.7	U	1.7	ng/L		10/19/23 15:39	10/24/23 03:59	1
Perfluorotridecanoic acid	1.7	U	1.7	ng/L		10/19/23 15:39	10/24/23 03:59	1
Perfluoroundecanoic acid	1.7	U	1.7	ng/L		10/19/23 15:39	10/24/23 03:59	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C2 PFDA	121		70 - 130	10/19/23 15:39	10/24/23 03:59	1
13C2 PFHxA	129		70 - 130	10/19/23 15:39	10/24/23 03:59	1
d5-NEtFOSAA	121		70 - 130	10/19/23 15:39	10/24/23 03:59	1



# Client Sample Results

Client: CT Male Associates DPC  
Project/Site: Hoosick Falls WTP

Job ID: 410-147466-1

**Client Sample ID: GAC PV-01 75**

**Lab Sample ID: 410-147466-2**

Date Collected: 10/17/23 09:45

Matrix: Water

Date Received: 10/18/23 09:35

**Method: EPA 537 (Mod) - EPA 537 Version 1.1 modified**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
6:2 Fluorotelomer sulfonic acid	1.7	U	1.7	ng/L		10/19/23 15:38	10/21/23 17:51	1
8:2 Fluorotelomer sulfonic acid	1.7	U	1.7	ng/L		10/19/23 15:38	10/21/23 17:51	1
<b>Perfluorobutanoic acid</b>	<b>6.8</b>		1.7	ng/L		10/19/23 15:38	10/21/23 17:51	1
Perfluorodecanesulfonic acid	1.7	U	1.7	ng/L		10/19/23 15:38	10/21/23 17:51	1
Perfluoroheptanesulfonic acid	1.7	U	1.7	ng/L		10/19/23 15:38	10/21/23 17:51	1
Perfluorooctanesulfonamide	1.7	U	1.7	ng/L		10/19/23 15:38	10/21/23 17:51	1
Perfluoropentanoic acid	1.7	U	1.7	ng/L		10/19/23 15:38	10/21/23 17:51	1

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
M2-6:2 FTS	112		40 - 200	10/19/23 15:38	10/21/23 17:51	1
M2-8:2 FTS	109		37 - 200	10/19/23 15:38	10/21/23 17:51	1
13C4 PFBA	91		22 - 174	10/19/23 15:38	10/21/23 17:51	1
13C5 PFPeA	105		33 - 196	10/19/23 15:38	10/21/23 17:51	1
13C8 PFOS	106		59 - 155	10/19/23 15:38	10/21/23 17:51	1
13C8 FOSA	98		10 - 155	10/19/23 15:38	10/21/23 17:51	1
13C3 PFHxS	112		48 - 169	10/19/23 15:38	10/21/23 17:51	1

**Method: EPA 537.1 - EPA 537.1, Ver 1.0 Nov 2018**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
NEtFOSAA	1.7	U	1.7	ng/L		10/19/23 15:39	10/24/23 04:11	1
NMeFOSAA	1.7	U	1.7	ng/L		10/19/23 15:39	10/24/23 04:11	1
Perfluorobutanesulfonic acid	1.7	U	1.7	ng/L		10/19/23 15:39	10/24/23 04:11	1
Perfluorodecanoic acid	1.7	U	1.7	ng/L		10/19/23 15:39	10/24/23 04:11	1
Perfluorododecanoic acid	1.7	U	1.7	ng/L		10/19/23 15:39	10/24/23 04:11	1
Perfluoroheptanoic acid	1.7	U	1.7	ng/L		10/19/23 15:39	10/24/23 04:11	1
Perfluorohexanesulfonic acid	1.7	U	1.7	ng/L		10/19/23 15:39	10/24/23 04:11	1
Perfluorohexanoic acid	1.7	U	1.7	ng/L		10/19/23 15:39	10/24/23 04:11	1
Perfluorononanoic acid	1.7	U	1.7	ng/L		10/19/23 15:39	10/24/23 04:11	1
Perfluorooctanesulfonic acid	1.7	U	1.7	ng/L		10/19/23 15:39	10/24/23 04:11	1
Perfluorooctanoic acid	1.7	U	1.7	ng/L		10/19/23 15:39	10/24/23 04:11	1
Perfluorotetradecanoic acid	1.7	U	1.7	ng/L		10/19/23 15:39	10/24/23 04:11	1
Perfluorotridecanoic acid	1.7	U	1.7	ng/L		10/19/23 15:39	10/24/23 04:11	1
Perfluoroundecanoic acid	1.7	U	1.7	ng/L		10/19/23 15:39	10/24/23 04:11	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C2 PFDA	122		70 - 130	10/19/23 15:39	10/24/23 04:11	1
13C2 PFHxA	127		70 - 130	10/19/23 15:39	10/24/23 04:11	1
d5-NEtFOSAA	123		70 - 130	10/19/23 15:39	10/24/23 04:11	1

# Client Sample Results

Client: CT Male Associates DPC  
Project/Site: Hoosick Falls WTP

Job ID: 410-147466-1

**Client Sample ID: GAC PV-02 25**

**Lab Sample ID: 410-147466-3**

Date Collected: 10/17/23 09:50

Matrix: Water

Date Received: 10/18/23 09:35

**Method: EPA 537 (Mod) - EPA 537 Version 1.1 modified**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
6:2 Fluorotelomer sulfonic acid	1.7	U	1.7	ng/L		10/19/23 15:38	10/21/23 18:05	1
8:2 Fluorotelomer sulfonic acid	1.7	U	1.7	ng/L		10/19/23 15:38	10/21/23 18:05	1
Perfluorobutanoic acid	1.7	U	1.7	ng/L		10/19/23 15:38	10/21/23 18:05	1
Perfluorodecanesulfonic acid	1.7	U	1.7	ng/L		10/19/23 15:38	10/21/23 18:05	1
Perfluoroheptanesulfonic acid	1.7	U	1.7	ng/L		10/19/23 15:38	10/21/23 18:05	1
Perfluorooctanesulfonamide	1.7	U	1.7	ng/L		10/19/23 15:38	10/21/23 18:05	1
Perfluoropentanoic acid	1.7	U	1.7	ng/L		10/19/23 15:38	10/21/23 18:05	1

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
M2-6:2 FTS	118		40 - 200	10/19/23 15:38	10/21/23 18:05	1
M2-8:2 FTS	115		37 - 200	10/19/23 15:38	10/21/23 18:05	1
13C4 PFBA	95		22 - 174	10/19/23 15:38	10/21/23 18:05	1
13C5 PFPeA	119		33 - 196	10/19/23 15:38	10/21/23 18:05	1
13C8 PFOS	115		59 - 155	10/19/23 15:38	10/21/23 18:05	1
13C8 FOSA	112		10 - 155	10/19/23 15:38	10/21/23 18:05	1
13C3 PFHxS	116		48 - 169	10/19/23 15:38	10/21/23 18:05	1

**Method: EPA 537.1 - EPA 537.1, Ver 1.0 Nov 2018**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
NEtFOSAA	1.7	U	1.7	ng/L		10/19/23 15:39	10/24/23 04:22	1
NMeFOSAA	1.7	U	1.7	ng/L		10/19/23 15:39	10/24/23 04:22	1
Perfluorobutanesulfonic acid	1.7	U	1.7	ng/L		10/19/23 15:39	10/24/23 04:22	1
Perfluorodecanoic acid	1.7	U	1.7	ng/L		10/19/23 15:39	10/24/23 04:22	1
Perfluorododecanoic acid	1.7	U	1.7	ng/L		10/19/23 15:39	10/24/23 04:22	1
Perfluoroheptanoic acid	1.7	U	1.7	ng/L		10/19/23 15:39	10/24/23 04:22	1
Perfluorohexanesulfonic acid	1.7	U	1.7	ng/L		10/19/23 15:39	10/24/23 04:22	1
Perfluorohexanoic acid	1.7	U	1.7	ng/L		10/19/23 15:39	10/24/23 04:22	1
Perfluorononanoic acid	1.7	U	1.7	ng/L		10/19/23 15:39	10/24/23 04:22	1
Perfluorooctanesulfonic acid	1.7	U	1.7	ng/L		10/19/23 15:39	10/24/23 04:22	1
Perfluorooctanoic acid	1.7	U	1.7	ng/L		10/19/23 15:39	10/24/23 04:22	1
Perfluorotetradecanoic acid	1.7	U	1.7	ng/L		10/19/23 15:39	10/24/23 04:22	1
Perfluorotridecanoic acid	1.7	U	1.7	ng/L		10/19/23 15:39	10/24/23 04:22	1
Perfluoroundecanoic acid	1.7	U	1.7	ng/L		10/19/23 15:39	10/24/23 04:22	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C2 PFDA	123		70 - 130	10/19/23 15:39	10/24/23 04:22	1
13C2 PFHxA	129		70 - 130	10/19/23 15:39	10/24/23 04:22	1
d5-NEtFOSAA	115		70 - 130	10/19/23 15:39	10/24/23 04:22	1

# Client Sample Results

Client: CT Male Associates DPC  
Project/Site: Hoosick Falls WTP

Job ID: 410-147466-1

**Client Sample ID: FTB01-231017**

**Lab Sample ID: 410-147466-4**

Date Collected: 10/17/23 09:55

Matrix: Water

Date Received: 10/18/23 09:35

**Method: EPA 537 (Mod) - EPA 537 Version 1.1 modified**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
6:2 Fluorotelomer sulfonic acid	1.7	U	1.7	ng/L		10/19/23 15:38	10/21/23 18:19	1
8:2 Fluorotelomer sulfonic acid	1.7	U	1.7	ng/L		10/19/23 15:38	10/21/23 18:19	1
Perfluorobutanoic acid	1.7	U	1.7	ng/L		10/19/23 15:38	10/21/23 18:19	1
Perfluorodecanesulfonic acid	1.7	U	1.7	ng/L		10/19/23 15:38	10/21/23 18:19	1
Perfluoroheptanesulfonic acid	1.7	U	1.7	ng/L		10/19/23 15:38	10/21/23 18:19	1
Perfluorooctanesulfonamide	1.7	U	1.7	ng/L		10/19/23 15:38	10/21/23 18:19	1
Perfluoropentanoic acid	1.7	U	1.7	ng/L		10/19/23 15:38	10/21/23 18:19	1

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
M2-6:2 FTS	120		40 - 200	10/19/23 15:38	10/21/23 18:19	1
M2-8:2 FTS	114		37 - 200	10/19/23 15:38	10/21/23 18:19	1
13C4 PFBA	113		22 - 174	10/19/23 15:38	10/21/23 18:19	1
13C5 PFPeA	111		33 - 196	10/19/23 15:38	10/21/23 18:19	1
13C8 PFOS	111		59 - 155	10/19/23 15:38	10/21/23 18:19	1
13C8 FOSA	109		10 - 155	10/19/23 15:38	10/21/23 18:19	1
13C3 PFHxS	109		48 - 169	10/19/23 15:38	10/21/23 18:19	1

**Method: EPA 537.1 - EPA 537.1, Ver 1.0 Nov 2018**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
NEtFOSAA	1.9	U	1.9	ng/L		10/19/23 15:39	10/24/23 04:34	1
NMeFOSAA	1.9	U	1.9	ng/L		10/19/23 15:39	10/24/23 04:34	1
Perfluorobutanesulfonic acid	1.9	U	1.9	ng/L		10/19/23 15:39	10/24/23 04:34	1
Perfluorodecanoic acid	1.9	U	1.9	ng/L		10/19/23 15:39	10/24/23 04:34	1
Perfluorododecanoic acid	1.9	U	1.9	ng/L		10/19/23 15:39	10/24/23 04:34	1
Perfluoroheptanoic acid	1.9	U	1.9	ng/L		10/19/23 15:39	10/24/23 04:34	1
Perfluorohexanesulfonic acid	1.9	U	1.9	ng/L		10/19/23 15:39	10/24/23 04:34	1
Perfluorohexanoic acid	1.9	U	1.9	ng/L		10/19/23 15:39	10/24/23 04:34	1
Perfluorononanoic acid	1.9	U	1.9	ng/L		10/19/23 15:39	10/24/23 04:34	1
Perfluorooctanesulfonic acid	1.9	U	1.9	ng/L		10/19/23 15:39	10/24/23 04:34	1
Perfluorooctanoic acid	1.9	U	1.9	ng/L		10/19/23 15:39	10/24/23 04:34	1
Perfluorotetradecanoic acid	1.9	U	1.9	ng/L		10/19/23 15:39	10/24/23 04:34	1
Perfluorotridecanoic acid	1.9	U	1.9	ng/L		10/19/23 15:39	10/24/23 04:34	1
Perfluoroundecanoic acid	1.9	U	1.9	ng/L		10/19/23 15:39	10/24/23 04:34	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C2 PFDA	124		70 - 130	10/19/23 15:39	10/24/23 04:34	1
13C2 PFHxA	130		70 - 130	10/19/23 15:39	10/24/23 04:34	1
d5-NEtFOSAA	113		70 - 130	10/19/23 15:39	10/24/23 04:34	1

# Client Sample Results

Client: CT Male Associates DPC  
Project/Site: Hoosick Falls WTP

Job ID: 410-147466-1

**Client Sample ID: LTB01-231017**

**Lab Sample ID: 410-147466-5**

Date Collected: 10/17/23 00:00

Matrix: Water

Date Received: 10/18/23 09:35

**Method: EPA 537 (Mod) - EPA 537 Version 1.1 modified**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
6:2 Fluorotelomer sulfonic acid	1.7	U	1.7	ng/L		10/19/23 15:38	10/21/23 18:32	1
8:2 Fluorotelomer sulfonic acid	1.7	U	1.7	ng/L		10/19/23 15:38	10/21/23 18:32	1
Perfluorobutanoic acid	1.7	U	1.7	ng/L		10/19/23 15:38	10/21/23 18:32	1
Perfluorodecanesulfonic acid	1.7	U	1.7	ng/L		10/19/23 15:38	10/21/23 18:32	1
Perfluoroheptanesulfonic acid	1.7	U	1.7	ng/L		10/19/23 15:38	10/21/23 18:32	1
Perfluorooctanesulfonamide	1.7	U	1.7	ng/L		10/19/23 15:38	10/21/23 18:32	1
Perfluoropentanoic acid	1.7	U	1.7	ng/L		10/19/23 15:38	10/21/23 18:32	1

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
M2-6:2 FTS	103		40 - 200	10/19/23 15:38	10/21/23 18:32	1
M2-8:2 FTS	102		37 - 200	10/19/23 15:38	10/21/23 18:32	1
13C4 PFBA	113		22 - 174	10/19/23 15:38	10/21/23 18:32	1
13C5 PFPeA	112		33 - 196	10/19/23 15:38	10/21/23 18:32	1
13C8 PFOS	105		59 - 155	10/19/23 15:38	10/21/23 18:32	1
13C8 FOSA	95		10 - 155	10/19/23 15:38	10/21/23 18:32	1
13C3 PFHxS	102		48 - 169	10/19/23 15:38	10/21/23 18:32	1

**Method: EPA 537.1 - EPA 537.1, Ver 1.0 Nov 2018**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
NEtFOSAA	1.7	U	1.7	ng/L		10/19/23 15:39	10/24/23 04:45	1
NMeFOSAA	1.7	U	1.7	ng/L		10/19/23 15:39	10/24/23 04:45	1
Perfluorobutanesulfonic acid	1.7	U	1.7	ng/L		10/19/23 15:39	10/24/23 04:45	1
Perfluorodecanoic acid	1.7	U	1.7	ng/L		10/19/23 15:39	10/24/23 04:45	1
Perfluorododecanoic acid	1.7	U	1.7	ng/L		10/19/23 15:39	10/24/23 04:45	1
Perfluoroheptanoic acid	1.7	U	1.7	ng/L		10/19/23 15:39	10/24/23 04:45	1
Perfluorohexanesulfonic acid	1.7	U	1.7	ng/L		10/19/23 15:39	10/24/23 04:45	1
Perfluorohexanoic acid	1.7	U	1.7	ng/L		10/19/23 15:39	10/24/23 04:45	1
Perfluorononanoic acid	1.7	U	1.7	ng/L		10/19/23 15:39	10/24/23 04:45	1
Perfluorooctanesulfonic acid	1.7	U	1.7	ng/L		10/19/23 15:39	10/24/23 04:45	1
Perfluorooctanoic acid	1.7	U	1.7	ng/L		10/19/23 15:39	10/24/23 04:45	1
Perfluorotetradecanoic acid	1.7	U	1.7	ng/L		10/19/23 15:39	10/24/23 04:45	1
Perfluorotridecanoic acid	1.7	U	1.7	ng/L		10/19/23 15:39	10/24/23 04:45	1
Perfluoroundecanoic acid	1.7	U	1.7	ng/L		10/19/23 15:39	10/24/23 04:45	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C2 PFDA	123		70 - 130	10/19/23 15:39	10/24/23 04:45	1
13C2 PFHxA	129		70 - 130	10/19/23 15:39	10/24/23 04:45	1
d5-NEtFOSAA	118		70 - 130	10/19/23 15:39	10/24/23 04:45	1

# Surrogate Summary

Client: CT Male Associates DPC  
Project/Site: Hoosick Falls WTP

Job ID: 410-147466-1

Method: EPA 537.1 - EPA 537.1, Ver 1.0 Nov 2018

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)		
		PFDA (70-130)	PFHxA (70-130)	d5NEFOS (70-130)
410-147466-1	GAC MIDFLUENT	121	129	121
410-147466-2	GAC PV-01 75	122	127	123
410-147466-3	GAC PV-02 25	123	129	115
410-147466-4	FTB01-231017	124	130	113
410-147466-5	LTB01-231017	123	129	118
LCS 410-433401/2-A	Lab Control Sample	121	126	109
MB 410-433401/1-A	Method Blank	120	125	115

#### Surrogate Legend

PFDA = 13C2 PFDA

PFHxA = 13C2 PFHxA

d5NEFOS = d5-NEtFOSAA

# Isotope Dilution Summary

Client: CT Male Associates DPC  
 Project/Site: Hoosick Falls WTP

Job ID: 410-147466-1

**Method: 537 (Mod) - EPA 537 Version 1.1 modified**

**Matrix: Water**

**Prep Type: Total/NA**

Lab Sample ID	Client Sample ID	Percent Isotope Dilution Recovery (Acceptance Limits)						
		M262FTS (40-200)	M282FTS (37-200)	PFBA (22-174)	PFPeA (33-196)	C8PFOS (59-155)	PFOSA (10-155)	C3PFHS (48-169)
410-147466-1	GAC MIDFLUENT	112	103	93	113	109	101	112
410-147466-2	GAC PV-01 75	112	109	91	105	106	98	112
410-147466-3	GAC PV-02 25	118	115	95	119	115	112	116
410-147466-4	FTB01-231017	120	114	113	111	111	109	109
410-147466-5	LTB01-231017	103	102	113	112	105	95	102
LCS 410-433400/2-A	Lab Control Sample	117	108	114	115	109	104	120
LCS 410-433400/3-A	Lab Control Sample Dup	110	106	97	105	104	98	108
MB 410-433400/1-A	Method Blank	133	129	104	116	118	110	138

**Surrogate Legend**

- M262FTS = M2-6:2 FTS
- M282FTS = M2-8:2 FTS
- PFBA = 13C4 PFBA
- PFPeA = 13C5 PFPeA
- C8PFOS = 13C8 PFOS
- PFOSA = 13C8 FOSA
- C3PFHS = 13C3 PFHxS

# QC Sample Results

Client: CT Male Associates DPC  
Project/Site: Hoosick Falls WTP

Job ID: 410-147466-1

## Method: 537 (Mod) - EPA 537 Version 1.1 modified

**Lab Sample ID: MB 410-433400/1-A**  
**Matrix: Water**  
**Analysis Batch: 434140**

**Client Sample ID: Method Blank**  
**Prep Type: Total/NA**  
**Prep Batch: 433400**

Analyte	MB	MB	RL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier						
6:2 Fluorotelomer sulfonic acid	2.0	U	2.0	ng/L		10/19/23 15:38	10/21/23 16:57	1
8:2 Fluorotelomer sulfonic acid	2.0	U	2.0	ng/L		10/19/23 15:38	10/21/23 16:57	1
Perfluorobutanoic acid	2.0	U	2.0	ng/L		10/19/23 15:38	10/21/23 16:57	1
Perfluorodecanesulfonic acid	2.0	U	2.0	ng/L		10/19/23 15:38	10/21/23 16:57	1
Perfluoroheptanesulfonic acid	2.0	U	2.0	ng/L		10/19/23 15:38	10/21/23 16:57	1
Perfluorooctanesulfonamide	2.0	U	2.0	ng/L		10/19/23 15:38	10/21/23 16:57	1
Perfluoropentanoic acid	2.0	U	2.0	ng/L		10/19/23 15:38	10/21/23 16:57	1

  

Isotope Dilution	MB	MB	Limits	Prepared	Analyzed	Dil Fac
	%Recovery	Qualifier				
M2-6:2 FTS	133		40 - 200	10/19/23 15:38	10/21/23 16:57	1
M2-8:2 FTS	129		37 - 200	10/19/23 15:38	10/21/23 16:57	1
13C4 PFBA	104		22 - 174	10/19/23 15:38	10/21/23 16:57	1
13C5 PFPeA	116		33 - 196	10/19/23 15:38	10/21/23 16:57	1
13C8 PFOS	118		59 - 155	10/19/23 15:38	10/21/23 16:57	1
13C8 FOSA	110		10 - 155	10/19/23 15:38	10/21/23 16:57	1
13C3 PFHxS	138		48 - 169	10/19/23 15:38	10/21/23 16:57	1

**Lab Sample ID: LCS 410-433400/2-A**  
**Matrix: Water**  
**Analysis Batch: 434140**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 433400**

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
8:2 Fluorotelomer sulfonic acid	24.5	22.4		ng/L		91	55 - 134
Perfluorobutanoic acid	25.6	23.5		ng/L		92	58 - 130
Perfluorodecanesulfonic acid	24.7	24.2		ng/L		98	55 - 130
Perfluoroheptanesulfonic acid	24.4	23.6		ng/L		97	59 - 130
Perfluorooctanesulfonamide	25.6	24.5		ng/L		96	67 - 132
Perfluoropentanoic acid	25.6	23.5		ng/L		92	60 - 130

  

Isotope Dilution	LCS	LCS	Limits
	%Recovery	Qualifier	
M2-6:2 FTS	117		40 - 200
M2-8:2 FTS	108		37 - 200
13C4 PFBA	114		22 - 174
13C5 PFPeA	115		33 - 196
13C8 PFOS	109		59 - 155
13C8 FOSA	104		10 - 155
13C3 PFHxS	120		48 - 169

**Lab Sample ID: LCSD 410-433400/3-A**  
**Matrix: Water**  
**Analysis Batch: 434140**

**Client Sample ID: Lab Control Sample Dup**  
**Prep Type: Total/NA**  
**Prep Batch: 433400**

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	
								RPD	Limit
6:2 Fluorotelomer sulfonic acid	24.3	23.8		ng/L		98	61 - 132	2	30
8:2 Fluorotelomer sulfonic acid	24.5	22.0		ng/L		90	55 - 134	2	30
Perfluorobutanoic acid	25.6	22.7		ng/L		89	58 - 130	3	30
Perfluorodecanesulfonic acid	24.7	23.5		ng/L		95	55 - 130	3	30
Perfluoroheptanesulfonic acid	24.4	23.2		ng/L		95	59 - 130	2	30

# QC Sample Results

Client: CT Male Associates DPC  
Project/Site: Hoosick Falls WTP

Job ID: 410-147466-1

## Method: 537 (Mod) - EPA 537 Version 1.1 modified (Continued)

**Lab Sample ID:** LCSD 410-433400/3-A  
**Matrix:** Water  
**Analysis Batch:** 434140

**Client Sample ID:** Lab Control Sample Dup  
**Prep Type:** Total/NA  
**Prep Batch:** 433400

Analyte	Spike	LCS	LCS	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
	Added	Result	Qualifier						
Perfluorooctanesulfonamide	25.6	24.4		ng/L		95	67 - 132	1	30
Perfluoropentanoic acid	25.6	24.2		ng/L		95	60 - 130	3	30

Isotope Dilution	LCS	LCS	Limits
	%Recovery	Qualifier	
M2-6:2 FTS	110		40 - 200
M2-8:2 FTS	106		37 - 200
13C4 PFBA	97		22 - 174
13C5 PFPeA	105		33 - 196
13C8 PFOS	104		59 - 155
13C8 FOSA	98		10 - 155
13C3 PFHxS	108		48 - 169

## Method: EPA 537.1 - EPA 537.1, Ver 1.0 Nov 2018

**Lab Sample ID:** MB 410-433401/1-A  
**Matrix:** Water  
**Analysis Batch:** 434732

**Client Sample ID:** Method Blank  
**Prep Type:** Total/NA  
**Prep Batch:** 433401

Analyte	MB	MB	RL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier						
NEtFOSAA	2.0	U	2.0	ng/L		10/19/23 15:39	10/24/23 00:31	1
NMeFOSAA	2.0	U	2.0	ng/L		10/19/23 15:39	10/24/23 00:31	1
Perfluorobutanesulfonic acid	2.0	U	2.0	ng/L		10/19/23 15:39	10/24/23 00:31	1
Perfluorodecanoic acid	2.0	U	2.0	ng/L		10/19/23 15:39	10/24/23 00:31	1
Perfluorododecanoic acid	2.0	U	2.0	ng/L		10/19/23 15:39	10/24/23 00:31	1
Perfluoroheptanoic acid	2.0	U	2.0	ng/L		10/19/23 15:39	10/24/23 00:31	1
Perfluorohexanesulfonic acid	2.0	U	2.0	ng/L		10/19/23 15:39	10/24/23 00:31	1
Perfluorohexanoic acid	2.0	U	2.0	ng/L		10/19/23 15:39	10/24/23 00:31	1
Perfluorononanoic acid	2.0	U	2.0	ng/L		10/19/23 15:39	10/24/23 00:31	1
Perfluorooctanesulfonic acid	2.0	U	2.0	ng/L		10/19/23 15:39	10/24/23 00:31	1
Perfluorooctanoic acid	2.0	U	2.0	ng/L		10/19/23 15:39	10/24/23 00:31	1
Perfluorotetradecanoic acid	2.0	U	2.0	ng/L		10/19/23 15:39	10/24/23 00:31	1
Perfluorotridecanoic acid	2.0	U	2.0	ng/L		10/19/23 15:39	10/24/23 00:31	1
Perfluoroundecanoic acid	2.0	U	2.0	ng/L		10/19/23 15:39	10/24/23 00:31	1

Surrogate	MB	MB	Limits	Prepared	Analyzed	Dil Fac
	%Recovery	Qualifier				
13C2 PFDA	120		70 - 130	10/19/23 15:39	10/24/23 00:31	1
13C2 PFHxA	125		70 - 130	10/19/23 15:39	10/24/23 00:31	1
d5-NEtFOSAA	115		70 - 130	10/19/23 15:39	10/24/23 00:31	1

**Lab Sample ID:** LCS 410-433401/2-A  
**Matrix:** Water  
**Analysis Batch:** 434732

**Client Sample ID:** Lab Control Sample  
**Prep Type:** Total/NA  
**Prep Batch:** 433401

Analyte	Spike	LCS	LCS	Unit	D	%Rec	%Rec Limits
	Added	Result	Qualifier				
NEtFOSAA	20.5	17.5		ng/L		86	70 - 130
NMeFOSAA	20.5	17.7		ng/L		87	70 - 130
Perfluorobutanesulfonic acid	18.1	16.9		ng/L		93	70 - 130
Perfluorodecanoic acid	20.5	21.5		ng/L		105	70 - 130
Perfluorododecanoic acid	20.5	21.7		ng/L		106	70 - 130



# QC Sample Results

Client: CT Male Associates DPC  
Project/Site: Hoosick Falls WTP

Job ID: 410-147466-1

## Method: EPA 537.1 - EPA 537.1, Ver 1.0 Nov 2018 (Continued)

Lab Sample ID: LCS 410-433401/2-A

Matrix: Water

Analysis Batch: 434732

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 433401

Analyte	Spike	LCS	LCS	Unit	D	%Rec	%Rec Limits
	Added	Result	Qualifier				
Perfluoroheptanoic acid	20.5	22.0		ng/L		107	70 - 130
Perfluorohexanesulfonic acid	18.7	17.6		ng/L		94	70 - 130
Perfluorohexanoic acid	20.5	22.9		ng/L		112	70 - 130
Perfluorononanoic acid	20.5	22.1		ng/L		108	70 - 130
Perfluorooctanesulfonic acid	19.0	17.5		ng/L		92	70 - 130
Perfluorooctanoic acid	20.5	23.6		ng/L		115	70 - 130
Perfluorotetradecanoic acid	20.5	20.9		ng/L		102	70 - 130
Perfluorotridecanoic acid	20.5	20.7		ng/L		101	70 - 130
Perfluoroundecanoic acid	20.5	21.0		ng/L		103	70 - 130

Surrogate	LCS	LCS	Limits
	%Recovery	Qualifier	
13C2 PFDA	121		70 - 130
13C2 PFHxA	126		70 - 130
d5-NEtFOSAA	109		70 - 130

# QC Association Summary

Client: CT Male Associates DPC  
 Project/Site: Hoosick Falls WTP

Job ID: 410-147466-1

## LCMS

### Prep Batch: 433400

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
410-147466-1	GAC MIDFLUENT	Total/NA	Water	SPE	
410-147466-2	GAC PV-01 75	Total/NA	Water	SPE	
410-147466-3	GAC PV-02 25	Total/NA	Water	SPE	
410-147466-4	FTB01-231017	Total/NA	Water	SPE	
410-147466-5	LTB01-231017	Total/NA	Water	SPE	
MB 410-433400/1-A	Method Blank	Total/NA	Water	SPE	
LCS 410-433400/2-A	Lab Control Sample	Total/NA	Water	SPE	
LCSD 410-433400/3-A	Lab Control Sample Dup	Total/NA	Water	SPE	

### Prep Batch: 433401

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
410-147466-1	GAC MIDFLUENT	Total/NA	Water	537.1 DW Prep	
410-147466-2	GAC PV-01 75	Total/NA	Water	537.1 DW Prep	
410-147466-3	GAC PV-02 25	Total/NA	Water	537.1 DW Prep	
410-147466-4	FTB01-231017	Total/NA	Water	537.1 DW Prep	
410-147466-5	LTB01-231017	Total/NA	Water	537.1 DW Prep	
MB 410-433401/1-A	Method Blank	Total/NA	Water	537.1 DW Prep	
LCS 410-433401/2-A	Lab Control Sample	Total/NA	Water	537.1 DW Prep	

### Analysis Batch: 434140

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
410-147466-1	GAC MIDFLUENT	Total/NA	Water	537 (Mod)	433400
410-147466-2	GAC PV-01 75	Total/NA	Water	537 (Mod)	433400
410-147466-3	GAC PV-02 25	Total/NA	Water	537 (Mod)	433400
410-147466-4	FTB01-231017	Total/NA	Water	537 (Mod)	433400
410-147466-5	LTB01-231017	Total/NA	Water	537 (Mod)	433400
MB 410-433400/1-A	Method Blank	Total/NA	Water	537 (Mod)	433400
LCS 410-433400/2-A	Lab Control Sample	Total/NA	Water	537 (Mod)	433400
LCSD 410-433400/3-A	Lab Control Sample Dup	Total/NA	Water	537 (Mod)	433400

### Analysis Batch: 434732

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
410-147466-1	GAC MIDFLUENT	Total/NA	Water	EPA 537.1	433401
410-147466-2	GAC PV-01 75	Total/NA	Water	EPA 537.1	433401
410-147466-3	GAC PV-02 25	Total/NA	Water	EPA 537.1	433401
410-147466-4	FTB01-231017	Total/NA	Water	EPA 537.1	433401
410-147466-5	LTB01-231017	Total/NA	Water	EPA 537.1	433401
MB 410-433401/1-A	Method Blank	Total/NA	Water	EPA 537.1	433401
LCS 410-433401/2-A	Lab Control Sample	Total/NA	Water	EPA 537.1	433401

# Lab Chronicle

Client: CT Male Associates DPC  
Project/Site: Hoosick Falls WTP

Job ID: 410-147466-1

## Client Sample ID: GAC MIDFLUENT

Lab Sample ID: 410-147466-1

Date Collected: 10/17/23 09:30

Matrix: Water

Date Received: 10/18/23 09:35

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Batch Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	SPE			433400	HAT6	ELLE	10/19/23 15:38
Total/NA	Analysis	537 (Mod)		1	434140	JVK6	ELLE	10/21/23 17:38
Total/NA	Prep	537.1 DW Prep			433401	WW2J	ELLE	10/19/23 15:39
Total/NA	Analysis	EPA 537.1		1	434732	DCS9	ELLE	10/24/23 03:59

## Client Sample ID: GAC PV-01 75

Lab Sample ID: 410-147466-2

Date Collected: 10/17/23 09:45

Matrix: Water

Date Received: 10/18/23 09:35

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Batch Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	SPE			433400	HAT6	ELLE	10/19/23 15:38
Total/NA	Analysis	537 (Mod)		1	434140	JVK6	ELLE	10/21/23 17:51
Total/NA	Prep	537.1 DW Prep			433401	WW2J	ELLE	10/19/23 15:39
Total/NA	Analysis	EPA 537.1		1	434732	DCS9	ELLE	10/24/23 04:11

## Client Sample ID: GAC PV-02 25

Lab Sample ID: 410-147466-3

Date Collected: 10/17/23 09:50

Matrix: Water

Date Received: 10/18/23 09:35

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Batch Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	SPE			433400	HAT6	ELLE	10/19/23 15:38
Total/NA	Analysis	537 (Mod)		1	434140	JVK6	ELLE	10/21/23 18:05
Total/NA	Prep	537.1 DW Prep			433401	WW2J	ELLE	10/19/23 15:39
Total/NA	Analysis	EPA 537.1		1	434732	DCS9	ELLE	10/24/23 04:22

## Client Sample ID: FTB01-231017

Lab Sample ID: 410-147466-4

Date Collected: 10/17/23 09:55

Matrix: Water

Date Received: 10/18/23 09:35

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Batch Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	SPE			433400	HAT6	ELLE	10/19/23 15:38
Total/NA	Analysis	537 (Mod)		1	434140	JVK6	ELLE	10/21/23 18:19
Total/NA	Prep	537.1 DW Prep			433401	WW2J	ELLE	10/19/23 15:39
Total/NA	Analysis	EPA 537.1		1	434732	DCS9	ELLE	10/24/23 04:34

## Client Sample ID: LTB01-231017

Lab Sample ID: 410-147466-5

Date Collected: 10/17/23 00:00

Matrix: Water

Date Received: 10/18/23 09:35

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Batch Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	SPE			433400	HAT6	ELLE	10/19/23 15:38
Total/NA	Analysis	537 (Mod)		1	434140	JVK6	ELLE	10/21/23 18:32
Total/NA	Prep	537.1 DW Prep			433401	WW2J	ELLE	10/19/23 15:39
Total/NA	Analysis	EPA 537.1		1	434732	DCS9	ELLE	10/24/23 04:45

# Lab Chronicle

Client: CT Male Associates DPC  
Project/Site: Hoosick Falls WTP

Job ID: 410-147466-1

**Laboratory References:**

ELLE = Eurofins Lancaster Laboratories Environment Testing, LLC, 2425 New Holland Pike, Lancaster, PA 17601, TEL (717)656-2300

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16

# Accreditation/Certification Summary

Client: CT Male Associates DPC  
Project/Site: Hoosick Falls WTP

Job ID: 410-147466-1

## Laboratory: Eurofins Lancaster Laboratories Environment Testing, LLC

Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below.

Authority	Program	Identification Number	Expiration Date
New York	NELAP	10670	04-01-24

The following analytes are included in this report, but the laboratory is not certified by the governing authority. This list may include analytes for which the agency does not offer certification.

Analysis Method	Prep Method	Matrix	Analyte
537 (Mod)	SPE	Water	6:2 Fluorotelomer sulfonic acid
537 (Mod)	SPE	Water	8:2 Fluorotelomer sulfonic acid
537 (Mod)	SPE	Water	Perfluorobutanoic acid
537 (Mod)	SPE	Water	Perfluorodecanesulfonic acid
537 (Mod)	SPE	Water	Perfluoroheptanesulfonic acid
537 (Mod)	SPE	Water	Perfluorooctanesulfonamide
537 (Mod)	SPE	Water	Perfluoropentanoic acid



# Method Summary

Client: CT Male Associates DPC  
Project/Site: Hoosick Falls WTP

Job ID: 410-147466-1

Method	Method Description	Protocol	Laboratory
537 (Mod)	EPA 537 Version 1.1 modified	EPA	ELLE
EPA 537.1	EPA 537.1, Ver 1.0 Nov 2018	EPA	ELLE
537.1 DW Prep	Extraction of Perfluorinated Alkyl Acids	EPA	ELLE

**Protocol References:**

EPA = US Environmental Protection Agency

**Laboratory References:**

ELLE = Eurofins Lancaster Laboratories Environment Testing, LLC, 2425 New Holland Pike, Lancaster, PA 17601, TEL (717)656-2300



# Sample Summary

Client: CT Male Associates DPC  
Project/Site: Hoosick Falls WTP

Job ID: 410-147466-1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
410-147466-1	GAC MIDFLUENT	Water	10/17/23 09:30	10/18/23 09:35
410-147466-2	GAC PV-01 75	Water	10/17/23 09:45	10/18/23 09:35
410-147466-3	GAC PV-02 25	Water	10/17/23 09:50	10/18/23 09:35
410-147466-4	FTB01-231017	Water	10/17/23 09:55	10/18/23 09:35
410-147466-5	LTB01-231017	Water	10/17/23 00:00	10/18/23 09:35

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16



vironme

# Chain of Custody Record

410-147466 Chain of Custody

Client Contact Jonathan Dippert		Sampler <i>Carter Benoit</i>		Lab PM Hobart, Paul		Carrier Tracking No(s)		COC No 410-77609-21525 2			
Company CT Male Associates DPC		PWSID		E-Mail Paul.Hobart@et.eurofinsus.com		State of Origin NY		Page 1 of 2 <i>CB</i>			
Address 50 Century Hill Dr		Due Date Requested:		Analysis Requested						Job #	
City Latham		TAT Requested (days): <i>5 day</i>									
State, Zip NY, 12110		Compliance Project: <input type="checkbox"/> Yes <input type="checkbox"/> No									
Phone <i>(518) 786-7400</i>		PO #									
Email j.dippert@ctmale.com		Purchase Order not required									
Project Name Hoosick Falls WTP		Project # 41000511		Field Filtered Sample (Yes or No)		Perform MS/MSD (Yes or No)		Total Number of containers			
Site <i>SGPP-McCaffery</i>		SSOW#		PFAS Drinking Water List		PFAS Drinking Water List		Preservation Codes:			
Sample Identification		Sample Date		Sample Time		Sample Type (C=Comp, G=grab)		Matrix (W=water, S=solid, O=water/soil, BT=Tissue, A=Air)		Special Instructions/Note:	
GAC MIDFLUENT		10/17/2023		09:30		G		Water		8 Q/A/QC samples here	
GAC PV-01 75				09:45				Water		4	
GAC PV-02 25				09:50				Water		4	
FTBot-23/017				09:55				Water		4	
LTBot-23/017								Water		4	
Possible Hazard Identification <input type="checkbox"/> Non-Hazard <input type="checkbox"/> Flammable <input type="checkbox"/> Skin Irritant <input type="checkbox"/> Poison B <input type="checkbox"/> Unknown <input type="checkbox"/> Radiological				Sample Disposal (A fee may be assessed if samples are retained longer than 1 month) <input type="checkbox"/> Return To Client <input type="checkbox"/> Disposal By Lab <input type="checkbox"/> Archive For _____ Months							
Deliverable Requested I, II, III, IV, Other (specify) <i>EQUIS FILE ASP-B</i>				Special Instructions/QC Requirements:							
Empty Kit Relinquished by		Date		Time		Method of Shipment					
Relinquished by <i>Carter Benoit</i>		Date/Time <i>10/17/2023 15:00</i>		Company <i>CTM</i>		Received by		Date/Time		Company	
Relinquished by		Date/Time		Company		Received by		Date/Time		Company	
Relinquished by		Date/Time		Company		Received by <i>MP</i>		Date/Time <i>10/18/23 0935</i>		Company <i>MP</i>	
Custody Seals Intact <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		Custody Seal No.		Cooler Temperature (°C) and Other Remarks <i>R: 0.4 C: 0.1</i>							

42





## Login Sample Receipt Checklist

Client: CT Male Associates DPC

Job Number: 410-147466-1

**Login Number: 147466**

**List Source: Eurofins Lancaster Laboratories Environment Testing, LLC**

**List Number: 1**

**Creator: Arroyo, Haley**

Question	Answer	Comment
The cooler's custody seal is intact.	True	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	
Cooler Temperature acceptable, where thermal pres is required (<math>\leq 6^{\circ}\text{C}</math>, not frozen).	True	
Cooler Temperature is recorded.	True	
WV: Container Temp acceptable, where thermal pres is required (<math>\leq 6^{\circ}\text{C}</math>, not frozen).	N/A	
WV: Container Temperature is recorded.	N/A	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the containers received and the COC.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
There is sufficient vol. for all requested analyses.	True	
Is the Field Sampler's name present on COC?	True	
Sample custody seals are intact.	True	
VOA sample vials do not have headspace >6mm in diameter (none, if from WV)?	N/A	

