



# ANALYTICAL REPORT

## PREPARED FOR

Attn: Jonathan Dippert  
CT Male Associates DPC  
50 Century Hill Dr  
Latham, New York 12110

Generated 7/23/2024 10:49:09 AM

## JOB DESCRIPTION

Hoosick Falls WTP  
HOO

## JOB NUMBER

410-177298-1

## Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

Analytical test results meet all requirements of the associated regulatory program (i.e., NELAC (TNI), DoD, and ISO 17025) unless otherwise noted under the individual analysis.

## Authorization



Generated  
7/23/2024 10:49:09 AM

Authorized for release by  
Kelly Gallagher, Project Manager  
[kelly.gallagher@et.eurofinsus.com](mailto:kelly.gallagher@et.eurofinsus.com)  
(717)205-7820

## Compliance Statement

Analytical test results meet all requirements of the associated regulatory program (e.g., NELAC (TNI), DoD, and ISO 17025) unless otherwise noted under the individual analysis. Data qualifiers are applied to note exceptions. Noncompliant quality control (QC) is further explained in narrative comments.

- QC results that exceed the upper limits and are associated with non-detect samples are qualified but further narration is not required since the bias is high and does not change a non-detect result. Further narration is also not required with QC blank detection when the associated sample concentration is non-detect or more than ten times the level in the blank.
- Matrix QC may not be reported if insufficient sample or site-specific QC samples were not submitted. In these situations, to demonstrate precision and accuracy at a batch level, a LCS/LCSD is performed, unless otherwise specified in the method.
- Surrogate and/or isotope dilution analyte recoveries (if applicable) which are outside of the QC window are confirmed unless attributed to a dilution or otherwise noted in the narrative.

Regulated compliance samples (e.g. SDWA, NPDES) must comply with the associated agency requirements/permits.

Measurement uncertainty values, as applicable, are available upon request.

Test results relate only to the sample tested. Clients should be aware that a critical step in a chemical or microbiological analysis is the collection of the sample. Unless the sample analyzed is truly representative of the bulk of material involved, the test results will be meaningless. If you have questions regarding the proper techniques of collecting samples, please contact us. We cannot be held responsible for sample integrity, however, unless sampling has been performed by a member of our staff. Times are local to the area of activity. Parameters listed in the 40 CFR Part 136 Table II as "analyze immediately" and tested in the laboratory are not performed within 15 minutes of collection.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**WARRANTY AND LIMITS OF LIABILITY** - In accepting analytical work, we warrant the accuracy of test results for the sample as submitted. The foregoing express warranty is exclusive and is given in lieu of all other warranties, expressed or implied, except as otherwise agreed. We disclaim any other warranties, expressed or implied, including a warranty of fitness for particular purpose and warranty of merchantability. In no event shall Eurofins Lancaster Laboratories Environmental, LLC be liable for indirect, special, consequential, or incidental damages including, but not limited to, damages for loss of profit or goodwill regardless of (A) the negligence (either sole or concurrent) of Eurofins Lancaster Laboratories Environmental and (B) whether Eurofins Lancaster Laboratories Environmental has been informed of the possibility of such damages. We accept no legal responsibility for the purposes for which the client uses the test results. Except as otherwise agreed, no purchase order or other order for work shall be accepted by Eurofins Lancaster Laboratories Environmental which includes any conditions that vary from the Standard Terms and Conditions, and Eurofins Lancaster Laboratories Environmental hereby objects to any conflicting terms contained in any acceptance or order submitted by client.

  
\_\_\_\_\_



# Table of Contents

Cover Page . . . . .	1
Table of Contents . . . . .	4
Definitions/Glossary . . . . .	5
Case Narrative . . . . .	6
Detection Summary . . . . .	7
Client Sample Results . . . . .	8
Surrogate Summary . . . . .	11
Isotope Dilution Summary . . . . .	12
QC Sample Results . . . . .	13
QC Association Summary . . . . .	16
Lab Chronicle . . . . .	17
Certification Summary . . . . .	18
Method Summary . . . . .	19
Sample Summary . . . . .	20
Chain of Custody . . . . .	21
Receipt Checklists . . . . .	22

# Definitions/Glossary

Client: CT Male Associates DPC  
Project/Site: Hoosick Falls WTP

Job ID: 410-177298-1  
SDG: HOO

## Qualifiers

### LCMS

Qualifier	Qualifier Description
U	Indicates the analyte was analyzed for but not detected.

## Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
α	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

# Case Narrative

Client: CT Male Associates DPC  
Project: Hoosick Falls WTP

Job ID: 410-177298-1

**Job ID: 410-177298-1**

**Eurofins Lancaster Laboratories Environment**

## Job Narrative 410-177298-1

Analytical test results meet all requirements of the associated regulatory program listed on the Accreditation/Certification Summary Page unless otherwise noted under the individual analysis. Data qualifiers and/or narrative comments are included to explain any exceptions, if applicable.

- Matrix QC may not be reported if insufficient sample is provided or site-specific QC samples were not submitted. In these situations, to demonstrate precision and accuracy at a batch level, a LCS/LCSD may be performed, unless otherwise specified in the method.
- Surrogate and/or isotope dilution analyte recoveries (if applicable) which are outside of the QC window are confirmed unless attributed to a dilution or otherwise noted in the narrative.

Regulated compliance samples (e.g. SDWA, NPDES) must comply with the associated agency requirements/permits.

### Receipt

The samples were received on 6/25/2024 9:55 AM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice. The temperature of the cooler at receipt time was 2.5°C.

### PFAS

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.



# Detection Summary

Client: CT Male Associates DPC  
Project/Site: Hoosick Falls WTP

Job ID: 410-177298-1  
SDG: HOO

## Client Sample ID: GAC MIDFLUENT

Lab Sample ID: 410-177298-1

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Perfluorobutanoic acid	4.4		1.6	ng/L	1		537 (Mod)	Total/NA

## Client Sample ID: FTB01-240624

Lab Sample ID: 410-177298-2

No Detections.

## Client Sample ID: LTB01-240624

Lab Sample ID: 410-177298-3

No Detections.

This Detection Summary does not include radiochemical test results.

Eurofins Lancaster Laboratories Environment Testing, LLC



# Client Sample Results

Client: CT Male Associates DPC  
Project/Site: Hoosick Falls WTP

Job ID: 410-177298-1  
SDG: HOO

**Client Sample ID: GAC MIDFLUENT**

**Lab Sample ID: 410-177298-1**

Date Collected: 06/24/24 12:00

Matrix: Water

Date Received: 06/25/24 09:55

**Method: EPA 537 (Mod) - EPA 537 Version 1.1 modified**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
6:2 Fluorotelomer sulfonic acid	1.6	U	1.6	ng/L		07/15/24 07:54	07/17/24 14:04	1
8:2 Fluorotelomer sulfonic acid	1.6	U	1.6	ng/L		07/15/24 07:54	07/17/24 14:04	1
<b>Perfluorobutanoic acid</b>	<b>4.4</b>		1.6	ng/L		07/15/24 07:54	07/17/24 14:04	1
Perfluorodecanesulfonic acid	1.6	U	1.6	ng/L		07/15/24 07:54	07/17/24 14:04	1
Perfluoroheptanesulfonic acid	1.6	U	1.6	ng/L		07/15/24 07:54	07/17/24 14:04	1
Perfluorooctanesulfonamide	1.6	U	1.6	ng/L		07/15/24 07:54	07/17/24 14:04	1
Perfluoropentanoic acid	1.6	U	1.6	ng/L		07/15/24 07:54	07/17/24 14:04	1

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
M2-6:2 FTS	80		40 - 200	07/15/24 07:54	07/17/24 14:04	1
M2-8:2 FTS	84		37 - 200	07/15/24 07:54	07/17/24 14:04	1
13C4 PFBA	74		22 - 174	07/15/24 07:54	07/17/24 14:04	1
13C5 PFPeA	77		33 - 196	07/15/24 07:54	07/17/24 14:04	1
13C8 PFOS	87		59 - 155	07/15/24 07:54	07/17/24 14:04	1
13C8 FOSA	63		10 - 155	07/15/24 07:54	07/17/24 14:04	1
13C3 PFHxS	82		48 - 169	07/15/24 07:54	07/17/24 14:04	1

**Method: EPA 537.1 - EPA 537.1, Ver 1.0 Nov 2018**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
NEtFOSAA	1.6	U	1.6	ng/L		06/28/24 11:41	07/02/24 03:02	1
NMeFOSAA	1.6	U	1.6	ng/L		06/28/24 11:41	07/02/24 03:02	1
Perfluorobutanesulfonic acid	1.6	U	1.6	ng/L		06/28/24 11:41	07/02/24 03:02	1
Perfluorodecanoic acid	1.6	U	1.6	ng/L		06/28/24 11:41	07/02/24 03:02	1
Perfluorododecanoic acid	1.6	U	1.6	ng/L		06/28/24 11:41	07/02/24 03:02	1
Perfluoroheptanoic acid	1.6	U	1.6	ng/L		06/28/24 11:41	07/02/24 03:02	1
Perfluorohexanesulfonic acid	1.6	U	1.6	ng/L		06/28/24 11:41	07/02/24 03:02	1
Perfluorohexanoic acid	1.6	U	1.6	ng/L		06/28/24 11:41	07/02/24 03:02	1
Perfluorononanoic acid	1.6	U	1.6	ng/L		06/28/24 11:41	07/02/24 03:02	1
Perfluorooctanesulfonic acid	1.6	U	1.6	ng/L		06/28/24 11:41	07/02/24 03:02	1
Perfluorooctanoic acid	1.6	U	1.6	ng/L		06/28/24 11:41	07/02/24 03:02	1
Perfluorotetradecanoic acid	1.6	U	1.6	ng/L		06/28/24 11:41	07/02/24 03:02	1
Perfluorotridecanoic acid	1.6	U	1.6	ng/L		06/28/24 11:41	07/02/24 03:02	1
Perfluoroundecanoic acid	1.6	U	1.6	ng/L		06/28/24 11:41	07/02/24 03:02	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C2 PFDA	92		70 - 130	06/28/24 11:41	07/02/24 03:02	1
13C2 PFHxA	96		70 - 130	06/28/24 11:41	07/02/24 03:02	1
d5-NEtFOSAA	89		70 - 130	06/28/24 11:41	07/02/24 03:02	1



# Client Sample Results

Client: CT Male Associates DPC  
Project/Site: Hoosick Falls WTP

Job ID: 410-177298-1  
SDG: HOO

**Client Sample ID: FTB01-240624**

**Lab Sample ID: 410-177298-2**

Date Collected: 06/24/24 13:30

Matrix: Water

Date Received: 06/25/24 09:55

**Method: EPA 537 (Mod) - EPA 537 Version 1.1 modified**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
6:2 Fluorotelomer sulfonic acid	1.7	U	1.7	ng/L		07/15/24 07:54	07/17/24 14:18	1
8:2 Fluorotelomer sulfonic acid	1.7	U	1.7	ng/L		07/15/24 07:54	07/17/24 14:18	1
Perfluorobutanoic acid	1.7	U	1.7	ng/L		07/15/24 07:54	07/17/24 14:18	1
Perfluorodecanesulfonic acid	1.7	U	1.7	ng/L		07/15/24 07:54	07/17/24 14:18	1
Perfluoroheptanesulfonic acid	1.7	U	1.7	ng/L		07/15/24 07:54	07/17/24 14:18	1
Perfluorooctanesulfonamide	1.7	U	1.7	ng/L		07/15/24 07:54	07/17/24 14:18	1
Perfluoropentanoic acid	1.7	U	1.7	ng/L		07/15/24 07:54	07/17/24 14:18	1

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
M2-6:2 FTS	91		40 - 200	07/15/24 07:54	07/17/24 14:18	1
M2-8:2 FTS	92		37 - 200	07/15/24 07:54	07/17/24 14:18	1
13C4 PFBA	79		22 - 174	07/15/24 07:54	07/17/24 14:18	1
13C5 PFPeA	91		33 - 196	07/15/24 07:54	07/17/24 14:18	1
13C8 PFOS	104		59 - 155	07/15/24 07:54	07/17/24 14:18	1
13C8 FOSA	79		10 - 155	07/15/24 07:54	07/17/24 14:18	1
13C3 PFHxS	96		48 - 169	07/15/24 07:54	07/17/24 14:18	1

**Method: EPA 537.1 - EPA 537.1, Ver 1.0 Nov 2018**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
NEtFOSAA	1.7	U	1.7	ng/L		06/28/24 11:41	07/02/24 03:13	1
NMeFOSAA	1.7	U	1.7	ng/L		06/28/24 11:41	07/02/24 03:13	1
Perfluorobutanesulfonic acid	1.7	U	1.7	ng/L		06/28/24 11:41	07/02/24 03:13	1
Perfluorodecanoic acid	1.7	U	1.7	ng/L		06/28/24 11:41	07/02/24 03:13	1
Perfluorododecanoic acid	1.7	U	1.7	ng/L		06/28/24 11:41	07/02/24 03:13	1
Perfluoroheptanoic acid	1.7	U	1.7	ng/L		06/28/24 11:41	07/02/24 03:13	1
Perfluorohexanesulfonic acid	1.7	U	1.7	ng/L		06/28/24 11:41	07/02/24 03:13	1
Perfluorohexanoic acid	1.7	U	1.7	ng/L		06/28/24 11:41	07/02/24 03:13	1
Perfluorononanoic acid	1.7	U	1.7	ng/L		06/28/24 11:41	07/02/24 03:13	1
Perfluorooctanesulfonic acid	1.7	U	1.7	ng/L		06/28/24 11:41	07/02/24 03:13	1
Perfluorooctanoic acid	1.7	U	1.7	ng/L		06/28/24 11:41	07/02/24 03:13	1
Perfluorotetradecanoic acid	1.7	U	1.7	ng/L		06/28/24 11:41	07/02/24 03:13	1
Perfluorotridecanoic acid	1.7	U	1.7	ng/L		06/28/24 11:41	07/02/24 03:13	1
Perfluoroundecanoic acid	1.7	U	1.7	ng/L		06/28/24 11:41	07/02/24 03:13	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C2 PFDA	103		70 - 130	06/28/24 11:41	07/02/24 03:13	1
13C2 PFHxA	100		70 - 130	06/28/24 11:41	07/02/24 03:13	1
d5-NEtFOSAA	93		70 - 130	06/28/24 11:41	07/02/24 03:13	1

# Client Sample Results

Client: CT Male Associates DPC  
Project/Site: Hoosick Falls WTP

Job ID: 410-177298-1  
SDG: HOO

**Client Sample ID: LTB01-240624**

**Lab Sample ID: 410-177298-3**

Date Collected: 06/24/24 00:00

Matrix: Water

Date Received: 06/25/24 09:55

**Method: EPA 537 (Mod) - EPA 537 Version 1.1 modified**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
6:2 Fluorotelomer sulfonic acid	1.7	U	1.7	ng/L		07/15/24 07:54	07/17/24 14:33	1
8:2 Fluorotelomer sulfonic acid	1.7	U	1.7	ng/L		07/15/24 07:54	07/17/24 14:33	1
Perfluorobutanoic acid	1.7	U	1.7	ng/L		07/15/24 07:54	07/17/24 14:33	1
Perfluorodecanesulfonic acid	1.7	U	1.7	ng/L		07/15/24 07:54	07/17/24 14:33	1
Perfluoroheptanesulfonic acid	1.7	U	1.7	ng/L		07/15/24 07:54	07/17/24 14:33	1
Perfluorooctanesulfonamide	1.7	U	1.7	ng/L		07/15/24 07:54	07/17/24 14:33	1
Perfluoropentanoic acid	1.7	U	1.7	ng/L		07/15/24 07:54	07/17/24 14:33	1

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
M2-6:2 FTS	96		40 - 200	07/15/24 07:54	07/17/24 14:33	1
M2-8:2 FTS	107		37 - 200	07/15/24 07:54	07/17/24 14:33	1
13C4 PFBA	74		22 - 174	07/15/24 07:54	07/17/24 14:33	1
13C5 PFPeA	95		33 - 196	07/15/24 07:54	07/17/24 14:33	1
13C8 PFOS	99		59 - 155	07/15/24 07:54	07/17/24 14:33	1
13C8 FOSA	74		10 - 155	07/15/24 07:54	07/17/24 14:33	1
13C3 PFHxS	100		48 - 169	07/15/24 07:54	07/17/24 14:33	1

**Method: EPA 537.1 - EPA 537.1, Ver 1.0 Nov 2018**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
NEtFOSAA	1.9	U	1.9	ng/L		06/28/24 11:41	07/02/24 03:25	1
NMeFOSAA	1.9	U	1.9	ng/L		06/28/24 11:41	07/02/24 03:25	1
Perfluorobutanesulfonic acid	1.9	U	1.9	ng/L		06/28/24 11:41	07/02/24 03:25	1
Perfluorodecanoic acid	1.9	U	1.9	ng/L		06/28/24 11:41	07/02/24 03:25	1
Perfluorododecanoic acid	1.9	U	1.9	ng/L		06/28/24 11:41	07/02/24 03:25	1
Perfluoroheptanoic acid	1.9	U	1.9	ng/L		06/28/24 11:41	07/02/24 03:25	1
Perfluorohexanesulfonic acid	1.9	U	1.9	ng/L		06/28/24 11:41	07/02/24 03:25	1
Perfluorohexanoic acid	1.9	U	1.9	ng/L		06/28/24 11:41	07/02/24 03:25	1
Perfluorononanoic acid	1.9	U	1.9	ng/L		06/28/24 11:41	07/02/24 03:25	1
Perfluorooctanesulfonic acid	1.9	U	1.9	ng/L		06/28/24 11:41	07/02/24 03:25	1
Perfluorooctanoic acid	1.9	U	1.9	ng/L		06/28/24 11:41	07/02/24 03:25	1
Perfluorotetradecanoic acid	1.9	U	1.9	ng/L		06/28/24 11:41	07/02/24 03:25	1
Perfluorotridecanoic acid	1.9	U	1.9	ng/L		06/28/24 11:41	07/02/24 03:25	1
Perfluoroundecanoic acid	1.9	U	1.9	ng/L		06/28/24 11:41	07/02/24 03:25	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C2 PFDA	98		70 - 130	06/28/24 11:41	07/02/24 03:25	1
13C2 PFHxA	96		70 - 130	06/28/24 11:41	07/02/24 03:25	1
d5-NEtFOSAA	92		70 - 130	06/28/24 11:41	07/02/24 03:25	1

# Surrogate Summary

Client: CT Male Associates DPC  
Project/Site: Hoosick Falls WTP

Job ID: 410-177298-1  
SDG: HOO

Method: EPA 537.1 - EPA 537.1, Ver 1.0 Nov 2018

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)		
		PFDA (70-130)	PFHxA (70-130)	d5NEFOS (70-130)
410-177298-1	GAC MIDFLUENT	92	96	89
410-177298-2	FTB01-240624	103	100	93
410-177298-3	LTB01-240624	98	96	92
LCS 410-522783/2-A	Lab Control Sample	95	93	88
LCS 410-522783/3-A	Lab Control Sample Dup	90	88	94
MB 410-522783/1-A	Method Blank	95	94	94

### Surrogate Legend

PFDA = 13C2 PFDA

PFHxA = 13C2 PFHxA

d5NEFOS = d5-NEtFOSAA

# Isotope Dilution Summary

Client: CT Male Associates DPC  
 Project/Site: Hoosick Falls WTP

Job ID: 410-177298-1  
 SDG: HOO

**Method: 537 (Mod) - EPA 537 Version 1.1 modified**

**Matrix: Water**

**Prep Type: Total/NA**

Lab Sample ID	Client Sample ID	Percent Isotope Dilution Recovery (Acceptance Limits)						
		M262FTS (40-200)	M282FTS (37-200)	PFBA (22-174)	PFPeA (33-196)	C8PFOS (59-155)	PFOSA (10-155)	C3PFHS (48-169)
410-177298-1	GAC MIDFLUENT	80	84	74	77	87	63	82
410-177298-2	FTB01-240624	91	92	79	91	104	79	96
410-177298-3	LTB01-240624	96	107	74	95	99	74	100
LCS 410-528127/2-A	Lab Control Sample	86	85	78	88	95	73	93
MB 410-528127/1-A	Method Blank	94	106	90	94	101	82	103

**Surrogate Legend**

- M262FTS = M2-6:2 FTS
- M282FTS = M2-8:2 FTS
- PFBA = 13C4 PFBA
- PFPeA = 13C5 PFPeA
- C8PFOS = 13C8 PFOS
- PFOSA = 13C8 FOSA
- C3PFHS = 13C3 PFHxS



# QC Sample Results

Client: CT Male Associates DPC  
Project/Site: Hoosick Falls WTP

Job ID: 410-177298-1  
SDG: HOO

## Method: 537 (Mod) - EPA 537 Version 1.1 modified

**Lab Sample ID: MB 410-528127/1-A**  
**Matrix: Water**  
**Analysis Batch: 529017**

**Client Sample ID: Method Blank**  
**Prep Type: Total/NA**  
**Prep Batch: 528127**

Analyte	MB	MB	RL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier						
6:2 Fluorotelomer sulfonic acid	2.0	U	2.0	ng/L		07/15/24 07:54	07/17/24 08:28	1
8:2 Fluorotelomer sulfonic acid	2.0	U	2.0	ng/L		07/15/24 07:54	07/17/24 08:28	1
Perfluorobutanoic acid	2.0	U	2.0	ng/L		07/15/24 07:54	07/17/24 08:28	1
Perfluorodecanesulfonic acid	2.0	U	2.0	ng/L		07/15/24 07:54	07/17/24 08:28	1
Perfluoroheptanesulfonic acid	2.0	U	2.0	ng/L		07/15/24 07:54	07/17/24 08:28	1
Perfluorooctanesulfonamide	2.0	U	2.0	ng/L		07/15/24 07:54	07/17/24 08:28	1
Perfluoropentanoic acid	2.0	U	2.0	ng/L		07/15/24 07:54	07/17/24 08:28	1

  

Isotope Dilution	MB	MB	Limits	Prepared	Analyzed	Dil Fac
	%Recovery	Qualifier				
M2-6:2 FTS	94		40 - 200	07/15/24 07:54	07/17/24 08:28	1
M2-8:2 FTS	106		37 - 200	07/15/24 07:54	07/17/24 08:28	1
13C4 PFBA	90		22 - 174	07/15/24 07:54	07/17/24 08:28	1
13C5 PFPeA	94		33 - 196	07/15/24 07:54	07/17/24 08:28	1
13C8 PFOS	101		59 - 155	07/15/24 07:54	07/17/24 08:28	1
13C8 FOSA	82		10 - 155	07/15/24 07:54	07/17/24 08:28	1
13C3 PFHxS	103		48 - 169	07/15/24 07:54	07/17/24 08:28	1

**Lab Sample ID: LCS 410-528127/2-A**  
**Matrix: Water**  
**Analysis Batch: 529017**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 528127**

Analyte	Spike Added	LCS	LCS	Unit	D	%Rec	%Rec Limits
		Result	Qualifier				
6:2 Fluorotelomer sulfonic acid	24.3	25.1		ng/L		103	61 - 132
8:2 Fluorotelomer sulfonic acid	24.5	25.6		ng/L		105	55 - 134
Perfluorobutanoic acid	25.6	24.2		ng/L		94	58 - 130
Perfluorodecanesulfonic acid	24.7	23.9		ng/L		97	55 - 130
Perfluoroheptanesulfonic acid	24.4	19.7		ng/L		81	59 - 130
Perfluorooctanesulfonamide	25.6	24.4		ng/L		95	67 - 132
Perfluoropentanoic acid	25.6	27.3		ng/L		107	60 - 130

  

Isotope Dilution	LCS	LCS	Limits
	%Recovery	Qualifier	
M2-6:2 FTS	86		40 - 200
M2-8:2 FTS	85		37 - 200
13C4 PFBA	78		22 - 174
13C5 PFPeA	88		33 - 196
13C8 PFOS	95		59 - 155
13C8 FOSA	73		10 - 155
13C3 PFHxS	93		48 - 169

## Method: EPA 537.1 - EPA 537.1, Ver 1.0 Nov 2018

**Lab Sample ID: MB 410-522783/1-A**  
**Matrix: Water**  
**Analysis Batch: 523694**

**Client Sample ID: Method Blank**  
**Prep Type: Total/NA**  
**Prep Batch: 522783**

Analyte	MB	MB	RL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier						
NEFOSAA	2.0	U	2.0	ng/L		06/28/24 11:41	07/01/24 23:22	1
NMeFOSAA	2.0	U	2.0	ng/L		06/28/24 11:41	07/01/24 23:22	1
Perfluorobutanesulfonic acid	2.0	U	2.0	ng/L		06/28/24 11:41	07/01/24 23:22	1

# QC Sample Results

Client: CT Male Associates DPC  
Project/Site: Hoosick Falls WTP

Job ID: 410-177298-1  
SDG: HOO

## Method: EPA 537.1 - EPA 537.1, Ver 1.0 Nov 2018 (Continued)

**Lab Sample ID: MB 410-522783/1-A**  
**Matrix: Water**  
**Analysis Batch: 523694**

**Client Sample ID: Method Blank**  
**Prep Type: Total/NA**  
**Prep Batch: 522783**

Analyte	MB	MB	RL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier						
Perfluorodecanoic acid	2.0	U	2.0	ng/L		06/28/24 11:41	07/01/24 23:22	1
Perfluorododecanoic acid	2.0	U	2.0	ng/L		06/28/24 11:41	07/01/24 23:22	1
Perfluoroheptanoic acid	2.0	U	2.0	ng/L		06/28/24 11:41	07/01/24 23:22	1
Perfluorohexanesulfonic acid	2.0	U	2.0	ng/L		06/28/24 11:41	07/01/24 23:22	1
Perfluorohexanoic acid	2.0	U	2.0	ng/L		06/28/24 11:41	07/01/24 23:22	1
Perfluorononanoic acid	2.0	U	2.0	ng/L		06/28/24 11:41	07/01/24 23:22	1
Perfluorooctanesulfonic acid	2.0	U	2.0	ng/L		06/28/24 11:41	07/01/24 23:22	1
Perfluorooctanoic acid	2.0	U	2.0	ng/L		06/28/24 11:41	07/01/24 23:22	1
Perfluorotetradecanoic acid	2.0	U	2.0	ng/L		06/28/24 11:41	07/01/24 23:22	1
Perfluorotridecanoic acid	2.0	U	2.0	ng/L		06/28/24 11:41	07/01/24 23:22	1
Perfluoroundecanoic acid	2.0	U	2.0	ng/L		06/28/24 11:41	07/01/24 23:22	1

Surrogate	MB	MB	Limits	Prepared	Analyzed	Dil Fac
	%Recovery	Qualifier				
13C2 PFDA	95		70 - 130	06/28/24 11:41	07/01/24 23:22	1
13C2 PFHxA	94		70 - 130	06/28/24 11:41	07/01/24 23:22	1
d5-NEtFOSAA	94		70 - 130	06/28/24 11:41	07/01/24 23:22	1

**Lab Sample ID: LCS 410-522783/2-A**  
**Matrix: Water**  
**Analysis Batch: 523694**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 522783**

Analyte	Spike Added	LCS	LCS	Unit	D	%Rec	%Rec Limits
		Result	Qualifier				
NEtFOSAA	20.5	16.9		ng/L		82	70 - 130
NMeFOSAA	20.5	18.2		ng/L		89	70 - 130
Perfluorobutanesulfonic acid	18.1	14.3		ng/L		79	70 - 130
Perfluorodecanoic acid	20.5	18.5		ng/L		90	70 - 130
Perfluorododecanoic acid	20.5	18.8		ng/L		92	70 - 130
Perfluoroheptanoic acid	20.5	18.7		ng/L		92	70 - 130
Perfluorohexanesulfonic acid	18.7	17.4		ng/L		93	70 - 130
Perfluorohexanoic acid	20.5	18.3		ng/L		89	70 - 130
Perfluorononanoic acid	20.5	20.2		ng/L		99	70 - 130
Perfluorooctanesulfonic acid	19.0	17.3		ng/L		91	70 - 130
Perfluorooctanoic acid	20.5	19.6		ng/L		96	70 - 130
Perfluorotetradecanoic acid	20.5	18.3		ng/L		89	70 - 130
Perfluorotridecanoic acid	20.5	17.7		ng/L		86	70 - 130
Perfluoroundecanoic acid	20.5	18.7		ng/L		91	70 - 130

Surrogate	LCS	LCS	Limits
	%Recovery	Qualifier	
13C2 PFDA	95		70 - 130
13C2 PFHxA	93		70 - 130
d5-NEtFOSAA	88		70 - 130

**Lab Sample ID: LCSD 410-522783/3-A**  
**Matrix: Water**  
**Analysis Batch: 523694**

**Client Sample ID: Lab Control Sample Dup**  
**Prep Type: Total/NA**  
**Prep Batch: 522783**

Analyte	Spike Added	LCSD	LCSD	Unit	D	%Rec	%Rec Limits	RPD	Limit
		Result	Qualifier						
NEtFOSAA	20.5	17.9		ng/L		87	70 - 130	6	30

# QC Sample Results

Client: CT Male Associates DPC  
 Project/Site: Hoosick Falls WTP

Job ID: 410-177298-1  
 SDG: HOO

## Method: EPA 537.1 - EPA 537.1, Ver 1.0 Nov 2018 (Continued)

Lab Sample ID: LCSD 410-522783/3-A

Matrix: Water

Analysis Batch: 523694

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

Prep Batch: 522783

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec		RPD	Limit
							Limits	RPD		
NMeFOSAA	20.5	18.7		ng/L		91	70 - 130	3	30	
Perfluorobutanesulfonic acid	18.1	14.8		ng/L		81	70 - 130	3	30	
Perfluorodecanoic acid	20.5	17.6		ng/L		86	70 - 130	5	30	
Perfluorododecanoic acid	20.5	17.7		ng/L		86	70 - 130	6	30	
Perfluoroheptanoic acid	20.5	19.5		ng/L		95	70 - 130	4	30	
Perfluorohexanesulfonic acid	18.7	18.0		ng/L		96	70 - 130	4	30	
Perfluorohexanoic acid	20.5	17.2		ng/L		84	70 - 130	6	30	
Perfluorononanoic acid	20.5	19.2		ng/L		94	70 - 130	5	30	
Perfluorooctanesulfonic acid	19.0	17.0		ng/L		90	70 - 130	2	30	
Perfluorooctanoic acid	20.5	18.4		ng/L		90	70 - 130	6	30	
Perfluorotetradecanoic acid	20.5	16.9		ng/L		82	70 - 130	8	30	
Perfluorotridecanoic acid	20.5	17.5		ng/L		85	70 - 130	1	30	
Perfluoroundecanoic acid	20.5	18.5		ng/L		91	70 - 130	1	30	

Surrogate	LCSD		Limits
	%Recovery	Qualifier	
13C2 PFDA	90		70 - 130
13C2 PFHxA	88		70 - 130
d5-NEtFOSAA	94		70 - 130

# QC Association Summary

Client: CT Male Associates DPC  
 Project/Site: Hoosick Falls WTP

Job ID: 410-177298-1  
 SDG: HOO

## LCMS

### Prep Batch: 522783

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
410-177298-1	GAC MIDFLUENT	Total/NA	Water	537.1 DW Prep	
410-177298-2	FTB01-240624	Total/NA	Water	537.1 DW Prep	
410-177298-3	LTB01-240624	Total/NA	Water	537.1 DW Prep	
MB 410-522783/1-A	Method Blank	Total/NA	Water	537.1 DW Prep	
LCS 410-522783/2-A	Lab Control Sample	Total/NA	Water	537.1 DW Prep	
LCSD 410-522783/3-A	Lab Control Sample Dup	Total/NA	Water	537.1 DW Prep	

### Analysis Batch: 523694

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
410-177298-1	GAC MIDFLUENT	Total/NA	Water	EPA 537.1	522783
410-177298-2	FTB01-240624	Total/NA	Water	EPA 537.1	522783
410-177298-3	LTB01-240624	Total/NA	Water	EPA 537.1	522783
MB 410-522783/1-A	Method Blank	Total/NA	Water	EPA 537.1	522783
LCS 410-522783/2-A	Lab Control Sample	Total/NA	Water	EPA 537.1	522783
LCSD 410-522783/3-A	Lab Control Sample Dup	Total/NA	Water	EPA 537.1	522783

### Prep Batch: 528127

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
410-177298-1	GAC MIDFLUENT	Total/NA	Water	SPE	
410-177298-2	FTB01-240624	Total/NA	Water	SPE	
410-177298-3	LTB01-240624	Total/NA	Water	SPE	
MB 410-528127/1-A	Method Blank	Total/NA	Water	SPE	
LCS 410-528127/2-A	Lab Control Sample	Total/NA	Water	SPE	

### Analysis Batch: 529017

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
410-177298-1	GAC MIDFLUENT	Total/NA	Water	537 (Mod)	528127
410-177298-2	FTB01-240624	Total/NA	Water	537 (Mod)	528127
410-177298-3	LTB01-240624	Total/NA	Water	537 (Mod)	528127
MB 410-528127/1-A	Method Blank	Total/NA	Water	537 (Mod)	528127
LCS 410-528127/2-A	Lab Control Sample	Total/NA	Water	537 (Mod)	528127



# Lab Chronicle

Client: CT Male Associates DPC  
Project/Site: Hoosick Falls WTP

Job ID: 410-177298-1  
SDG: HOO

## Client Sample ID: GAC MIDFLUENT

Lab Sample ID: 410-177298-1

Date Collected: 06/24/24 12:00

Matrix: Water

Date Received: 06/25/24 09:55

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Batch Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	SPE			528127	WQ8R	ELLE	07/15/24 07:54
Total/NA	Analysis	537 (Mod)		1	529017	DCS9	ELLE	07/17/24 14:04
Total/NA	Prep	537.1 DW Prep			522783	HQ8B	ELLE	06/28/24 11:41
Total/NA	Analysis	EPA 537.1		1	523694	QD9Y	ELLE	07/02/24 03:02

## Client Sample ID: FTB01-240624

Lab Sample ID: 410-177298-2

Date Collected: 06/24/24 13:30

Matrix: Water

Date Received: 06/25/24 09:55

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Batch Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	SPE			528127	WQ8R	ELLE	07/15/24 07:54
Total/NA	Analysis	537 (Mod)		1	529017	DCS9	ELLE	07/17/24 14:18
Total/NA	Prep	537.1 DW Prep			522783	HQ8B	ELLE	06/28/24 11:41
Total/NA	Analysis	EPA 537.1		1	523694	QD9Y	ELLE	07/02/24 03:13

## Client Sample ID: LTB01-240624

Lab Sample ID: 410-177298-3

Date Collected: 06/24/24 00:00

Matrix: Water

Date Received: 06/25/24 09:55

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Batch Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	SPE			528127	WQ8R	ELLE	07/15/24 07:54
Total/NA	Analysis	537 (Mod)		1	529017	DCS9	ELLE	07/17/24 14:33
Total/NA	Prep	537.1 DW Prep			522783	HQ8B	ELLE	06/28/24 11:41
Total/NA	Analysis	EPA 537.1		1	523694	QD9Y	ELLE	07/02/24 03:25

### Laboratory References:

ELLE = Eurofins Lancaster Laboratories Environment Testing, LLC, 2425 New Holland Pike, Lancaster, PA 17601, TEL (717)656-2300

# Accreditation/Certification Summary

Client: CT Male Associates DPC  
Project/Site: Hoosick Falls WTP

Job ID: 410-177298-1  
SDG: HOO

## Laboratory: Eurofins Lancaster Laboratories Environment Testing, LLC

Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below.

Authority	Program	Identification Number	Expiration Date
New York	NELAP	10670	04-01-25

The following analytes are included in this report, but the laboratory is not certified by the governing authority. This list may include analytes for which the agency does not offer certification.

Analysis Method	Prep Method	Matrix	Analyte
537 (Mod)	SPE	Water	6:2 Fluorotelomer sulfonic acid
537 (Mod)	SPE	Water	8:2 Fluorotelomer sulfonic acid
537 (Mod)	SPE	Water	Perfluorobutanoic acid
537 (Mod)	SPE	Water	Perfluorodecanesulfonic acid
537 (Mod)	SPE	Water	Perfluoroheptanesulfonic acid
537 (Mod)	SPE	Water	Perfluorooctanesulfonamide
537 (Mod)	SPE	Water	Perfluoropentanoic acid



# Method Summary

Client: CT Male Associates DPC  
Project/Site: Hoosick Falls WTP

Job ID: 410-177298-1  
SDG: HOO

Method	Method Description	Protocol	Laboratory
537 (Mod)	EPA 537 Version 1.1 modified	EPA	ELLE
EPA 537.1	EPA 537.1, Ver 1.0 Nov 2018	EPA	ELLE
537.1 DW Prep	Extraction of Perfluorinated Alkyl Acids	EPA	ELLE
SPE	PFAS by SPE	Lab SOP	ELLE

**Protocol References:**

EPA = US Environmental Protection Agency  
Lab SOP = Laboratory Standard Operating Procedure

**Laboratory References:**

ELLE = Eurofins Lancaster Laboratories Environment Testing, LLC, 2425 New Holland Pike, Lancaster, PA 17601, TEL (717)656-2300



# Sample Summary

Client: CT Male Associates DPC  
Project/Site: Hoosick Falls WTP

Job ID: 410-177298-1  
SDG: HOO

---

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
410-177298-1	GAC MIDFLUENT	Water	06/24/24 12:00	06/25/24 09:55
410-177298-2	FTB01-240624	Water	06/24/24 13:30	06/25/24 09:55
410-177298-3	LTB01-240624	Water	06/24/24 00:00	06/25/24 09:55

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16



## Login Sample Receipt Checklist

Client: CT Male Associates DPC

Job Number: 410-177298-1

SDG Number: HOO

**Login Number: 177298**

**List Source: Eurofins Lancaster Laboratories Environment Testing, LLC**

**List Number: 1**

**Creator: Reiff, Nicole L**

Question	Answer	Comment
The cooler's custody seal is intact.	True	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	
Cooler Temperature acceptable, where thermal pres is required (<math>\leq 6^{\circ}\text{C}</math>, not frozen).	True	
Cooler Temperature is recorded.	True	
WV: Container Temp acceptable, where thermal pres is required (<math>\leq 6^{\circ}\text{C}</math>, not frozen).	N/A	
WV: Container Temperature is recorded.	N/A	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the containers received and the COC.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
There is sufficient vol. for all requested analyses.	True	
Is the Field Sampler's name present on COC?	True	
Sample custody seals are intact.	True	
VOA sample vials do not have headspace >6mm in diameter (none, if from WV)?	N/A	

