

12/1/14

### Lab Analysis Results

EPA range is measured in micrograms per liter.  
Lab analysis was measured in nanograms per liter.

micrograms per liter = ppb (parts per **billion**)  
nanograms per liter = ppt (parts per **trillion**)

The EPA benchmark range converted from micrograms per liter to nanograms per liter=  
0.2 - 0.4 micrograms per liter = 200 - 400 nanograms per liter.

Results from the samples to date:

Sample 1 Pre-treated:	Well 3	Well 6	Well 7
	230	280	540

Sample 2 Pre-treated:	170	280	450
-----------------------	-----	-----	-----

Sample 1 Treated = 440

Sample 2 Treated = TBD

As a result of Sample 1, well 3 replaced well 7 as the prime water supply.