

New York State Department of Health Wadsworth Center

Biggs Laboratory
PO Box 509
Albany, NY 12201
CLIA# 33D0654341

David Axelrod Institute
120 New Scotland Avenue
Albany, NY 12208
CLIA# 33D2005937

Griffin Laboratory
5668 State Farm Road
Slingerlands, NY 12159
CLIA# 33D2005935

Report No: **EHS1600057996-SR-1**

Page 1 of 1

Report Date: **01/06/2017**

Report retrieved via NYSDOH Health Commerce System by Irw03 on 03/09/2017

REQUESTED BY: DIRECTOR-WCENVIRO

DIRECTOR'S OFFICE
DIVISION OF ENVIRONMENTAL HEALTH SCIENCES
WADSWORTH CENTER
PO BOX 509
EMPIRE STATE PLAZA
ALBANY NY 12201-0509

Wadsworth Center - Environmental Labs

County: RENNELAER
City (or) Town: HOOSICK FALLS
Submitted by: DAVE PHILLIPS
Collected by:

Submitter's Reference Number: HF01

Grab/Collection Date: 12/22/2016 09:10

Date received: 12/22/2016 14:30

OUTBREAK #: HFPFOA

Location/Project/Facility Name: NY4100041, HOOSICK FALLS (V) PWS - HOOSICK FALLS
Sampling Location Details: TEMP GAC INFLUENT
Chlorinated: Yes

FINAL LABORATORY REPORT

Biggs Laboratory
NYSELAP ID: 10763

Laboratory of Organic Analytical Chemistry
Lab Director: Dr. K. Kannan
Contact: Dr. David Spink 518-486-2530

Sample Id: EHS1600057996-01

Sample Type: Finished Water

Received Temperature (°C): **5.1**

Lab Tracking Id: HF01

Perfluoroalkyl Substances (PFASs) in Drinking Water by Ultra Performance Liquid Chromatography (UPLC) Tandem Mass Spectrometry (MS/MS): ISO 25101

Start Date: 12/23/2016 Analysis Date: 12/27/2016

Perfluorobutanesulfonic acid (PFBS): **<1.77 ng/L**

Perfluorohexanesulfonic acid (PFHxS): **<1.89 ng/L**

Perfluoroheptanoic acid (PFHpA): **12.3 ng/L**

Perfluorooctanoic acid (PFOA): **477 ng/L**

NYSELAP

Perfluorooctanesulfonic acid (PFOS): **4.79 ng/L**

NYSELAP

Perfluorononanoic acid (PFNA): **<2.00 ng/L**

The purpose of our sampling is to analyze for PFOA and/or PFOS, as per ISO 25101:2009 (E) method. This test includes four additional Perfluorinated Chemicals (PFCs): perfluorobutanesulfonic acid (PFBS), perfluorohexanesulfonic acid (PFHxS), perfluoroheptanoic acid (PFHpA), perfluorononanoic acid (PFNA) that have been validated by the laboratory. These other PFCs may have been detected at very low concentrations-EPA has not established health advisories for these chemicals. All six PFCs are effectively removed from drinking water by granular activated carbon filtration systems.

NYSELAP: Accredited by the New York State Environmental Laboratory Approval Program

END OF REPORT

The Laboratory Director authorizes the release of this report. The results in this report relate only to the sample submitted to the laboratory.

New York State Department of Health Wadsworth Center

Biggs Laboratory
PO Box 509
Albany, NY 12201
CLIA# 33D0654341

David Axelrod Institute
120 New Scotland Avenue
Albany, NY 12208
CLIA# 33D2005937

Griffin Laboratory
5668 State Farm Road
Slingerlands, NY 12159
CLIA# 33D2005935

Report No: **EHS1600057997-SR-1**

Page 1 of 1

Report Date: **01/06/2017**

Report retrieved via NYSDOH Health Commerce System by Irw03 on 03/09/2017

REQUESTED BY: DIRECTOR-WCENVIRO

DIRECTOR'S OFFICE
DIVISION OF ENVIRONMENTAL HEALTH SCIENCES
WADSWORTH CENTER
PO BOX 509
EMPIRE STATE PLAZA
ALBANY NY 12201-0509

Wadsworth Center - Environmental Labs

County: RENNELAER
City (or) Town: HOOSICK FALLS
Submitted by: DAVE PHILLIPS
Collected by:

Submitter's Reference Number: HF02

Grab/Collection Date: 12/22/2016 09:15
Date received: 12/22/2016 14:30

OUTBREAK #: HFPFOA

Location/Project/Facility Name: NY4100041, HOOSICK FALLS (V) PWS - HOOSICK FALLS
Sampling Location Details: TEMP GAC MID POINT
Chlorinated: No

FINAL LABORATORY REPORT

Biggs Laboratory
NYSELAP ID: 10763

Laboratory of Organic Analytical Chemistry
Lab Director: Dr. K. Kannan
Contact: Dr. David Spink 518-486-2530

Sample Id: EHS1600057997-01

Sample Type: Finished Water

Received Temperature (°C): **5.6**

Lab Tracking Id: HF02

Perfluoroalkyl Substances (PFASs) in Drinking Water by Ultra Performance Liquid Chromatography (UPLC) Tandem Mass Spectrometry (MS/MS): ISO 25101

Start Date: 12/23/2016 Analysis Date: 12/27/2016

Perfluorobutanesulfonic acid (PFBS): **<1.77 ng/L**
Perfluorohexanesulfonic acid (PFHxS): **<1.89 ng/L**
Perfluoroheptanoic acid (PFHpA): **<2.00 ng/L**
Perfluorooctanoic acid (PFOA): **9.02 ng/L**
Perfluorooctanesulfonic acid (PFOS): **<1.91 ng/L**
Perfluorononanoic acid (PFNA): **<2.00 ng/L**

NYSELAP

NYSELAP

The purpose of our sampling is to analyze for PFOA and/or PFOS, as per ISO 25101:2009 (E) method. This test includes four additional Perfluorinated Chemicals (PFCs): perfluorobutanesulfonic acid (PFBS), perfluorohexanesulfonic acid (PFHxS), perfluoroheptanoic acid (PFHpA), perfluorononanoic acid (PFNA) that have been validated by the laboratory. These other PFCs may have been detected at very low concentrations-EPA has not established health advisories for these chemicals. All six PFCs are effectively removed from drinking water by granular activated carbon filtration systems.

NYSELAP: Accredited by the New York State Environmental Laboratory Approval Program

END OF REPORT

The Laboratory Director authorizes the release of this report. The results in this report relate only to the sample submitted to the laboratory.

New York State Department of Health Wadsworth Center

Biggs Laboratory
PO Box 509
Albany, NY 12201
CLIA# 33D0654341

David Axelrod Institute
120 New Scotland Avenue
Albany, NY 12208
CLIA# 33D2005937

Griffin Laboratory
5668 State Farm Road
Slingerlands, NY 12159
CLIA# 33D2005935

Report No: **EHS1600057998-SR-1**

Page 1 of 1

Report Date: **01/06/2017**

Report retrieved via NYSDOH Health Commerce System by Irw03 on 03/09/2017

REQUESTED BY: DIRECTOR-WCENVIRO

DIRECTOR'S OFFICE
DIVISION OF ENVIRONMENTAL HEALTH SCIENCES
WADSWORTH CENTER
PO BOX 509
EMPIRE STATE PLAZA
ALBANY NY 12201-0509

Wadsworth Center - Environmental Labs

County: RENNELAER
City (or) Town: HOOSICK FALLS
Submitted by: DAVE PHILLIPS
Collected by:

Submitter's Reference Number: HF03

Grab/Collection Date: 12/22/2016 09:15

Date received: 12/22/2016 14:30

OUTBREAK #: HFPFOA

Location/Project/Facility Name: NY4100041, HOOSICK FALLS (V) PWS - HOOSICK FALLS
Sampling Location Details: TEMP GAC MID POINT - DUP
Chlorinated: No

FINAL LABORATORY REPORT

Biggs Laboratory
NYSELAP ID: 10763

Laboratory of Organic Analytical Chemistry
Lab Director: Dr. K. Kannan
Contact: Dr. David Spink 518-486-2530

Sample Id: EHS1600057998-01

Sample Type: Finished Water

Received Temperature (°C): **6.1**

Lab Tracking Id: HF03

Perfluoroalkyl Substances (PFASs) in Drinking Water by Ultra Performance Liquid Chromatography (UPLC) Tandem Mass Spectrometry (MS/MS): ISO 25101

Start Date: 12/23/2016 Analysis Date: 12/27/2016

Perfluorobutanesulfonic acid (PFBS): **<1.77 ng/L**

Perfluorohexanesulfonic acid (PFHxS): **<1.89 ng/L**

Perfluoroheptanoic acid (PFHpA): **3.94 ng/L**

Perfluorooctanoic acid (PFOA): **11.0 ng/L**

NYSELAP

Perfluorooctanesulfonic acid (PFOS): **<1.91 ng/L**

NYSELAP

Perfluorononanoic acid (PFNA): **3.26 ng/L**

The purpose of our sampling is to analyze for PFOA and/or PFOS, as per ISO 25101:2009 (E) method. This test includes four additional Perfluorinated Chemicals (PFCs): perfluorobutanesulfonic acid (PFBS), perfluorohexanesulfonic acid (PFHxS), perfluoroheptanoic acid (PFHpA), perfluorononanoic acid (PFNA) that have been validated by the laboratory. These other PFCs may have been detected at very low concentrations-EPA has not established health advisories for these chemicals. All six PFCs are effectively removed from drinking water by granular activated carbon filtration systems.

NYSELAP: Accredited by the New York State Environmental Laboratory Approval Program

END OF REPORT

The Laboratory Director authorizes the release of this report. The results in this report relate only to the sample submitted to the laboratory.

New York State Department of Health Wadsworth Center

Biggs Laboratory
PO Box 509
Albany, NY 12201
CLIA# 33D0654341

David Axelrod Institute
120 New Scotland Avenue
Albany, NY 12208
CLIA# 33D2005937

Griffin Laboratory
5668 State Farm Road
Slingerlands, NY 12159
CLIA# 33D2005935

Report No: **EHS1600057999-SR-1**

Page 1 of 1

Report Date: **01/06/2017**

Report retrieved via NYSDOH Health Commerce System by Irw03 on 03/09/2017

REQUESTED BY: DIRECTOR-WCENVIRO

DIRECTOR'S OFFICE
DIVISION OF ENVIRONMENTAL HEALTH SCIENCES
WADSWORTH CENTER
PO BOX 509
EMPIRE STATE PLAZA
ALBANY NY 12201-0509

Wadsworth Center - Environmental Labs

County: RENNELAER
City (or) Town: HOOSICK FALLS
Submitted by: DAVE PHILLIPS
Collected by:

Submitter's Reference Number: HF04

Grab/Collection Date: 12/22/2016 09:20
Date received: 12/22/2016 14:30

OUTBREAK #: HFPFOA

Location/Project/Facility Name: NY4100041, HOOSICK FALLS (V) PWS - HOOSICK FALLS
Sampling Location Details: TEMP GAC EFFLUENT
Chlorinated: No

FINAL LABORATORY REPORT

Biggs Laboratory
NYSELAP ID: 10763

Laboratory of Organic Analytical Chemistry
Lab Director: Dr. K. Kannan
Contact: Dr. David Spink 518-486-2530

Sample Id: EHS1600057999-01

Sample Type: Finished Water

Received Temperature (°C): **7.2**

Lab Tracking Id: HF04

Perfluoroalkyl Substances (PFASs) in Drinking Water by Ultra Performance Liquid Chromatography (UPLC) Tandem Mass Spectrometry (MS/MS): ISO 25101

Start Date: 12/23/2016 Analysis Date: 12/27/2016

Perfluorobutanesulfonic acid (PFBS): **<1.77 ng/L**
Perfluorohexanesulfonic acid (PFHxS): **<1.89 ng/L**
Perfluoroheptanoic acid (PFHpA): **2.76 ng/L**
Perfluorooctanoic acid (PFOA): **2.41 ng/L**
Perfluorooctanesulfonic acid (PFOS): **<1.91 ng/L**
Perfluorononanoic acid (PFNA): **3.04 ng/L**

NYSELAP

NYSELAP

The purpose of our sampling is to analyze for PFOA and/or PFOS, as per ISO 25101:2009 (E) method. This test includes four additional Perfluorinated Chemicals (PFCs): perfluorobutanesulfonic acid (PFBS), perfluorohexanesulfonic acid (PFHxS), perfluoroheptanoic acid (PFHpA), perfluorononanoic acid (PFNA) that have been validated by the laboratory. These other PFCs may have been detected at very low concentrations-EPA has not established health advisories for these chemicals. All six PFCs are effectively removed from drinking water by granular activated carbon filtration systems.

NYSELAP: Accredited by the New York State Environmental Laboratory Approval Program

END OF REPORT

The Laboratory Director authorizes the release of this report. The results in this report relate only to the sample submitted to the laboratory.

New York State Department of Health Wadsworth Center

Biggs Laboratory
PO Box 509
Albany, NY 12201
CLIA# 33D0654341

David Axelrod Institute
120 New Scotland Avenue
Albany, NY 12208
CLIA# 33D2005937

Griffin Laboratory
5668 State Farm Road
Slingerlands, NY 12159
CLIA# 33D2005935

Report No: **EHS1600058000-SR-1**

Page 1 of 1

Report Date: **01/06/2017**

Report retrieved via NYSDOH Health Commerce System by Irw03 on 03/09/2017

REQUESTED BY: DIRECTOR-WCENVIRO

DIRECTOR'S OFFICE
DIVISION OF ENVIRONMENTAL HEALTH SCIENCES
WADSWORTH CENTER
PO BOX 509
EMPIRE STATE PLAZA
ALBANY NY 12201-0509

Wadsworth Center - Environmental Labs

County: RENNELAER
City (or) Town: HOOSICK FALLS
Submitted by: DAVE PHILLIPS
Collected by:

Submitter's Reference Number: HF05

Grab/Collection Date: 12/22/2016 09:35
Date received: 12/22/2016 14:30

OUTBREAK #: HFPFOA

Location/Project/Facility Name: NY4100041, HOOSICK FALLS (V) PWS - HOOSICK FALLS
Sampling Location Details: DPW GARAGE BATHROOM CWT
Chlorinated: Yes

FINAL LABORATORY REPORT

Biggs Laboratory
NYSELAP ID: 10763

Laboratory of Organic Analytical Chemistry
Lab Director: Dr. K. Kannan
Contact: Dr. David Spink 518-486-2530

Sample Id: EHS1600058000-01

Sample Type: Finished Water

Received Temperature (°C): **5.1**

Lab Tracking Id: HF05

Perfluoroalkyl Substances (PFASs) in Drinking Water by Ultra Performance Liquid Chromatography (UPLC) Tandem Mass Spectrometry (MS/MS): ISO 25101

Start Date: 12/23/2016 Analysis Date: 12/27/2016

Perfluorobutanesulfonic acid (PFBS): **<1.77 ng/L**
Perfluorohexanesulfonic acid (PFHxS): **<1.89 ng/L**
Perfluoroheptanoic acid (PFHpA): **<2.00 ng/L**
Perfluorooctanoic acid (PFOA): **<2.00 ng/L**
Perfluorooctanesulfonic acid (PFOS): **<1.91 ng/L**
Perfluorononanoic acid (PFNA): **<2.00 ng/L**

NYSELAP
NYSELAP

The purpose of our sampling is to analyze for PFOA and/or PFOS, as per ISO 25101:2009 (E) method. This test includes four additional Perfluorinated Chemicals (PFCs): perfluorobutanesulfonic acid (PFBS), perfluorohexanesulfonic acid (PFHxS), perfluoroheptanoic acid (PFHpA), perfluorononanoic acid (PFNA) that have been validated by the laboratory. These other PFCs may have been detected at very low concentrations-EPA has not established health advisories for these chemicals. All six PFCs are effectively removed from drinking water by granular activated carbon filtration systems.

NYSELAP: Accredited by the New York State Environmental Laboratory Approval Program

END OF REPORT

The Laboratory Director authorizes the release of this report. The results in this report relate only to the sample submitted to the laboratory.

New York State Department of Health Wadsworth Center

Biggs Laboratory
PO Box 509
Albany, NY 12201
CLIA# 33D0654341

David Axelrod Institute
120 New Scotland Avenue
Albany, NY 12208
CLIA# 33D2005937

Griffin Laboratory
5668 State Farm Road
Slingerlands, NY 12159
CLIA# 33D2005935

Report No: **EHS1600058001-SR-1**

Page 1 of 1

Report Date: **01/06/2017**

Report retrieved via NYSDOH Health Commerce System by Irw03 on 03/09/2017

REQUESTED BY: DIRECTOR-WCENVIRO

DIRECTOR'S OFFICE
DIVISION OF ENVIRONMENTAL HEALTH SCIENCES
WADSWORTH CENTER
PO BOX 509
EMPIRE STATE PLAZA
ALBANY NY 12201-0509

Wadsworth Center - Environmental Labs

County: RENNELAER
City (or) Town: HOOSICK FALLS
Submitted by: DAVE PHILLIPS
Collected by:

Submitter's Reference Number: HF06

Grab/Collection Date: 12/22/2016 09:45
Date received: 12/22/2016 14:30

OUTBREAK #: HFPFOA

Location/Project/Facility Name: NY4100041, HOOSICK FALLS (V) PWS - HOOSICK FALLS
Sampling Location Details: VILLAGE HALL MENS ROOM CWT
Chlorinated: Yes

FINAL LABORATORY REPORT

Biggs Laboratory
NYSELAP ID: 10763

Laboratory of Organic Analytical Chemistry
Lab Director: Dr. K. Kannan
Contact: Dr. David Spink 518-486-2530

Sample Id: EHS1600058001-01

Sample Type: Finished Water

Received Temperature (°C): **7.7**

Lab Tracking Id: HF06

Perfluoroalkyl Substances (PFASs) in Drinking Water by Ultra Performance Liquid Chromatography (UPLC) Tandem Mass Spectrometry (MS/MS): ISO 25101

Start Date: 12/23/2016 Analysis Date: 12/27/2016

Perfluorobutanesulfonic acid (PFBS): **<1.77 ng/L**
Perfluorohexanesulfonic acid (PFHxS): **<1.89 ng/L**
Perfluoroheptanoic acid (PFHpA): **<2.00 ng/L**
Perfluorooctanoic acid (PFOA): **<2.00 ng/L**
Perfluorooctanesulfonic acid (PFOS): **<1.91 ng/L**
Perfluorononanoic acid (PFNA): **<2.00 ng/L**

NYSELAP

NYSELAP

The purpose of our sampling is to analyze for PFOA and/or PFOS, as per ISO 25101:2009 (E) method. This test includes four additional Perfluorinated Chemicals (PFCs): perfluorobutanesulfonic acid (PFBS), perfluorohexanesulfonic acid (PFHxS), perfluoroheptanoic acid (PFHpA), perfluorononanoic acid (PFNA) that have been validated by the laboratory. These other PFCs may have been detected at very low concentrations-EPA has not established health advisories for these chemicals. All six PFCs are effectively removed from drinking water by granular activated carbon filtration systems.

NYSELAP: Accredited by the New York State Environmental Laboratory Approval Program

END OF REPORT

The Laboratory Director authorizes the release of this report. The results in this report relate only to the sample submitted to the laboratory.

New York State Department of Health Wadsworth Center

Biggs Laboratory
PO Box 509
Albany, NY 12201
CLIA# 33D0654341

David Axelrod Institute
120 New Scotland Avenue
Albany, NY 12208
CLIA# 33D2005937

Griffin Laboratory
5668 State Farm Road
Slingerlands, NY 12159
CLIA# 33D2005935

Report No: **EHS1600058002-SR-1**

Page 1 of 1

Report Date: **01/06/2017**

Report retrieved via NYSDOH Health Commerce System by Irw03 on 03/09/2017

REQUESTED BY: DIRECTOR-WCENVIRO

DIRECTOR'S OFFICE
DIVISION OF ENVIRONMENTAL HEALTH SCIENCES
WADSWORTH CENTER
PO BOX 509
EMPIRE STATE PLAZA
ALBANY NY 12201-0509

Wadsworth Center - Environmental Labs

County: RENSSELAER
Submitted by: DAVE PHILLIPS
Collected by:

Submitter's Reference Number: FRB

Grab/Collection Date: 12/22/2016
Date received: 12/22/2016 14:30

Location/Project/Facility Name: FIELD REAGENT BLANK

Sampling Location Details: PREPARED ON: 12/13/16 - WITH SAMPLE(S): EHS1600057996 - 58001

FINAL LABORATORY REPORT

Biggs Laboratory
NYS ELAP ID: 10763

Laboratory of Organic Analytical Chemistry
Lab Director: Dr. K. Kannan
Contact: Dr. David Spink 518-486-2530

Sample Id: EHS1600058002-01

Sample Type: Field Blank

Received Temperature (°C): **7.6**

Lab Tracking Id: FRB

Perfluoroalkyl Substances (PFASs) in Drinking Water by Ultra Performance Liquid Chromatography (UPLC) Tandem Mass Spectrometry (MS/MS): ISO 25101

Start Date: 12/23/2016 Analysis Date: 12/27/2016

Perfluorobutanesulfonic acid (PFBS):	<1.77 ng/L
Perfluorohexanesulfonic acid (PFHxS):	<1.89 ng/L
Perfluoroheptanoic acid (PFHpA):	<2.00 ng/L
Perfluorooctanoic acid (PFOA):	<2.00 ng/L
Perfluorooctanesulfonic acid (PFOS):	<1.91 ng/L
Perfluorononanoic acid (PFNA):	<2.00 ng/L

NYSELAP

NYSELAP

The purpose of our sampling is to analyze for PFOA and/or PFOS, as per ISO 25101:2009 (E) method. This test includes four additional Perfluorinated Chemicals (PFCs): perfluorobutanesulfonic acid (PFBS), perfluorohexanesulfonic acid (PFHxS), perfluoroheptanoic acid (PFHpA), perfluorononanoic acid (PFNA) that have been validated by the laboratory. These other PFCs may have been detected at very low concentrations-EPA has not established health advisories for these chemicals. All six PFCs are effectively removed from drinking water by granular activated carbon filtration systems.

NYSELAP: Accredited by the New York State Environmental Laboratory Approval Program

END OF REPORT

The Laboratory Director authorizes the release of this report. The results in this report relate only to the sample submitted to the laboratory.

New York State Department of Health Wadsworth Center

Biggs Laboratory
PO Box 509
Albany, NY 12201
CLIA# 33D0654341

David Axelrod Institute
120 New Scotland Avenue
Albany, NY 12208
CLIA# 33D2005937

Griffin Laboratory
5668 State Farm Road
Slingerlands, NY 12159
CLIA# 33D2005935

Report No: **EHS1600058003-SR-1**

Page 1 of 1

Report Date: **01/06/2017**

Report retrieved via NYSDOH Health Commerce System by Irw03 on 03/09/2017

REQUESTED BY: DIRECTOR-WCENVIRO

DIRECTOR'S OFFICE
DIVISION OF ENVIRONMENTAL HEALTH SCIENCES
WADSWORTH CENTER
PO BOX 509
EMPIRE STATE PLAZA
ALBANY NY 12201-0509

Wadsworth Center - Environmental Labs

County: RENNELAER
Submitted by: JEFFREY WINERITER
Collected by:

Submitter's Reference Number: LRB

Grab/Collection Date: 12/22/2016
Date received: 12/22/2016 14:30

Location/Project/Facility Name: LABORATORY REAGENT BLANK
Sampling Location Details: PREPARED ON: 12/22/16 - EXTRACTED WITH: EHS1600057996 - 58001

FINAL LABORATORY REPORT

Biggs Laboratory
NYS ELAP ID: 10763

Laboratory of Organic Analytical Chemistry
Lab Director: Dr. K. Kannan
Contact: Dr. David Spink 518-486-2530

Sample Id: EHS1600058003-01

Sample Type: Method Blank

Lab Tracking Id: LRB

Perfluoroalkyl Substances (PFASs) in Drinking Water by Ultra Performance Liquid Chromatography (UPLC) Tandem Mass Spectrometry (MS/MS): ISO 25101

Start Date: 12/23/2016 Analysis Date: 12/27/2016

Perfluorobutanesulfonic acid (PFBS):	<1.77 ng/L
Perfluorohexanesulfonic acid (PFHxS):	<1.89 ng/L
Perfluoroheptanoic acid (PFHpA):	<2.00 ng/L
Perfluorooctanoic acid (PFOA):	<2.00 ng/L
Perfluorooctanesulfonic acid (PFOS):	<1.91 ng/L
Perfluorononanoic acid (PFNA):	<2.00 ng/L

NYSELAP

NYSELAP

The purpose of our sampling is to analyze for PFOA and/or PFOS, as per ISO 25101:2009 (E) method. This test includes four additional Perfluorinated Chemicals (PFCs): perfluorobutanesulfonic acid (PFBS), perfluorohexanesulfonic acid (PFHxS), perfluoroheptanoic acid (PFHpA), perfluorononanoic acid (PFNA) that have been validated by the laboratory. These other PFCs may have been detected at very low concentrations-EPA has not established health advisories for these chemicals. All six PFCs are effectively removed from drinking water by granular activated carbon filtration systems.

NYSELAP: Accredited by the New York State Environmental Laboratory Approval Program

END OF REPORT

The Laboratory Director authorizes the release of this report. The results in this report relate only to the sample submitted to the laboratory.

New York State Department of Health Wadsworth Center

Biggs Laboratory
PO Box 509
Albany, NY 12201
CLIA# 33D0654341

David Axelrod Institute
120 New Scotland Avenue
Albany, NY 12208
CLIA# 33D2005937

Griffin Laboratory
5668 State Farm Road
Slingerlands, NY 12159
CLIA# 33D2005935

Report No: **EHS1600058654-SR-1**

Page 1 of 1

Report Date: **01/06/2017**

Report retrieved via NYSDOH Health Commerce System by Irw03 on 03/09/2017

REQUESTED BY: DIRECTOR-WCENVIRO

DIRECTOR'S OFFICE
DIVISION OF ENVIRONMENTAL HEALTH SCIENCES
WADSWORTH CENTER
PO BOX 509
EMPIRE STATE PLAZA
ALBANY NY 12201-0509

Wadsworth Center - Environmental Labs

County: RENSSELAER
City (or) Town: HOOSICK FALLS
Submitted by: T. VICKERSON
Collected by:

Submitter's Reference Number: HF1

Grab/Collection Date: 12/29/2016 09:05

Date received: 12/29/2016 14:00

OUTBREAK #: HFPFOA

Location/Project/Facility Name: NY4100041, HOOSICK FALLS (V) PWS - HOOSICK FALLS
Sampling Location Details: TEMPORARY GAC EFFLUENT
Chlorinated: No

FINAL LABORATORY REPORT

Biggs Laboratory
NYSELAP ID: 10763

Laboratory of Organic Analytical Chemistry
Lab Director: Dr. K. Kannan
Contact: Dr. David Spink 518-486-2530

Sample Id: EHS1600058654-01

Sample Type: Finished Water

Received Temperature (°C): **9.9**

Lab Tracking Id: HF1

Perfluoroalkyl Substances (PFASs) in Drinking Water by Ultra Performance Liquid Chromatography (UPLC) Tandem Mass Spectrometry (MS/MS): ISO 25101

Start Date: 12/30/2016 Analysis Date: 12/30/2016

Perfluorobutanesulfonic acid (PFBS): **<1.77 ng/L**
Perfluorohexanesulfonic acid (PFHxS): **<1.89 ng/L**
Perfluoroheptanoic acid (PFHpA): **<2.00 ng/L**
Perfluorooctanoic acid (PFOA): **<2.00 ng/L**
Perfluorooctanesulfonic acid (PFOS): **<1.91 ng/L**
Perfluorononanoic acid (PFNA): **<2.00 ng/L**

NYSELAP

NYSELAP

The purpose of our sampling is to analyze for PFOA and/or PFOS, as per ISO 25101:2009 (E) method. This test includes four additional Perfluorinated Chemicals (PFCs): perfluorobutanesulfonic acid (PFBS), perfluorohexanesulfonic acid (PFHxS), perfluoroheptanoic acid (PFHpA), perfluorononanoic acid (PFNA) that have been validated by the laboratory. These other PFCs may have been detected at very low concentrations-EPA has not established health advisories for these chemicals. All six PFCs are effectively removed from drinking water by granular activated carbon filtration systems.

NYSELAP: Accredited by the New York State Environmental Laboratory Approval Program

END OF REPORT

The Laboratory Director authorizes the release of this report. The results in this report relate only to the sample submitted to the laboratory.

New York State Department of Health Wadsworth Center

Biggs Laboratory
PO Box 509
Albany, NY 12201
CLIA# 33D0654341

David Axelrod Institute
120 New Scotland Avenue
Albany, NY 12208
CLIA# 33D2005937

Griffin Laboratory
5668 State Farm Road
Slingerlands, NY 12159
CLIA# 33D2005935

Report No: **EHS1600058655-SR-1**

Page 1 of 1

Report Date: **01/06/2017**

Report retrieved via NYSDOH Health Commerce System by Irw03 on 03/09/2017

REQUESTED BY: DIRECTOR-WCENVIRO

DIRECTOR'S OFFICE
DIVISION OF ENVIRONMENTAL HEALTH SCIENCES
WADSWORTH CENTER
PO BOX 509
EMPIRE STATE PLAZA
ALBANY NY 12201-0509

Wadsworth Center - Environmental Labs

County: RENSSELAER
City (or) Town: HOOSICK FALLS
Submitted by: T. VICKERSON
Collected by:

Submitter's Reference Number: HF2

Grab/Collection Date: 12/29/2016 09:06

Date received: 12/29/2016 14:00

OUTBREAK #: HFPFOA

Location/Project/Facility Name: NY4100041, HOOSICK FALLS (V) PWS - HOOSICK FALLS
Sampling Location Details: TEMPORARY GAC MIDWAY
HOOSICK FALLS NY
Chlorinated: No

FINAL LABORATORY REPORT

Biggs Laboratory
NYS ELAP ID: 10763

Laboratory of Organic Analytical Chemistry
Lab Director: Dr. K. Kannan
Contact: Dr. David Spink 518-486-2530

Sample Id: EHS1600058655-01

Sample Type: Finished Water

Received Temperature (°C): **10.8**

Received State: **Cooling**

Lab Tracking Id: HF2

Perfluoroalkyl Substances (PFASs) in Drinking Water by Ultra Performance Liquid Chromatography (UPLC) Tandem Mass Spectrometry (MS/MS): ISO 25101

Start Date: 12/30/2016 Analysis Date: 12/30/2016

Perfluorobutanesulfonic acid (PFBS): **<1.77 ng/L**

Perfluorohexanesulfonic acid (PFHxS): **<1.89 ng/L**

Perfluoroheptanoic acid (PFHpA): **<2.00 ng/L**

Perfluorooctanoic acid (PFOA): **9.25 ng/L**

NYSELAP

Perfluorooctanesulfonic acid (PFOS): **<1.91 ng/L**

NYSELAP

Perfluorononanoic acid (PFNA): **<2.00 ng/L**

The purpose of our sampling is to analyze for PFOA and/or PFOS, as per ISO 25101:2009 (E) method. This test includes four additional Perfluorinated Chemicals (PFCs): perfluorobutanesulfonic acid (PFBS), perfluorohexanesulfonic acid (PFHxS), perfluoroheptanoic acid (PFHpA), perfluorononanoic acid (PFNA) that have been validated by the laboratory. These other PFCs may have been detected at very low concentrations-EPA has not established health advisories for these chemicals. All six PFCs are effectively removed from drinking water by granular activated carbon filtration systems.

NYSELAP: Accredited by the New York State Environmental Laboratory Approval Program

END OF REPORT

The Laboratory Director authorizes the release of this report. The results in this report relate only to the sample submitted to the laboratory.

New York State Department of Health Wadsworth Center

Biggs Laboratory
PO Box 509
Albany, NY 12201
CLIA# 33D0654341

David Axelrod Institute
120 New Scotland Avenue
Albany, NY 12208
CLIA# 33D2005937

Griffin Laboratory
5668 State Farm Road
Slingerlands, NY 12159
CLIA# 33D2005935

Report No: **EHS1600058656-SR-1**

Page 1 of 1

Report Date: **01/06/2017**

Report retrieved via NYSDOH Health Commerce System by Irw03 on 03/09/2017

REQUESTED BY: DIRECTOR-WCENVIRO

DIRECTOR'S OFFICE
DIVISION OF ENVIRONMENTAL HEALTH SCIENCES
WADSWORTH CENTER
PO BOX 509
EMPIRE STATE PLAZA
ALBANY NY 12201-0509

Wadsworth Center - Environmental Labs

County: RENSSELAER
City (or) Town: HOOSICK FALLS
Submitted by: T. VICKERSON
Collected by: T. VICKERSON

Submitter's Reference Number: HF3

Grab/Collection Date: 12/29/2016 09:06

Date received: 12/29/2016 14:00

OUTBREAK #: HFPFOA

Location/Project/Facility Name: NY4100041, HOOSICK FALLS (V) PWS - HOOSICK FALLS
Sampling Location Details: TEMPORARY GAC MIDWAY DUPLICATE
HOOSICK FALLS NY
Chlorinated: No

FINAL LABORATORY REPORT

Biggs Laboratory
NYS ELAP ID: 10763

Laboratory of Organic Analytical Chemistry
Lab Director: Dr. K. Kannan
Contact: Dr. David Spink 518-486-2530

Sample Id: EHS1600058656-01

Sample Type: Finished Water

Received Temperature (°C): **10.5**

Received State: **Cooling**

Lab Tracking Id: HF3

Perfluoroalkyl Substances (PFASs) in Drinking Water by Ultra Performance Liquid Chromatography (UPLC) Tandem Mass Spectrometry (MS/MS): ISO 25101

Start Date: 12/30/2016 Analysis Date: 12/30/2016

Perfluorobutanesulfonic acid (PFBS): **<1.77 ng/L**

Perfluorohexanesulfonic acid (PFHxS): **<1.89 ng/L**

Perfluoroheptanoic acid (PFHpA): **<2.00 ng/L**

Perfluorooctanoic acid (PFOA): **9.24 ng/L**

NYSELAP

Perfluorooctanesulfonic acid (PFOS): **<1.91 ng/L**

NYSELAP

Perfluorononanoic acid (PFNA): **<2.00 ng/L**

The purpose of our sampling is to analyze for PFOA and/or PFOS, as per ISO 25101:2009 (E) method. This test includes four additional Perfluorinated Chemicals (PFCs): perfluorobutanesulfonic acid (PFBS), perfluorohexanesulfonic acid (PFHxS), perfluoroheptanoic acid (PFHpA), perfluorononanoic acid (PFNA) that have been validated by the laboratory. These other PFCs may have been detected at very low concentrations-EPA has not established health advisories for these chemicals. All six PFCs are effectively removed from drinking water by granular activated carbon filtration systems.

NYSELAP: Accredited by the New York State Environmental Laboratory Approval Program

END OF REPORT

The Laboratory Director authorizes the release of this report. The results in this report relate only to the sample submitted to the laboratory.

New York State Department of Health Wadsworth Center

Biggs Laboratory
PO Box 509
Albany, NY 12201
CLIA# 33D0654341

David Axelrod Institute
120 New Scotland Avenue
Albany, NY 12208
CLIA# 33D2005937

Griffin Laboratory
5668 State Farm Road
Slingerlands, NY 12159
CLIA# 33D2005935

Report No: **EHS1600058657-SR-1**

Page 1 of 1

Report Date: **01/06/2017**

Report retrieved via NYSDOH Health Commerce System by Irw03 on 03/09/2017

REQUESTED BY: DIRECTOR-WCENVIRO

DIRECTOR'S OFFICE
DIVISION OF ENVIRONMENTAL HEALTH SCIENCES
WADSWORTH CENTER
PO BOX 509
EMPIRE STATE PLAZA
ALBANY NY 12201-0509

Wadsworth Center - Environmental Labs

County: RENSSELAER
City (or) Town: HOOSICK FALLS
Submitted by: T. VICKERSON
Collected by:

Submitter's Reference Number: HF4

Grab/Collection Date: 12/29/2016 09:08
Date received: 12/29/2016 14:00

OUTBREAK #: HFPFOA

Location/Project/Facility Name: NY4100041, HOOSICK FALLS (V) PWS - HOOSICK FALLS
Sampling Location Details: TEMPORARY GAC INFLUENT
HOOSICK FALLS NY
Chlorinated: Yes

FINAL LABORATORY REPORT

Biggs Laboratory
NYS ELAP ID: 10763

Laboratory of Organic Analytical Chemistry
Lab Director: Dr. K. Kannan
Contact: Dr. David Spink 518-486-2530

Sample Id: EHS1600058657-01

Sample Type: Finished Water

Received Temperature (°C): **9.4**

Lab Tracking Id: HF4

Perfluoroalkyl Substances (PFASs) in Drinking Water by Ultra Performance Liquid Chromatography (UPLC) Tandem Mass Spectrometry (MS/MS): ISO 25101

Start Date: 12/30/2016 Analysis Date: 12/30/2016

Perfluorobutanesulfonic acid (PFBS):	<1.77 ng/L	
Perfluorohexanesulfonic acid (PFHxS):	<1.89 ng/L	
Perfluoroheptanoic acid (PFHpA):	14.0 ng/L	
Perfluorooctanoic acid (PFOA):	467 ng/L	NYSELAP
Perfluorooctanesulfonic acid (PFOS):	4.65 ng/L	NYSELAP
Perfluorononanoic acid (PFNA):	3.20 ng/L	

The purpose of our sampling is to analyze for PFOA and/or PFOS, as per ISO 25101:2009 (E) method. This test includes four additional Perfluorinated Chemicals (PFCs): perfluorobutanesulfonic acid (PFBS), perfluorohexanesulfonic acid (PFHxS), perfluoroheptanoic acid (PFHpA), perfluorononanoic acid (PFNA) that have been validated by the laboratory. These other PFCs may have been detected at very low concentrations-EPA has not established health advisories for these chemicals. All six PFCs are effectively removed from drinking water by granular activated carbon filtration systems.

NYSELAP: Accredited by the New York State Environmental Laboratory Approval Program

END OF REPORT

The Laboratory Director authorizes the release of this report. The results in this report relate only to the sample submitted to the laboratory.

New York State Department of Health Wadsworth Center

Biggs Laboratory
PO Box 509
Albany, NY 12201
CLIA# 33D0654341

David Axelrod Institute
120 New Scotland Avenue
Albany, NY 12208
CLIA# 33D2005937

Griffin Laboratory
5668 State Farm Road
Slingerlands, NY 12159
CLIA# 33D2005935

Report No: **EHS1600058658-SR-1**

Page 1 of 1

Report Date: **01/06/2017**

Report retrieved via NYSDOH Health Commerce System by Irw03 on 03/09/2017

REQUESTED BY: DIRECTOR-WCENVIRO

DIRECTOR'S OFFICE
DIVISION OF ENVIRONMENTAL HEALTH SCIENCES
WADSWORTH CENTER
PO BOX 509
EMPIRE STATE PLAZA
ALBANY NY 12201-0509

Wadsworth Center - Environmental Labs

County: RENSSELAER
City (or) Town: HOOSICK FALLS
Submitted by: T. VICKERSON
Collected by:

Submitter's Reference Number: HF5

Grab/Collection Date: 12/29/2016 09:20
Date received: 12/29/2016 14:00

OUTBREAK #: HFPFOA

Location/Project/Facility Name: NY4100041, HOOSICK FALLS (V) PWS - HOOSICK FALLS
Sampling Location Details: DPW GARAGE RESTROOM CWT
HOOSICK FALLS NY
Chlorinated: Yes

FINAL LABORATORY REPORT

Biggs Laboratory
NYS ELAP ID: 10763

Laboratory of Organic Analytical Chemistry
Lab Director: Dr. K. Kannan
Contact: Dr. David Spink 518-486-2530

Sample Id: EHS1600058658-01

Sample Type: Finished Water

Received Temperature (°C): **10.9**

Received State: **Cooling**

Lab Tracking Id: HF5

Perfluoroalkyl Substances (PFASs) in Drinking Water by Ultra Performance Liquid Chromatography (UPLC) Tandem Mass Spectrometry (MS/MS): ISO 25101

Start Date: 12/30/2016 Analysis Date: 12/30/2016

Perfluorobutanesulfonic acid (PFBS): **<1.77 ng/L**

Perfluorohexanesulfonic acid (PFHxS): **<1.89 ng/L**

Perfluoroheptanoic acid (PFHpA): **<2.00 ng/L**

Perfluorooctanoic acid (PFOA): **<2.00 ng/L**

NYSELAP

Perfluorooctanesulfonic acid (PFOS): **<1.91 ng/L**

NYSELAP

Perfluorononanoic acid (PFNA): **<2.00 ng/L**

The purpose of our sampling is to analyze for PFOA and/or PFOS, as per ISO 25101:2009 (E) method. This test includes four additional Perfluorinated Chemicals (PFCs): perfluorobutanesulfonic acid (PFBS), perfluorohexanesulfonic acid (PFHxS), perfluoroheptanoic acid (PFHpA), perfluorononanoic acid (PFNA) that have been validated by the laboratory. These other PFCs may have been detected at very low concentrations-EPA has not established health advisories for these chemicals. All six PFCs are effectively removed from drinking water by granular activated carbon filtration systems.

NYSELAP: Accredited by the New York State Environmental Laboratory Approval Program

END OF REPORT

The Laboratory Director authorizes the release of this report. The results in this report relate only to the sample submitted to the laboratory.

New York State Department of Health Wadsworth Center

Biggs Laboratory
PO Box 509
Albany, NY 12201
CLIA# 33D0654341

David Axelrod Institute
120 New Scotland Avenue
Albany, NY 12208
CLIA# 33D2005937

Griffin Laboratory
5668 State Farm Road
Slingerlands, NY 12159
CLIA# 33D2005935

Report No: **EHS1600058659-SR-1**

Page 1 of 1

Report Date: **01/06/2017**

Report retrieved via NYSDOH Health Commerce System by Irw03 on 03/09/2017

REQUESTED BY: DIRECTOR-WCENVIRO

DIRECTOR'S OFFICE
DIVISION OF ENVIRONMENTAL HEALTH SCIENCES
WADSWORTH CENTER
PO BOX 509
EMPIRE STATE PLAZA
ALBANY NY 12201-0509

Wadsworth Center - Environmental Labs

County: RENSSELAER
City (or) Town: HOOSICK FALLS
Submitted by: T. VICKERSON
Collected by:

Submitter's Reference Number: HF6

Grab/Collection Date: 12/29/2016 09:35

Date received: 12/29/2016 14:00

OUTBREAK #: HFPFOA

Location/Project/Facility Name: NY4100041, HOOSICK FALLS (V) PWS - HOOSICK FALLS
Sampling Location Details: VILLAGE HALL MEN'S CWT
HOOSICK FALLS NY
Chlorinated: Yes

FINAL LABORATORY REPORT

Biggs Laboratory
NYS ELAP ID: 10763

Laboratory of Organic Analytical Chemistry
Lab Director: Dr. K. Kannan
Contact: Dr. David Spink 518-486-2530

Sample Id: EHS1600058659-01

Sample Type: Finished Water

Received Temperature (°C): **9.8**

Lab Tracking Id: HF6

Perfluoroalkyl Substances (PFASs) in Drinking Water by Ultra Performance Liquid Chromatography (UPLC) Tandem Mass Spectrometry (MS/MS): ISO 25101

Start Date: 12/30/2016 Analysis Date: 12/30/2016

Perfluorobutanesulfonic acid (PFBS): **<1.77 ng/L**
Perfluorohexanesulfonic acid (PFHxS): **<1.89 ng/L**
Perfluoroheptanoic acid (PFHpA): **<2.00 ng/L**
Perfluorooctanoic acid (PFOA): **<2.00 ng/L**
Perfluorooctanesulfonic acid (PFOS): **<1.91 ng/L**
Perfluorononanoic acid (PFNA): **<2.00 ng/L**

NYSELAP
NYSELAP

The purpose of our sampling is to analyze for PFOA and/or PFOS, as per ISO 25101:2009 (E) method. This test includes four additional Perfluorinated Chemicals (PFCs): perfluorobutanesulfonic acid (PFBS), perfluorohexanesulfonic acid (PFHxS), perfluoroheptanoic acid (PFHpA), perfluorononanoic acid (PFNA) that have been validated by the laboratory. These other PFCs may have been detected at very low concentrations-EPA has not established health advisories for these chemicals. All six PFCs are effectively removed from drinking water by granular activated carbon filtration systems.

NYSELAP: Accredited by the New York State Environmental Laboratory Approval Program

END OF REPORT

The Laboratory Director authorizes the release of this report. The results in this report relate only to the sample submitted to the laboratory.

New York State Department of Health Wadsworth Center

Biggs Laboratory
PO Box 509
Albany, NY 12201
CLIA# 33D0654341

David Axelrod Institute
120 New Scotland Avenue
Albany, NY 12208
CLIA# 33D2005937

Griffin Laboratory
5668 State Farm Road
Slingerlands, NY 12159
CLIA# 33D2005935

Report No: **EHS1600058660-SR-1**

Page 1 of 1

Report Date: **01/06/2017**

Report retrieved via NYSDOH Health Commerce System by Irw03 on 03/09/2017

REQUESTED BY: DIRECTOR-WCENVIRO

DIRECTOR'S OFFICE
DIVISION OF ENVIRONMENTAL HEALTH SCIENCES
WADSWORTH CENTER
PO BOX 509
EMPIRE STATE PLAZA
ALBANY NY 12201-0509

Wadsworth Center - Environmental Labs

County: RENSSELAER
City (or) Town: HOOSICK FALLS
Submitted by: TIM VICKERSON
Collected by:

Submitter's Reference Number: FRB

Grab/Collection Date: 12/29/2016
Date received: 12/29/2016 14:00

Location/Project/Facility Name: FIELD BLANK REAGENT BLANK
Sampling Location Details: PREPARED ON: 12/27/16 - WITH SAMPLE(S): EHS1600058654 - 58659

FINAL LABORATORY REPORT

Biggs Laboratory
NYS ELAP ID: 10763

Laboratory of Organic Analytical Chemistry
Lab Director: Dr. K. Kannan
Contact: Dr. David Spink 518-486-2530

Sample Id: EHS1600058660-01

Sample Type: Field Blank

Received Temperature (°C): **9.3**

Lab Tracking Id: FRB

Perfluoroalkyl Substances (PFASs) in Drinking Water by Ultra Performance Liquid Chromatography (UPLC) Tandem Mass Spectrometry (MS/MS): ISO 25101

Start Date: 12/30/2016 Analysis Date: 12/30/2016

Perfluorobutanesulfonic acid (PFBS):	<1.77 ng/L
Perfluorohexanesulfonic acid (PFHxS):	<1.89 ng/L
Perfluoroheptanoic acid (PFHpA):	<2.00 ng/L
Perfluorooctanoic acid (PFOA):	<2.00 ng/L
Perfluorooctanesulfonic acid (PFOS):	<1.91 ng/L
Perfluorononanoic acid (PFNA):	<2.00 ng/L

NYSELAP

NYSELAP

The purpose of our sampling is to analyze for PFOA and/or PFOS, as per ISO 25101:2009 (E) method. This test includes four additional Perfluorinated Chemicals (PFCs): perfluorobutanesulfonic acid (PFBS), perfluorohexanesulfonic acid (PFHxS), perfluoroheptanoic acid (PFHpA), perfluorononanoic acid (PFNA) that have been validated by the laboratory. These other PFCs may have been detected at very low concentrations-EPA has not established health advisories for these chemicals. All six PFCs are effectively removed from drinking water by granular activated carbon filtration systems.

NYSELAP: Accredited by the New York State Environmental Laboratory Approval Program

END OF REPORT

The Laboratory Director authorizes the release of this report. The results in this report relate only to the sample submitted to the laboratory.

New York State Department of Health Wadsworth Center

Biggs Laboratory
PO Box 509
Albany, NY 12201
CLIA# 33D0654341

David Axelrod Institute
120 New Scotland Avenue
Albany, NY 12208
CLIA# 33D2005937

Griffin Laboratory
5668 State Farm Road
Slingerlands, NY 12159
CLIA# 33D2005935

Report No: **EHS1600058661-SR-1**

Page 1 of 1

Report Date: **01/06/2017**

Report retrieved via NYSDOH Health Commerce System by Irw03 on 03/09/2017

REQUESTED BY: DIRECTOR-WCENVIRO

DIRECTOR'S OFFICE
DIVISION OF ENVIRONMENTAL HEALTH SCIENCES
WADSWORTH CENTER
PO BOX 509
EMPIRE STATE PLAZA
ALBANY NY 12201-0509

Wadsworth Center - Environmental Labs

County: RENSSELAER
Submitted by: JEFF WINERITER
Collected by: JEFF WINERITER

Submitter's Reference Number: LRB

Grab/Collection Date: 12/29/2016
Date received: 12/29/2016 14:00

Location/Project/Facility Name: LABORATORY REAGENT BLANK
Sampling Location Details: PREPARED ON: 12/29/16 - EXTRACTED WITH: EHS1600058654 - 58660

FINAL LABORATORY REPORT

Biggs Laboratory
NYS ELAP ID: 10763

Laboratory of Organic Analytical Chemistry
Lab Director: Dr. K. Kannan
Contact: Dr. David Spink 518-486-2530

Sample Id: EHS1600058661-01

Sample Type: Method Blank

Lab Tracking Id: LRB

Perfluoroalkyl Substances (PFASs) in Drinking Water by Ultra Performance Liquid Chromatography (UPLC) Tandem Mass Spectrometry (MS/MS): ISO 25101

Start Date: 12/30/2016 Analysis Date: 12/30/2016

Perfluorobutanesulfonic acid (PFBS):	<1.77 ng/L	
Perfluorohexanesulfonic acid (PFHxS):	<1.89 ng/L	
Perfluoroheptanoic acid (PFHpA):	<2.00 ng/L	
Perfluorooctanoic acid (PFOA):	2.04 ng/L; B - Analyte found in an associated method blank; result in doubt	NYSELAP
Perfluorooctanesulfonic acid (PFOS):	<1.91 ng/L	NYSELAP
Perfluorononanoic acid (PFNA):	<2.00 ng/L	

The purpose of our sampling is to analyze for PFOA and/or PFOS, as per ISO 25101:2009 (E) method. This test includes four additional Perfluorinated Chemicals (PFCs): perfluorobutanesulfonic acid (PFBS), perfluorohexanesulfonic acid (PFHxS), perfluoroheptanoic acid (PFHpA), perfluorononanoic acid (PFNA) that have been validated by the laboratory. These other PFCs may have been detected at very low concentrations-EPA has not established health advisories for these chemicals. All six PFCs are effectively removed from drinking water by granular activated carbon filtration systems.

NYSELAP: Accredited by the New York State Environmental Laboratory Approval Program

END OF REPORT

The Laboratory Director authorizes the release of this report. The results in this report relate only to the sample submitted to the laboratory.