

To: David Borge, Mayor

From: Dave Lukas, MRB

Date: 3/17/15

Subj: PAC Sample Results

Results from PAC testing for PFOA removal

Test Compounds	ppt of PFOA
1.PCH	530
2.PC610	550
3.PC605	540
4.ACH	530
RAW WATER WELL #7	580

Eurofins called with the results from the run of various PAC compounds for PFOA removal from Friday February 27<sup>th</sup>. They had "internal problems" and never knew it was a 5 day verbal rush even though it was written on the chain of custody sheet as well as a separate sheet attached to the samples. There will not be any surcharge for the rush sampling because they did not perform it.

Results : None of the compounds tested showed any significant decrease in PFOA levels. This does not mean that PAC is not needed. If the next step is GAC then PFOA will be needed to replace Hypo and Potassium Permanganate as hypo would pass through the PALL filters and blind the GAC quickly – shortening its life span significantly.