

NYSDOH Sampling January 18, 2018.

	Sample Location	PFBA	PFPeA	PFHxA	PFHpA	PFOA	PFNA	PFDA	PFUnA	PFDoA	PFPrS	PFBS
Hoosick Falls Public Water Supply	GAC UNIT INFLUENT	ND*	2.93	11	9.64	384	ND	ND	ND	ND	ND	ND
	GAC UNIT MIDPOINT	5.53	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	GAC UNIT MIDPOINT DUPLICATE	6.01	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	GAC UNIT EFFLUENT (Finished Water)	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Saint-Gobain Monitoring Wells	MONITORING WELL 3	20	32.4	90.8	106	5350	8.75	3.94	ND	ND	ND	1.78
	MONITORING WELL 10	22.6	33.9	88.1	111	7790	7.11	ND	ND	ND	ND	1.94
	MONITORING WELL 15	25.3	35.5	111	137	5960	4.1	ND	ND	ND	ND	ND
	MONITORING WELL 29	7.61	8.59	29.6	24.6	1120	ND	ND	ND	ND	ND	2.4
	MONITORING WELL 29 DUPLICATE	7.47	8.71	30.4	25	1010	ND	ND	ND	ND	ND	2.43
	FIELD REAGENT BLANK	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	LABORATORY REAGENT BLANK	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

	Sample Location	PFPeS	PFHxS	PFHpS	PFOS	PFOSA	GenX	DONA	PFECA A	PFECA F	PFECA G
Hoosick Falls Public Water Supply	GAC UNIT INFLUENT	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	GAC UNIT MIDPOINT	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	GAC UNIT MIDPOINT DUPLICATE	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	GAC UNIT EFFLUENT (Finished Water)	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Saint-Gobain Monitoring Wells	MONITORING WELL 3	ND	ND	ND	3.63	ND	ND	ND	ND	ND	ND
	MONITORING WELL 10	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	MONITORING WELL 15	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	MONITORING WELL 29	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	MONITORING WELL 29 DUPLICATE	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	FIELD REAGENT BLANK	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	LABORATORY REAGENT BLANK	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

*ND means that the result was below the reporting limit provided in the laboratory analysis. For specific reporting limits see the corresponding laboratory report.