

**NYSDOH Sampling February 9, 2018 (all results in parts per trillion) .**

	<b>Sample Location</b>	<b>PFBA</b>	<b>PFPeA</b>	<b>PFHxA</b>	<b>PFHpA</b>	<b>PFOA</b>	<b>PFNA</b>	<b>PFDA</b>	<b>PFUnA</b>	<b>PFDoA</b>	<b>PFPrS</b>	<b>PFBS</b>
<b>Hoosick Falls Public Water Supply</b>	GAC UNIT INFLUENT Raw 1	5.46	3.86	12.8	12.6	483	*ND	ND	ND	ND	ND	ND
	GAC Unit Influent	ND	3.04	12.07	11.8	496	ND	ND	ND	ND	ND	ND
	GAC UNIT MIDPOINT Middle 1	6.76	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	GAC UNIT MIDPOINT DUPLICATE Middle 2	6.64	2.06	ND	ND	ND	ND	ND	ND	ND	ND	ND
	GAC UNIT EFFLUENT Finished 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	GAC Unit Effluent Duplicate Finished 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

	<b>Sample Location</b>	<b>PFPeS</b>	<b>PFHxS</b>	<b>PFHpS</b>	<b>PFOS</b>	<b>PFOSA</b>	<b>GenX</b>	<b>DONA</b>	<b>PFECA A</b>	<b>PFECA F</b>	<b>PFECA G</b>
<b>Hoosick Falls Public Water Supply</b>	GAC UNIT INFLUENT Raw 1	ND	ND	ND	ND	ND	NA**	NA	NA	NA	NA
	GAC Unit Influent	ND	ND	ND	1.99	ND	NA	NA	NA	NA	NA
	GAC UNIT MIDPOINT Middle 1	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA
	GAC UNIT MIDPOINT DUPLICATE Middle 2	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA
	GAC UNIT EFFLUENT Finished 1	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA
	GAC Unit Effluent Duplicate Finished 2	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA

\*ND means that the result was below the reporting limit provided in the laboratory analysis. For specific reporting limits see the corresponding laboratory report

\*\*NA means not analyzed