



## ANALYSIS REPORT

Prepared by:

Eurofins Lancaster Laboratories Environmental  
2425 New Holland Pike  
Lancaster, PA 17601

Prepared for:

C. T. Male Associates  
50 Century Hill Drive  
Latham NY 12110

Report Date: December 06, 2018 16:11

### Project: Hoosick Falls WTP

Account #: 37191  
Group Number: 2012449  
SDG: HOO17  
PO Number: 14.4756  
State of Sample Origin: NY

Electronic Copy To	C. T. Male Associates	Attn: Kirk Moline
Electronic Copy To	C. T. Male Associates	Attn: Dan Reilly
Electronic Copy To	C. T. Male Associates	Attn: Jeff Marx
Electronic Copy To	Barr Engineering Company	Attn: Lauren Brady
Electronic Copy To	Environmental Standards	Attn: St. Gobain
Electronic Copy To	Barr Engineering Company	Attn: Data Mgt

Respectfully Submitted,



Nancy Jean Bornholm  
Principal Specialist

(717) 556-7250

To view our laboratory's current scopes of accreditation please go to <http://www.eurofinsus.com/environment-testing/laboratories/eurofins-lancaster-laboratories-environmental/resources/certifications/>. Historical copies may be requested through your project manager.



### SAMPLE INFORMATION

<u>Client Sample Description</u>	<u>Sample Collection Date/Time</u>	<u>ELLE#</u>
GAC Influent Grab Drinking Water	11/26/2018 10:46	9913172
GAC Midfluent Grab Drinking Water	11/26/2018 10:48	9913173
GAC Effluent Grab Drinking Water	11/26/2018 10:50	9913174
FTB01-181126 Grab Blank Water	11/26/2018 10:43	9913175
LTB01-181126 Blank Water	11/26/2018	9913176

The specific methodologies used in obtaining the enclosed analytical results are indicated on the Laboratory Sample Analysis Record.

Project Name: Hoosick Falls WTP  
ELLE Group #: 2012449

**General Comments:**

See the Laboratory Sample Analysis Record section of the Analysis Report for the method references.

All QC met criteria unless otherwise noted in an Analysis Specific Comment below.

Refer to the QC Summary for specific values and acceptance criteria.

Project specific QC samples are not included in this data set.

Matrix QC may not be reported if site-specific QC samples were not submitted. In these situations, to demonstrate precision and accuracy at a batch level, a LCS/LCSD was performed, unless otherwise specified in the method.

Surrogate recoveries (if applicable) which are outside of the QC window are confirmed unless attributed to a dilution or otherwise noted in an Analysis Specific Comment below.

The samples were received at the appropriate temperature and in accordance with the chain of custody unless otherwise noted.

**Analysis Specific Comments:**

No additional comments are necessary.

**Sample Description:** GAC Influent Grab Drinking Water  
Hoosick Falls Water Treatment Plant

**C. T. Male Associates**  
**ELLE Sample #:** PW 9913172  
**ELLE Group #:** 2012449  
**Matrix:** Drinking Water

**Project Name:** Hoosick Falls WTP

**Submission Date/Time:** 11/27/2018 11:15  
**Collection Date/Time:** 11/26/2018 10:46  
**SDG#:** HOO17-01

CAT No.	Analysis Name	CAS Number	Result	Limit of Quantitation	Dilution Factor
<b>LC/MS/MS Miscellaneous EPA 537 Version 1.1</b>			<b>ng/l</b>	<b>ng/l</b>	
14070	NEtFOSAA NEtFOSAA is the acronym for N-ethyl perfluorooctanesulfonamidoacetic Acid.	2991-50-6	1.9 U	1.9	1
14070	NMeFOSAA NMeFOSAA is the acronym for N-methyl perfluorooctanesulfonamidoacetic Acid.	2355-31-9	1.9 U	1.9	1
14070	Perfluorobutanesulfonate	375-73-5	1.9 U	1.9	1
14070	Perfluorodecanoic acid	335-76-2	1.9 U	1.9	1
14070	Perfluorododecanoic acid	307-55-1	1.9 U	1.9	1
14070	<b>Perfluoroheptanoic acid</b>	375-85-9	<b>14</b>	1.9	1
14070	Perfluorohexanesulfonate	355-46-4	1.9 U	1.9	1
14070	<b>Perfluorohexanoic acid</b>	307-24-4	<b>16</b>	1.9	1
14070	Perfluorononanoic acid	375-95-1	1.9 U	1.9	1
14070	<b>Perfluoro-octanesulfonate</b>	1763-23-1	<b>3.3</b>	1.9	1
14070	<b>Perfluorooctanoic acid</b>	335-67-1	<b>460</b>	19	10
14070	Perfluorotetradecanoic acid	376-06-7	1.9 U	1.9	1
14070	Perfluorotridecanoic acid	72629-94-8	1.9 U	1.9	1
14070	Perfluoroundecanoic acid	2058-94-8	1.9 U	1.9	1

CAT No.	Analysis Name	Method	Trial#	Batch#	Analysis Date and Time	Analyst	Dilution Factor
<b>LC/MS/MS Miscellaneous EPA 537 Version 1.1 Modified</b>					<b>ng/l</b>	<b>ng/l</b>	
14473	6:2 fluorotelomersulfonate	27619-97-2	1.8 U	1.8	1		
14473	8:2 fluorotelomersulfonate	39108-34-4	5.3 U	5.3	1		
14473	Perfluorobutanoic acid	375-22-4	5.3 U	5.3	1		
14473	Perfluorodecanesulfonate	335-77-3	1.8 U	1.8	1		
14473	Perfluoroheptanesulfonate	375-92-8	1.8 U	1.8	1		
14473	Perfluorooctanesulfonamide	754-91-6	2.7 U	2.7	1		
14473	Perfluoropentanoic acid	2706-90-3	5.3 U	5.3	1		

### Laboratory Sample Analysis Record

CAT No.	Analysis Name	Method	Trial#	Batch#	Analysis Date and Time	Analyst	Dilution Factor
14070	14 PFAS Drinking Water List	EPA 537 Version 1.1	1	18333012	11/30/2018 20:42	Joshua P Trost	1
14070	14 PFAS Drinking Water List	EPA 537 Version 1.1	1	18333012	12/03/2018 21:54	Joshua P Trost	10
14473	7 PFAS Compounds	EPA 537 Version 1.1 Modified	1	18331013	11/29/2018 02:43	Devon M Whooley	1
14381	DW PFAS Prep	EPA 537 Version 1.1	1	18333012	11/29/2018 16:00	Anthony C Polaski	1
14091	PFAS Water Prep	EPA 537 Version 1.1 Modified	1	18331013	11/27/2018 16:00	Anthony C Polaski	1

**Sample Description:** GAC Midfluent Grab Drinking Water  
Hoosick Falls Water Treatment Plant

**C. T. Male Associates**  
**ELLE Sample #:** PW 9913173  
**ELLE Group #:** 2012449  
**Matrix:** Drinking Water

**Project Name:** Hoosick Falls WTP

**Submission Date/Time:** 11/27/2018 11:15  
**Collection Date/Time:** 11/26/2018 10:48  
**SDG#:** HOO17-02

CAT No.	Analysis Name	CAS Number	Result	Limit of Quantitation	Dilution Factor
<b>LC/MS/MS Miscellaneous EPA 537 Version 1.1</b>			<b>ng/l</b>	<b>ng/l</b>	
14070	NEtFOSAA NEtFOSAA is the acronym for N-ethyl perfluorooctanesulfonamidoacetic Acid.	2991-50-6	1.8 U	1.8	1
14070	NMeFOSAA NMeFOSAA is the acronym for N-methyl perfluorooctanesulfonamidoacetic Acid.	2355-31-9	1.8 U	1.8	1
14070	Perfluorobutanesulfonate	375-73-5	1.8 U	1.8	1
14070	Perfluorodecanoic acid	335-76-2	1.8 U	1.8	1
14070	Perfluorododecanoic acid	307-55-1	1.8 U	1.8	1
14070	Perfluoroheptanoic acid	375-85-9	1.8 U	1.8	1
14070	Perfluorohexanesulfonate	355-46-4	1.8 U	1.8	1
14070	Perfluorohexanoic acid	307-24-4	1.8 U	1.8	1
14070	Perfluorononanoic acid	375-95-1	1.8 U	1.8	1
14070	Perfluoro-octanesulfonate	1763-23-1	1.8 U	1.8	1
14070	Perfluorooctanoic acid	335-67-1	1.8 U	1.8	1
14070	Perfluorotetradecanoic acid	376-06-7	1.8 U	1.8	1
14070	Perfluorotridecanoic acid	72629-94-8	1.8 U	1.8	1
14070	Perfluoroundecanoic acid	2058-94-8	1.8 U	1.8	1

CAT No.	Analysis Name	CAS Number	Result	Limit of Quantitation	Dilution Factor
<b>LC/MS/MS Miscellaneous EPA 537 Version 1.1 Modified</b>			<b>ng/l</b>	<b>ng/l</b>	
14473	6:2 fluorotelomersulfonate	27619-97-2	1.8 U	1.8	1
14473	8:2 fluorotelomersulfonate	39108-34-4	5.3 U	5.3	1
14473	<b>Perfluorobutanoic acid</b>	375-22-4	<b>7.3</b>	5.3	1
14473	Perfluorodecanesulfonate	335-77-3	1.8 U	1.8	1
14473	Perfluoroheptanesulfonate	375-92-8	1.8 U	1.8	1
14473	Perfluorooctanesulfonamide	754-91-6	2.6 U	2.6	1
14473	Perfluoropentanoic acid	2706-90-3	5.3 U	5.3	1

### Laboratory Sample Analysis Record

CAT No.	Analysis Name	Method	Trial#	Batch#	Analysis Date and Time	Analyst	Dilution Factor
14070	14 PFAS Drinking Water List	EPA 537 Version 1.1	1	18333012	11/30/2018 20:54	Joshua P Trost	1
14473	7 PFAS Compounds	EPA 537 Version 1.1 Modified	1	18331013	11/29/2018 02:52	Devon M Whooley	1
14381	DW PFAS Prep	EPA 537 Version 1.1	1	18333012	11/29/2018 16:00	Anthony C Polaski	1
14091	PFAS Water Prep	EPA 537 Version 1.1 Modified	1	18331013	11/27/2018 16:00	Anthony C Polaski	1

**Sample Description:** GAC Effluent Grab Drinking Water  
Hoosick Falls Water Treatment Plant

**C. T. Male Associates**  
**ELLE Sample #:** PW 9913174  
**ELLE Group #:** 2012449  
**Matrix:** Drinking Water

**Project Name:** Hoosick Falls WTP

**Submission Date/Time:** 11/27/2018 11:15  
**Collection Date/Time:** 11/26/2018 10:50  
**SDG#:** HOO17-03

CAT No.	Analysis Name	CAS Number	Result	Limit of Quantitation	Dilution Factor
<b>LC/MS/MS Miscellaneous EPA 537 Version 1.1</b>			<b>ng/l</b>	<b>ng/l</b>	
14070	NEtFOSAA NEtFOSAA is the acronym for N-ethyl perfluorooctanesulfonamidoacetic Acid.	2991-50-6	1.8 U	1.8	1
14070	NMeFOSAA NMeFOSAA is the acronym for N-methyl perfluorooctanesulfonamidoacetic Acid.	2355-31-9	1.8 U	1.8	1
14070	Perfluorobutanesulfonate	375-73-5	1.8 U	1.8	1
14070	Perfluorodecanoic acid	335-76-2	1.8 U	1.8	1
14070	Perfluorododecanoic acid	307-55-1	1.8 U	1.8	1
14070	Perfluoroheptanoic acid	375-85-9	1.8 U	1.8	1
14070	Perfluorohexanesulfonate	355-46-4	1.8 U	1.8	1
14070	Perfluorohexanoic acid	307-24-4	1.8 U	1.8	1
14070	Perfluorononanoic acid	375-95-1	1.8 U	1.8	1
14070	Perfluoro-octanesulfonate	1763-23-1	1.8 U	1.8	1
14070	Perfluorooctanoic acid	335-67-1	1.8 U	1.8	1
14070	Perfluorotetradecanoic acid	376-06-7	1.8 U	1.8	1
14070	Perfluorotridecanoic acid	72629-94-8	1.8 U	1.8	1
14070	Perfluoroundecanoic acid	2058-94-8	1.8 U	1.8	1

CAT No.	Analysis Name	CAS Number	Result	Limit of Quantitation	Dilution Factor
<b>LC/MS/MS Miscellaneous EPA 537 Version 1.1 Modified</b>			<b>ng/l</b>	<b>ng/l</b>	
14473	6:2 fluorotelomersulfonate	27619-97-2	1.8 U	1.8	1
14473	8:2 fluorotelomersulfonate	39108-34-4	5.3 U	5.3	1
14473	Perfluorobutanoic acid	375-22-4	5.3 U	5.3	1
14473	Perfluorodecanesulfonate	335-77-3	1.8 U	1.8	1
14473	Perfluoroheptanesulfonate	375-92-8	1.8 U	1.8	1
14473	Perfluorooctanesulfonamide	754-91-6	2.6 U	2.6	1
14473	Perfluoropentanoic acid	2706-90-3	5.3 U	5.3	1

### Laboratory Sample Analysis Record

CAT No.	Analysis Name	Method	Trial#	Batch#	Analysis Date and Time	Analyst	Dilution Factor
14070	14 PFAS Drinking Water List	EPA 537 Version 1.1	1	18333012	11/30/2018 21:05	Joshua P Trost	1
14473	7 PFAS Compounds	EPA 537 Version 1.1 Modified	1	18331013	11/29/2018 03:01	Devon M Whooley	1
14381	DW PFAS Prep	EPA 537 Version 1.1	1	18333012	11/29/2018 16:00	Anthony C Polaski	1
14091	PFAS Water Prep	EPA 537 Version 1.1 Modified	1	18331013	11/27/2018 16:00	Anthony C Polaski	1

**Sample Description:** FTB01-181126 Grab Blank Water  
Hoosick Falls Water Treatment Plant

**C. T. Male Associates**  
**ELLE Sample #:** PW 9913175  
**ELLE Group #:** 2012449  
**Matrix:** Blank Water

**Project Name:** Hoosick Falls WTP

**Submission Date/Time:** 11/27/2018 11:15  
**Collection Date/Time:** 11/26/2018 10:43  
**SDG#:** HOO17-04FB

CAT No.	Analysis Name	CAS Number	Result	Limit of Quantitation	Dilution Factor
<b>LC/MS/MS Miscellaneous EPA 537 Version 1.1</b>			<b>ng/l</b>	<b>ng/l</b>	
14070	NEtFOSAA NEtFOSAA is the acronym for N-ethyl perfluorooctanesulfonamidoacetic Acid.	2991-50-6	1.7 U	1.7	1
14070	NMeFOSAA NMeFOSAA is the acronym for N-methyl perfluorooctanesulfonamidoacetic Acid.	2355-31-9	1.7 U	1.7	1
14070	Perfluorobutanesulfonate	375-73-5	1.7 U	1.7	1
14070	Perfluorodecanoic acid	335-76-2	1.7 U	1.7	1
14070	Perfluorododecanoic acid	307-55-1	1.7 U	1.7	1
14070	Perfluoroheptanoic acid	375-85-9	1.7 U	1.7	1
14070	Perfluorohexanesulfonate	355-46-4	1.7 U	1.7	1
14070	Perfluorohexanoic acid	307-24-4	1.7 U	1.7	1
14070	Perfluorononanoic acid	375-95-1	1.7 U	1.7	1
14070	Perfluoro-octanesulfonate	1763-23-1	1.7 U	1.7	1
14070	Perfluorooctanoic acid	335-67-1	1.7 U	1.7	1
14070	Perfluorotetradecanoic acid	376-06-7	1.7 U	1.7	1
14070	Perfluorotridecanoic acid	72629-94-8	1.7 U	1.7	1
14070	Perfluoroundecanoic acid	2058-94-8	1.7 U	1.7	1

CAT No.	Analysis Name	CAS Number	Result	Limit of Quantitation	Dilution Factor
<b>LC/MS/MS Miscellaneous EPA 537 Version 1.1 Modified</b>			<b>ng/l</b>	<b>ng/l</b>	
14473	6:2 fluorotelomersulfonate	27619-97-2	1.8 U	1.8	1
14473	8:2 fluorotelomersulfonate	39108-34-4	5.3 U	5.3	1
14473	Perfluorobutanoic acid	375-22-4	5.3 U	5.3	1
14473	Perfluorodecanesulfonate	335-77-3	1.8 U	1.8	1
14473	Perfluoroheptanesulfonate	375-92-8	1.8 U	1.8	1
14473	Perfluorooctanesulfonamide	754-91-6	2.6 U	2.6	1
14473	Perfluoropentanoic acid	2706-90-3	5.3 U	5.3	1

### Laboratory Sample Analysis Record

CAT No.	Analysis Name	Method	Trial#	Batch#	Analysis Date and Time	Analyst	Dilution Factor
14070	14 PFAS Drinking Water List	EPA 537 Version 1.1	1	18333012	11/30/2018 21:17	Joshua P Trost	1
14473	7 PFAS Compounds	EPA 537 Version 1.1 Modified	1	18331013	11/29/2018 03:19	Devon M Whooley	1
14381	DW PFAS Prep	EPA 537 Version 1.1	1	18333012	11/29/2018 16:00	Anthony C Polaski	1
14091	PFAS Water Prep	EPA 537 Version 1.1 Modified	1	18331013	11/27/2018 16:00	Anthony C Polaski	1

**Sample Description:** LTB01-181126 Blank Water  
Hoosick Falls Water Treatment Plant

**C. T. Male Associates**  
**ELLE Sample #:** WW 9913176  
**ELLE Group #:** 2012449  
**Matrix:** Blank Water

**Project Name:** Hoosick Falls WTP

**Submittal Date/Time:** 11/27/2018 11:15  
**Collection Date/Time:** 11/26/2018  
**SDG#:** HOO17-05TB

CAT No.	Analysis Name	CAS Number	Result	Limit of Quantitation	Dilution Factor
<b>LC/MS/MS Miscellaneous EPA 537 Version 1.1</b>					
14070	NEtFOSAA NEtFOSAA is the acronym for N-ethyl perfluorooctanesulfonamidoacetic Acid.	2991-50-6	1.8 U	1.8	1
14070	NMeFOSAA NMeFOSAA is the acronym for N-methyl perfluorooctanesulfonamidoacetic Acid.	2355-31-9	1.8 U	1.8	1
14070	Perfluorobutanesulfonate	375-73-5	1.8 U	1.8	1
14070	Perfluorodecanoic acid	335-76-2	1.8 U	1.8	1
14070	Perfluorododecanoic acid	307-55-1	1.8 U	1.8	1
14070	Perfluoroheptanoic acid	375-85-9	1.8 U	1.8	1
14070	Perfluorohexanesulfonate	355-46-4	1.8 U	1.8	1
14070	Perfluorohexanoic acid	307-24-4	1.8 U	1.8	1
14070	Perfluorononanoic acid	375-95-1	1.8 U	1.8	1
14070	Perfluoro-octanesulfonate	1763-23-1	1.8 U	1.8	1
14070	Perfluorooctanoic acid	335-67-1	1.8 U	1.8	1
14070	Perfluorotetradecanoic acid	376-06-7	1.8 U	1.8	1
14070	Perfluorotridecanoic acid	72629-94-8	1.8 U	1.8	1
14070	Perfluoroundecanoic acid	2058-94-8	1.8 U	1.8	1

CAT No.	Analysis Name	CAS Number	Result	Limit of Quantitation	Dilution Factor
<b>LC/MS/MS Miscellaneous EPA 537 Version 1.1 Modified</b>					
14473	6:2 fluorotelomersulfonate	27619-97-2	1.8 U	1.8	1
14473	8:2 fluorotelomersulfonate	39108-34-4	5.5 U	5.5	1
14473	Perfluorobutanoic acid	375-22-4	5.5 U	5.5	1
14473	Perfluorodecanesulfonate	335-77-3	1.8 U	1.8	1
14473	Perfluoroheptanesulfonate	375-92-8	1.8 U	1.8	1
14473	Perfluorooctanesulfonamide	754-91-6	2.7 U	2.7	1
14473	Perfluoropentanoic acid	2706-90-3	5.5 U	5.5	1

### Laboratory Sample Analysis Record

CAT No.	Analysis Name	Method	Trial#	Batch#	Analysis Date and Time	Analyst	Dilution Factor
14070	14 PFAS Drinking Water List	EPA 537 Version 1.1	1	18333012	11/30/2018 21:28	Joshua P Trost	1
14473	7 PFAS Compounds	EPA 537 Version 1.1 Modified	1	18331013	11/29/2018 03:28	Devon M Whooley	1
14381	DW PFAS Prep	EPA 537 Version 1.1	1	18333012	11/29/2018 16:00	Anthony C Polaski	1
14091	PFAS Water Prep	EPA 537 Version 1.1 Modified	1	18331013	11/27/2018 16:00	Anthony C Polaski	1



## Quality Control Summary

Client Name: C. T. Male Associates  
Reported: 12/06/2018 16:11

Group Number: 2012449

Matrix QC may not be reported if insufficient sample or site-specific QC samples were not submitted. In these situations, to demonstrate precision and accuracy at a batch level, a LCS/LCSD was performed, unless otherwise specified in the method.

All Inorganic Initial Calibration and Continuing Calibration Blanks met acceptable method criteria unless otherwise noted on the Analysis Report.

### Method Blank

Analysis Name	Result	LOQ
	ng/l	ng/l
Batch number: 18331013	Sample number(s): 9913172-9913176	
6:2 fluorotelomersulfonate	2.0 U	2.0
8:2 fluorotelomersulfonate	6.0 U	6.0
Perfluorobutanoic acid	6.0 U	6.0
Perfluorodecanesulfonate	2.0 U	2.0
Perfluoroheptanesulfonate	2.0 U	2.0
Perfluorooctanesulfonamide	3.0 U	3.0
Perfluoropentanoic acid	6.0 U	6.0
Batch number: 18333012	Sample number(s): 9913172-9913176	
NETFOSAA	2.0 U	2.0
NMeFOSAA	2.0 U	2.0
Perfluorobutanesulfonate	2.0 U	2.0
Perfluorodecanoic acid	2.0 U	2.0
Perfluorododecanoic acid	2.0 U	2.0
Perfluoroheptanoic acid	2.0 U	2.0
Perfluorohexanesulfonate	2.0 U	2.0
Perfluorohexanoic acid	2.0 U	2.0
Perfluorononanoic acid	2.0 U	2.0
Perfluoro-octanesulfonate	2.0 U	2.0
Perfluorooctanoic acid	2.0 U	2.0
Perfluorotetradecanoic acid	2.0 U	2.0
Perfluorotridecanoic acid	2.0 U	2.0
Perfluoroundecanoic acid	2.0 U	2.0

### LCS/LCSD

Analysis Name	LCS Spike Added	LCS Conc	LCSD Spike Added	LCSD Conc	LCS %REC	LCSD %REC	LCS/LCSD Limits	RPD	RPD Max
	ng/l	ng/l	ng/l	ng/l					
Batch number: 18331013	Sample number(s): 9913172-9913176								
6:2 fluorotelomersulfonate	15.17	12.01	15.17	13.14	79	87	66-155	9	30
8:2 fluorotelomersulfonate	15.33	15.17	15.33	14.58	99	95	66-148	4	30
Perfluorobutanoic acid	5.44	5.03	5.44	5.03	92	93	74-142	0	30
Perfluorodecanesulfonate	5.24	4.28	5.24	4.36	82	83	60-135	2	30
Perfluoroheptanesulfonate	5.18	4.44	5.18	4.54	86	88	64-135	2	30
Perfluorooctanesulfonamide	5.44	4.66	5.44	4.77	86	88	65-164	2	30

\*- Outside of specification

- (1) The result for one or both determinations was less than five times the LOQ.
- (2) The unspiked result was more than four times the spike added.

P##### is indicative of a Background or Unspiked sample that is batch matrix QC and was not performed using a sample from this submission group.

## Quality Control Summary

Client Name: C. T. Male Associates  
Reported: 12/06/2018 16:11

Group Number: 2012449

### LCS/LCSD (continued)

Analysis Name	LCS Spike Added ng/l	LCS Conc ng/l	LCSD Spike Added ng/l	LCSD Conc ng/l	LCS %REC	LCSD %REC	LCS/LCSD Limits	RPD	RPD Max
Perfluoropentanoic acid	5.44	4.77	5.44	5.19	88	95	74-134	8	30
Batch number: 18333012	Sample number(s): 9913172-9913176								
NEtFOSAA	80	81.03	80	75.97	101	95	70-130	6	30
NMeFOSAA	80	80.49	80	82.91	101	104	70-130	3	30
Perfluorobutanesulfonate	70.76	63.66	70.76	65.01	90	92	70-130	2	30
Perfluorodecanoic acid	80	75.49	80	80.31	94	100	70-130	6	30
Perfluorododecanoic acid	80	66.47	80	71.62	83	90	70-130	7	30
Perfluoroheptanoic acid	80	76.4	80	85.74	96	107	70-130	12	30
Perfluorohexanesulfonate	75.64	69.96	75.64	71.96	92	95	70-130	3	30
Perfluorohexanoic acid	80	75.61	80	83.68	95	105	70-130	10	30
Perfluorononanoic acid	80	75.8	80	79.24	95	99	70-130	4	30
Perfluoro-octanesulfonate	76.48	63.39	76.48	63.3	83	83	70-130	0	30
Perfluorooctanoic acid	80	74.02	80	82.06	93	103	70-130	10	30
Perfluorotetradecanoic acid	80	61.36	80	66.48	77	83	70-130	8	30
Perfluorotridecanoic acid	80	70.49	80	74.53	88	93	70-130	6	30
Perfluoroundecanoic acid	80	64.14	80	69.06	80	86	70-130	7	30

### Labeled Isotope Quality Control

Labeled isotope recoveries which are outside of the QC window are confirmed unless otherwise noted on the analysis report.

Analysis Name: 7 PFAS Compounds  
Batch number: 18331013

	13C4-PFBA	13C5-PFPeA	13C3-PFHxS	13C2-6:2-FTS	13C8-PFOS	13C2-8:2-FTS
9913172	80	97	80	100	67	67
9913173	88	89	86	104	80	76
9913174	87	84	83	101	83	93
9913175	86	84	81	102	83	88
9913176	83	81	76	97	83	80
Blank	79	77	74	102	81	95
LCS	79	76	69	101	73	79
LCSD	85	85	75	99	71	84
Limits:	33-123	31-157	34-126	32-170	50-121	27-164

#### 13C8-PFOSA

9913172	42
9913173	78
9913174	80
9913175	79

\*- Outside of specification

- (1) The result for one or both determinations was less than five times the LOQ.
- (2) The unspiked result was more than four times the spike added.

P##### is indicative of a Background or Unspiked sample that is batch matrix QC and was not performed using a sample from this submission group.

## Quality Control Summary

Client Name: C. T. Male Associates  
Reported: 12/06/2018 16:11

Group Number: 2012449

### Labeled Isotope Quality Control (continued)

Labeled isotope recoveries which are outside of the QC window are confirmed unless otherwise noted on the analysis report.

Analysis Name: 7 PFAS Compounds

Batch number: 18331013

13C8-PFOSA

9913176	72
Blank	76
LCS	69
LCSD	67

Limits: 11-127

Analysis Name: 14 PFAS Drinking Water List

Batch number: 18333012

13C2-PFHxA

13C2-PFDA

D5-NetFOSAA

9913172	99	99	84
9913173	101	94	84
9913174	96	91	89
9913175	98	91	86
9913176	100	93	89
Blank	85	79	75
LCS	94	90	83
LCSD	106	98	89

Limits: 70-130      70-130      70-130


\*- Outside of specification

(1) The result for one or both determinations was less than five times the LOQ.

(2) The unspiked result was more than four times the spike added.

P##### is indicative of a Background or Unspiked sample that is batch matrix QC and was not performed using a sample from this submission group.

# Environmental Analysis Request/Chain of Custody



Lancaster Laboratories Environmental

For Eurofins Lancaster Laboratories Environmental use only

Acct. # 37191 Group # 2012449 Sample # 9913172-76

COC # 569722

Client Information				Matrix			Analysis Requested										For Lab Use Only																																					
Client: <u>C.T. Male Associates</u>		Acct. #:		<input type="checkbox"/> Soil <input type="checkbox"/> Sediment <input type="checkbox"/> Tissue <input checked="" type="checkbox"/> Potable <input checked="" type="checkbox"/> Ground <input type="checkbox"/> Surface <input type="checkbox"/> Water Drinking Water <input type="checkbox"/> NPDES Other: <u>Raise Water</u>			Preservation and Filtration Codes										FSC: _____	SCR#: _____																																				
Project Name/#: <u>Hoosick Falls WTP</u>		PWSID #:					<table border="1"> <tr><td>Z</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> </table>										Z																																				<b>Preservation Codes</b> H=HCl T=Thiosulfate N=HNO <sub>3</sub> B=NaOH S=H <sub>2</sub> SO <sub>4</sub> P=H <sub>3</sub> PO <sub>4</sub> F=Field Filtered O=Other	
Z																																																						
Project Manager: <u>Kick Meine</u>		P.O. #: <u>14.4756</u>		Total # of Containers <u>7 PFCs (EPA 537 ml)</u> <u>14 (PFCs) (EPA 537 Ver. 1.0)</u>		Remarks																																																
Sampler: <u>CB</u>		Quote #:		State where samples were collected: <u>NY</u>		For Compliance: Yes <input type="checkbox"/> No <input type="checkbox"/>		Z = Triang																																														
Sample Identification		Collected				Grab	Composite			Remarks																																												
Date	Time																																																					
<u>GAC Influent</u>	<u>11/26/18</u>	<u>1046</u>	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>	<u>4</u>	<u>X</u>	<u>X</u>																																														
<u>GAC Midfluent</u>		<u>1048</u>	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>	<u>4</u>	<u>X</u>	<u>X</u>																																														
<u>GAC Effluent</u>		<u>1050</u>	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>	<u>4</u>	<u>X</u>	<u>X</u>																																														
<u>FTB01-181126</u>		<u>1043</u>	<input checked="" type="checkbox"/>			<u>4</u>	<u>X</u>	<u>X</u>																																														
<u>LTB01-181126</u>			<input checked="" type="checkbox"/>			<u>4</u>	<u>X</u>	<u>X</u>																																														
<u>FTB02-181126</u> <u>(CB)</u>						<u>4</u>	<u>X</u>	<u>X</u>																																														
<u>LTB02-181126</u>																																																						

Turnaround Time (TAT) Requested (please circle)

Standard Rush

(Rush TAT is subject to laboratory approval and surcharge.)

Requested TAT in business days: \_\_\_\_\_

E-mail address: K.meine@ctmale.com

Data Package Options (circle if required)

- Type I (EPA Level 3 Equivalent/non-CLP)      Type VI (Raw Data Only)
- Type III (Reduced non-CLP)      NJ DKQP      TX TRRP-13
- NYSDEC Category A or B      MA MCP      CT RCP

Relinquished by <u>Chris Bull</u>	Date <u>11/26/18</u>	Time <u>1215</u>	Received by	Date	Time
Relinquished by	Date	Time	Received by	Date	Time
Relinquished by	Date	Time	Received by	Date	Time
Relinquished by	Date	Time	Received by	Date	Time
Relinquished by	Date	Time	Received by	Date	Time
Relinquished by	Date	Time	Received by <u>Mif</u>	Date <u>11/27/18</u>	Time <u>1115</u>
EDD Required? Yes No			Relinquished by Commercial Carrier:		
If yes, format: _____			UPS _____ FedEx <u>X</u> Other _____		
Site-Specific QC (MS/MSD/Dup)? Yes No			Temperature upon receipt <u>1.8</u> °C		
(If yes, indicate QC sample and submit triplicate sample volume.)					



Client: C.T. Male Assoc.

**Hoosick Falls WTP**

**Delivery and Receipt Information**

Delivery Method:	<u>Fed Ex</u>	Arrival Timestamp:	<u>11/27/2018 11:15</u>
Number of Packages:	<u>1</u>	Number of Projects:	<u>1</u>
State/Province of Origin:	<u>NY</u>		

**Arrival Condition Summary**

Shipping Container Sealed:	Yes	Sample IDs on COC match Containers:	Yes
Custody Seal Present:	Yes	Sample Date/Times match COC:	Yes
Custody Seal Intact:	Yes	VOA Vial Headspace $\geq$ 6mm:	N/A
Samples Chilled:	Yes	Total Trip Blank Qty:	4
Paperwork Enclosed:	Yes	Trip Blank Type:	Trizma
Samples Intact:	Yes	Air Quality Samples Present:	No
Missing Samples:	No		
Extra Samples:	No		
Discrepancy in Container Qty on COC:	No		

*Unpacked by Nicole Reiff (25 684) at 13:56 on 11/27/2018*

**Samples Chilled Details: Hoosick Falls WTP**

Thermometer Types: DT = Digital (Temp. Bottle) IR = Infrared (Surface Temp) All Temperatures in °C.

<u>Cooler #</u>	<u>Thermometer ID</u>	<u>Corrected Temp</u>	<u>Therm. Type</u>	<u>Ice Type</u>	<u>Ice Present?</u>	<u>Ice Container</u>	<u>Elevated Temp?</u>
1	DT146	1.8	DT	Wet	Y	Bagged	N

# Explanation of Symbols and Abbreviations

The following defines common symbols and abbreviations used in reporting technical data:

<b>BMQL</b>	Below Minimum Quantitation Level	<b>mL</b>	milliliter(s)
<b>C</b>	degrees Celsius	<b>MPN</b>	Most Probable Number
<b>cfu</b>	colony forming units	<b>N.D.</b>	non-detect
<b>CP Units</b>	cobalt-chloroplatinate units	<b>ng</b>	nanogram(s)
<b>F</b>	degrees Fahrenheit	<b>NTU</b>	nephelometric turbidity units
<b>g</b>	gram(s)	<b>pg/L</b>	picogram/liter
<b>IU</b>	International Units	<b>RL</b>	Reporting Limit
<b>kg</b>	kilogram(s)	<b>TNTC</b>	Too Numerous To Count
<b>L</b>	liter(s)	<b>µg</b>	microgram(s)
<b>lb.</b>	pound(s)	<b>µL</b>	microliter(s)
<b>m3</b>	cubic meter(s)	<b>umhos/cm</b>	micromhos/cm
<b>meq</b>	milliequivalents	<b>MCL</b>	Maximum Contamination Limit
<b>mg</b>	milligram(s)		
<b>&lt;</b>	less than		
<b>&gt;</b>	greater than		
<b>ppm</b>	parts per million - One ppm is equivalent to one milligram per kilogram (mg/kg) or one gram per million grams. For aqueous liquids, ppm is usually taken to be equivalent to milligrams per liter (mg/l), because one liter of water has a weight very close to a kilogram. For gases or vapors, one ppm is equivalent to one microliter per liter of gas.		
<b>ppb</b>	parts per billion		
<b>Dry weight basis</b>	Results printed under this heading have been adjusted for moisture content. This increases the analyte weight concentration to approximate the value present in a similar sample without moisture. All other results are reported on an as-received basis.		

**Analytical test results meet all requirements of the associated regulatory program (i.e., NELAC (TNI), DoD, and ISO 17025) unless otherwise noted under the individual analysis.**

Measurement uncertainty values, as applicable, are available upon request.

Tests results relate only to the sample tested. Clients should be aware that a critical step in a chemical or microbiological analysis is the collection of the sample. Unless the sample analyzed is truly representative of the bulk of material involved, the test results will be meaningless. If you have questions regarding the proper techniques of collecting samples, please contact us. We cannot be held responsible for sample integrity, however, unless sampling has been performed by a member of our staff.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Times are local to the area of activity. Parameters listed in the 40 CFR Part 136 Table II as “analyze immediately” are not performed within 15 minutes.

**WARRANTY AND LIMITS OF LIABILITY** - In accepting analytical work, we warrant the accuracy of test results for the sample as submitted. THE FOREGOING EXPRESS WARRANTY IS EXCLUSIVE AND IS GIVEN IN LIEU OF ALL OTHER WARRANTIES, EXPRESSED OR IMPLIED. WE DISCLAIM ANY OTHER WARRANTIES, EXPRESSED OR IMPLIED, INCLUDING A WARRANTY OF FITNESS FOR PARTICULAR PURPOSE AND WARRANTY OF MERCHANTABILITY. IN NO EVENT SHALL EUROFINS LANCASTER LABORATORIES ENVIRONMENTAL, LLC BE LIABLE FOR INDIRECT, SPECIAL, CONSEQUENTIAL, OR INCIDENTAL DAMAGES INCLUDING, BUT NOT LIMITED TO, DAMAGES FOR LOSS OF PROFIT OR GOODWILL REGARDLESS OF (A) THE NEGLIGENCE (EITHER SOLE OR CONCURRENT) OF EUROFINS LANCASTER LABORATORIES ENVIRONMENTAL AND (B) WHETHER EUROFINS LANCASTER LABORATORIES ENVIRONMENTAL HAS BEEN INFORMED OF THE POSSIBILITY OF SUCH DAMAGES. We accept no legal responsibility for the purposes for which the client uses the test results. No purchase order or other order for work shall be accepted by Eurofins Lancaster Laboratories Environmental which includes any conditions that vary from the Standard Terms and Conditions, and Eurofins Lancaster Laboratories Environmental hereby objects to any conflicting terms contained in any acceptance or order submitted by client.

# Data Qualifiers

Qualifier	Definition
C	Result confirmed by reanalysis
D1	Indicates for dual column analyses that the result is reported from column 1
D2	Indicates for dual column analyses that the result is reported from column 2
E	Concentration exceeds the calibration range
K1	Initial Calibration Blank is above the QC limit and the sample result is ND
K2	Continuing Calibration Blank is above the QC limit and the sample result is ND
K3	Initial Calibration Verification is above the QC limit and the sample result is ND
K4	Continuing Calibration Verification is above the QC limit and the sample result is ND
J (or G, I, X)	Estimated value $\geq$ the Method Detection Limit (MDL or DL) and $<$ the Limit of Quantitation (LOQ or RL)
P	Concentration difference between the primary and confirmation column $>40\%$ . The lower result is reported.
P^	Concentration difference between the primary and confirmation column $> 40\%$ . The higher result is reported.
U	Analyte was not detected at the value indicated
V	Concentration difference between the primary and confirmation column $>100\%$ . The reporting limit is raised due to this disparity and evident interference.
W	The dissolved oxygen uptake for the unseeded blank is greater than 0.20 mg/L.
Z	Laboratory Defined - see analysis report

Additional Organic and Inorganic CLP qualifiers may be used with Form 1 reports as defined by the CLP methods. Qualifiers specific to Dioxin/Furans and PCB Congeners are detailed on the individual Analysis Report.