

 **ANALYTICAL REPORT****PREPARED FOR**

Attn: Jonathan Dippert
CT Male Associates DPC
50 Century Hill Dr
Latham, New York 12110

Generated 2/9/2024 5:48:31 PM

JOB DESCRIPTION

Hoosick Falls WTP

JOB NUMBER

410-159500-1

Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

Analytical test results meet all requirements of the associated regulatory program (i.e., NELAC (TNI), DoD, and ISO 17025) unless otherwise noted under the individual analysis.

Authorization



Generated
2/9/2024 5:48:31 PM

Authorized for release by
Kelly Gallagher, Project Manager
kelly.gallagher@et.eurofinsus.com
(717)205-7820

Compliance Statement

Analytical test results meet all requirements of the associated regulatory program (e.g., NELAC (TNI), DoD, and ISO 17025) unless otherwise noted under the individual analysis. Data qualifiers are applied to note exceptions. Noncompliant quality control (QC) is further explained in narrative comments.

- QC results that exceed the upper limits and are associated with non-detect samples are qualified but further narration is not required since the bias is high and does not change a non-detect result. Further narration is also not required with QC blank detection when the associated sample concentration is non-detect or more than ten times the level in the blank.
- Matrix QC may not be reported if insufficient sample or site-specific QC samples were not submitted. In these situations, to demonstrate precision and accuracy at a batch level, a LCS/LCSD is performed, unless otherwise specified in the method.
- Surrogate and/or isotope dilution analyte recoveries (if applicable) which are outside of the QC window are confirmed unless attributed to a dilution or otherwise noted in the narrative.

Regulated compliance samples (e.g. SDWA, NPDES) must comply with the associated agency requirements/permits.

Measurement uncertainty values, as applicable, are available upon request.

Test results relate only to the sample tested. Clients should be aware that a critical step in a chemical or microbiological analysis is the collection of the sample. Unless the sample analyzed is truly representative of the bulk of material involved, the test results will be meaningless. If you have questions regarding the proper techniques of collecting samples, please contact us. We cannot be held responsible for sample integrity, however, unless sampling has been performed by a member of our staff. Times are local to the area of activity. Parameters listed in the 40 CFR Part 136 Table II as "analyze immediately" and tested in the laboratory are not performed within 15 minutes of collection.

This report shall not be reproduced except in full, without the written approval of the laboratory.

WARRANTY AND LIMITS OF LIABILITY - In accepting analytical work, we warrant the accuracy of test results for the sample as submitted. The foregoing express warranty is exclusive and is given in lieu of all other warranties, expressed or implied, except as otherwise agreed. We disclaim any other warranties, expressed or implied, including a warranty of fitness for particular purpose and warranty of merchantability. In no event shall Eurofins Lancaster Laboratories Environmental, LLC be liable for indirect, special, consequential, or incidental damages including, but not limited to, damages for loss of profit or goodwill regardless of (A) the negligence (either sole or concurrent) of Eurofins Lancaster Laboratories Environmental and (B) whether Eurofins Lancaster Laboratories Environmental has been informed of the possibility of such damages. We accept no legal responsibility for the purposes for which the client uses the test results. Except as otherwise agreed, no purchase order or other order for work shall be accepted by Eurofins Lancaster Laboratories Environmental which includes any conditions that vary from the Standard Terms and Conditions, and Eurofins Lancaster Laboratories Environmental hereby objects to any conflicting terms contained in any acceptance or order submitted by client.





Table of Contents

Cover Page	1
Table of Contents	4
Definitions/Glossary	5
Case Narrative	6
Detection Summary	7
Client Sample Results	8
Surrogate Summary	13
Isotope Dilution Summary	14
QC Sample Results	15
QC Association Summary	18
Lab Chronicle	19
Certification Summary	21
Method Summary	22
Sample Summary	23
Chain of Custody	24
Receipt Checklists	25

Definitions/Glossary

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-159500-1

Qualifiers

LCMS

Qualifier	Qualifier Description
U	Indicates the analyte was analyzed for but not detected.

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
α	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

Case Narrative

Client: CT Male Associates DPC
Project: Hoosick Falls WTP

Job ID: 410-159500-1

Job ID: 410-159500-1

Eurofins Lancaster Laboratories Environment

Job Narrative 410-159500-1

Analytical test results meet all requirements of the associated regulatory program listed on the Accreditation/Certification Summary Page unless otherwise noted under the individual analysis. Data qualifiers are applied to indicate exceptions. Noncompliant quality control (QC) is further explained in narrative comments.

- Matrix QC may not be reported if insufficient sample or site-specific QC samples were not submitted. In these situations, to demonstrate precision and accuracy at a batch level, a LCS/LCSD may be performed, unless otherwise specified in the method.
- Surrogate and/or isotope dilution analyte recoveries (if applicable) which are outside of the QC window are confirmed unless attributed to a dilution or otherwise noted in the narrative.

Regulated compliance samples (e.g. SDWA, NPDES) must comply with the associated agency requirements/permits.

Receipt

The samples were received on 2/2/2024 9:50 AM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice. The temperature of the cooler at receipt time was 1.2°C

PFAS

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Detection Summary

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-159500-1

Client Sample ID: GAC INFLUENT

Lab Sample ID: 410-159500-1

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Perfluorobutanoic acid	4.6		1.7	ng/L	1		537 (Mod)	Total/NA
Perfluorooctanesulfonamide	1.7		1.7	ng/L	1		537 (Mod)	Total/NA
Perfluoropentanoic acid	2.9		1.7	ng/L	1		537 (Mod)	Total/NA
Perfluoroheptanoic acid	11		1.8	ng/L	1		EPA 537.1	Total/NA
Perfluorohexanoic acid	10		1.8	ng/L	1		EPA 537.1	Total/NA
Perfluorooctanesulfonic acid	3.4		1.8	ng/L	1		EPA 537.1	Total/NA
Perfluorooctanoic acid - DL	370		18	ng/L	10		EPA 537.1	Total/NA

Client Sample ID: GAC MIDFLUENT

Lab Sample ID: 410-159500-2

No Detections.

Client Sample ID: GAC EFFLUENT

Lab Sample ID: 410-159500-3

No Detections.

Client Sample ID: FTB01-240201

Lab Sample ID: 410-159500-4

No Detections.

Client Sample ID: LTB01-240201

Lab Sample ID: 410-159500-5

No Detections.

This Detection Summary does not include radiochemical test results.

Eurofins Lancaster Laboratories Environment Testing, LLC

Client Sample Results

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-159500-1

Client Sample ID: GAC INFLUENT

Lab Sample ID: 410-159500-1

Date Collected: 02/01/24 09:45

Matrix: Water

Date Received: 02/02/24 09:50

Method: EPA 537 (Mod) - EPA 537 Version 1.1 modified

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
6:2 Fluorotelomer sulfonic acid	1.7	U	1.7	ng/L		02/06/24 07:45	02/07/24 21:09	1
8:2 Fluorotelomer sulfonic acid	1.7	U	1.7	ng/L		02/06/24 07:45	02/07/24 21:09	1
Perfluorobutanoic acid	4.6		1.7	ng/L		02/06/24 07:45	02/07/24 21:09	1
Perfluorodecanesulfonic acid	1.7	U	1.7	ng/L		02/06/24 07:45	02/07/24 21:09	1
Perfluoroheptanesulfonic acid	1.7	U	1.7	ng/L		02/06/24 07:45	02/07/24 21:09	1
Perfluorooctanesulfonamide	1.7		1.7	ng/L		02/06/24 07:45	02/07/24 21:09	1
Perfluoropentanoic acid	2.9		1.7	ng/L		02/06/24 07:45	02/07/24 21:09	1
Isotope Dilution	%Recovery	Qualifier	Limits			Prepared	Analyzed	Dil Fac
M2-6:2 FTS	90		40 - 200			02/06/24 07:45	02/07/24 21:09	1
M2-8:2 FTS	91		37 - 200			02/06/24 07:45	02/07/24 21:09	1
13C4 PFBA	73		22 - 174			02/06/24 07:45	02/07/24 21:09	1
13C5 PFPeA	86		33 - 196			02/06/24 07:45	02/07/24 21:09	1
13C8 PFOS	79		59 - 155			02/06/24 07:45	02/07/24 21:09	1
13C8 FOSA	59		10 - 155			02/06/24 07:45	02/07/24 21:09	1
13C3 PFHxS	94		48 - 169			02/06/24 07:45	02/07/24 21:09	1

Method: EPA 537.1 - EPA 537.1, Ver 1.0 Nov 2018

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
NEtFOSAA	1.8	U	1.8	ng/L		02/05/24 13:52	02/07/24 15:28	1
NMeFOSAA	1.8	U	1.8	ng/L		02/05/24 13:52	02/07/24 15:28	1
Perfluorobutanesulfonic acid	1.8	U	1.8	ng/L		02/05/24 13:52	02/07/24 15:28	1
Perfluorodecanoic acid	1.8	U	1.8	ng/L		02/05/24 13:52	02/07/24 15:28	1
Perfluorododecanoic acid	1.8	U	1.8	ng/L		02/05/24 13:52	02/07/24 15:28	1
Perfluoroheptanoic acid	11		1.8	ng/L		02/05/24 13:52	02/07/24 15:28	1
Perfluorohexanesulfonic acid	1.8	U	1.8	ng/L		02/05/24 13:52	02/07/24 15:28	1
Perfluorohexanoic acid	10		1.8	ng/L		02/05/24 13:52	02/07/24 15:28	1
Perfluorononanoic acid	1.8	U	1.8	ng/L		02/05/24 13:52	02/07/24 15:28	1
Perfluorooctanesulfonic acid	3.4		1.8	ng/L		02/05/24 13:52	02/07/24 15:28	1
Perfluorotetradecanoic acid	1.8	U	1.8	ng/L		02/05/24 13:52	02/07/24 15:28	1
Perfluorotridecanoic acid	1.8	U	1.8	ng/L		02/05/24 13:52	02/07/24 15:28	1
Perfluoroundecanoic acid	1.8	U	1.8	ng/L		02/05/24 13:52	02/07/24 15:28	1
Surrogate	%Recovery	Qualifier	Limits			Prepared	Analyzed	Dil Fac
13C2 PFDA	115		70 - 130			02/05/24 13:52	02/07/24 15:28	1
13C2 PFHxA	119		70 - 130			02/05/24 13:52	02/07/24 15:28	1
d5-NEtFOSAA	96		70 - 130			02/05/24 13:52	02/07/24 15:28	1

Method: EPA 537.1 - EPA 537.1, Ver 1.0 Nov 2018 - DL

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorooctanoic acid	370		18	ng/L		02/05/24 13:52	02/08/24 03:00	10
Surrogate	%Recovery	Qualifier	Limits			Prepared	Analyzed	Dil Fac
13C2 PFDA	96		70 - 130			02/05/24 13:52	02/08/24 03:00	10
13C2 PFHxA	93		70 - 130			02/05/24 13:52	02/08/24 03:00	10
d5-NEtFOSAA	94		70 - 130			02/05/24 13:52	02/08/24 03:00	10

Client Sample Results

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-159500-1

Client Sample ID: GAC MIDFLUENT

Lab Sample ID: 410-159500-2

Date Collected: 02/01/24 09:50

Matrix: Water

Date Received: 02/02/24 09:50

Method: EPA 537 (Mod) - EPA 537 Version 1.1 modified

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
6:2 Fluorotelomer sulfonic acid	1.7	U	1.7	ng/L		02/06/24 07:45	02/07/24 21:22	1
8:2 Fluorotelomer sulfonic acid	1.7	U	1.7	ng/L		02/06/24 07:45	02/07/24 21:22	1
Perfluorobutanoic acid	1.7	U	1.7	ng/L		02/06/24 07:45	02/07/24 21:22	1
Perfluorodecanesulfonic acid	1.7	U	1.7	ng/L		02/06/24 07:45	02/07/24 21:22	1
Perfluoroheptanesulfonic acid	1.7	U	1.7	ng/L		02/06/24 07:45	02/07/24 21:22	1
Perfluorooctanesulfonamide	1.7	U	1.7	ng/L		02/06/24 07:45	02/07/24 21:22	1
Perfluoropentanoic acid	1.7	U	1.7	ng/L		02/06/24 07:45	02/07/24 21:22	1

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
M2-6:2 FTS	81		40 - 200	02/06/24 07:45	02/07/24 21:22	1
M2-8:2 FTS	82		37 - 200	02/06/24 07:45	02/07/24 21:22	1
13C4 PFBA	50		22 - 174	02/06/24 07:45	02/07/24 21:22	1
13C5 PFPeA	54		33 - 196	02/06/24 07:45	02/07/24 21:22	1
13C8 PFOS	76		59 - 155	02/06/24 07:45	02/07/24 21:22	1
13C8 FOSA	58		10 - 155	02/06/24 07:45	02/07/24 21:22	1
13C3 PFHxS	77		48 - 169	02/06/24 07:45	02/07/24 21:22	1

Method: EPA 537.1 - EPA 537.1, Ver 1.0 Nov 2018

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
NEtFOSAA	1.7	U	1.7	ng/L		02/05/24 13:52	02/07/24 15:39	1
NMeFOSAA	1.7	U	1.7	ng/L		02/05/24 13:52	02/07/24 15:39	1
Perfluorobutanesulfonic acid	1.7	U	1.7	ng/L		02/05/24 13:52	02/07/24 15:39	1
Perfluorodecanoic acid	1.7	U	1.7	ng/L		02/05/24 13:52	02/07/24 15:39	1
Perfluorododecanoic acid	1.7	U	1.7	ng/L		02/05/24 13:52	02/07/24 15:39	1
Perfluoroheptanoic acid	1.7	U	1.7	ng/L		02/05/24 13:52	02/07/24 15:39	1
Perfluorohexanesulfonic acid	1.7	U	1.7	ng/L		02/05/24 13:52	02/07/24 15:39	1
Perfluorohexanoic acid	1.7	U	1.7	ng/L		02/05/24 13:52	02/07/24 15:39	1
Perfluorononanoic acid	1.7	U	1.7	ng/L		02/05/24 13:52	02/07/24 15:39	1
Perfluorooctanesulfonic acid	1.7	U	1.7	ng/L		02/05/24 13:52	02/07/24 15:39	1
Perfluorooctanoic acid	1.7	U	1.7	ng/L		02/05/24 13:52	02/07/24 15:39	1
Perfluorotetradecanoic acid	1.7	U	1.7	ng/L		02/05/24 13:52	02/07/24 15:39	1
Perfluorotridecanoic acid	1.7	U	1.7	ng/L		02/05/24 13:52	02/07/24 15:39	1
Perfluoroundecanoic acid	1.7	U	1.7	ng/L		02/05/24 13:52	02/07/24 15:39	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C2 PFDA	100		70 - 130	02/05/24 13:52	02/07/24 15:39	1
13C2 PFHxA	103		70 - 130	02/05/24 13:52	02/07/24 15:39	1
d5-NEtFOSAA	97		70 - 130	02/05/24 13:52	02/07/24 15:39	1

Client Sample Results

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-159500-1

Client Sample ID: GAC EFFLUENT

Lab Sample ID: 410-159500-3

Date Collected: 02/01/24 09:55

Matrix: Water

Date Received: 02/02/24 09:50

Method: EPA 537 (Mod) - EPA 537 Version 1.1 modified

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
6:2 Fluorotelomer sulfonic acid	1.7	U	1.7	ng/L		02/06/24 07:45	02/07/24 21:36	1
8:2 Fluorotelomer sulfonic acid	1.7	U	1.7	ng/L		02/06/24 07:45	02/07/24 21:36	1
Perfluorobutanoic acid	1.7	U	1.7	ng/L		02/06/24 07:45	02/07/24 21:36	1
Perfluorodecanesulfonic acid	1.7	U	1.7	ng/L		02/06/24 07:45	02/07/24 21:36	1
Perfluoroheptanesulfonic acid	1.7	U	1.7	ng/L		02/06/24 07:45	02/07/24 21:36	1
Perfluorooctanesulfonamide	1.7	U	1.7	ng/L		02/06/24 07:45	02/07/24 21:36	1
Perfluoropentanoic acid	1.7	U	1.7	ng/L		02/06/24 07:45	02/07/24 21:36	1

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
M2-6:2 FTS	84		40 - 200	02/06/24 07:45	02/07/24 21:36	1
M2-8:2 FTS	83		37 - 200	02/06/24 07:45	02/07/24 21:36	1
13C4 PFBA	37		22 - 174	02/06/24 07:45	02/07/24 21:36	1
13C5 PFPeA	44		33 - 196	02/06/24 07:45	02/07/24 21:36	1
13C8 PFOS	80		59 - 155	02/06/24 07:45	02/07/24 21:36	1
13C8 FOSA	53		10 - 155	02/06/24 07:45	02/07/24 21:36	1
13C3 PFHxS	80		48 - 169	02/06/24 07:45	02/07/24 21:36	1

Method: EPA 537.1 - EPA 537.1, Ver 1.0 Nov 2018

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
NEtFOSAA	1.7	U	1.7	ng/L		02/05/24 13:52	02/07/24 15:51	1
NMeFOSAA	1.7	U	1.7	ng/L		02/05/24 13:52	02/07/24 15:51	1
Perfluorobutanesulfonic acid	1.7	U	1.7	ng/L		02/05/24 13:52	02/07/24 15:51	1
Perfluorodecanoic acid	1.7	U	1.7	ng/L		02/05/24 13:52	02/07/24 15:51	1
Perfluorododecanoic acid	1.7	U	1.7	ng/L		02/05/24 13:52	02/07/24 15:51	1
Perfluoroheptanoic acid	1.7	U	1.7	ng/L		02/05/24 13:52	02/07/24 15:51	1
Perfluorohexanesulfonic acid	1.7	U	1.7	ng/L		02/05/24 13:52	02/07/24 15:51	1
Perfluorohexanoic acid	1.7	U	1.7	ng/L		02/05/24 13:52	02/07/24 15:51	1
Perfluorononanoic acid	1.7	U	1.7	ng/L		02/05/24 13:52	02/07/24 15:51	1
Perfluorooctanesulfonic acid	1.7	U	1.7	ng/L		02/05/24 13:52	02/07/24 15:51	1
Perfluorooctanoic acid	1.7	U	1.7	ng/L		02/05/24 13:52	02/07/24 15:51	1
Perfluorotetradecanoic acid	1.7	U	1.7	ng/L		02/05/24 13:52	02/07/24 15:51	1
Perfluorotridecanoic acid	1.7	U	1.7	ng/L		02/05/24 13:52	02/07/24 15:51	1
Perfluoroundecanoic acid	1.7	U	1.7	ng/L		02/05/24 13:52	02/07/24 15:51	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C2 PFDA	96		70 - 130	02/05/24 13:52	02/07/24 15:51	1
13C2 PFHxA	109		70 - 130	02/05/24 13:52	02/07/24 15:51	1
d5-NEtFOSAA	95		70 - 130	02/05/24 13:52	02/07/24 15:51	1

Client Sample Results

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-159500-1

Client Sample ID: FTB01-240201

Lab Sample ID: 410-159500-4

Date Collected: 02/01/24 10:00

Matrix: Water

Date Received: 02/02/24 09:50

Method: EPA 537 (Mod) - EPA 537 Version 1.1 modified

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
6:2 Fluorotelomer sulfonic acid	1.9	U	1.9	ng/L		02/06/24 07:45	02/07/24 21:49	1
8:2 Fluorotelomer sulfonic acid	1.9	U	1.9	ng/L		02/06/24 07:45	02/07/24 21:49	1
Perfluorobutanoic acid	1.9	U	1.9	ng/L		02/06/24 07:45	02/07/24 21:49	1
Perfluorodecanesulfonic acid	1.9	U	1.9	ng/L		02/06/24 07:45	02/07/24 21:49	1
Perfluoroheptanesulfonic acid	1.9	U	1.9	ng/L		02/06/24 07:45	02/07/24 21:49	1
Perfluorooctanesulfonamide	1.9	U	1.9	ng/L		02/06/24 07:45	02/07/24 21:49	1
Perfluoropentanoic acid	1.9	U	1.9	ng/L		02/06/24 07:45	02/07/24 21:49	1

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
M2-6:2 FTS	80		40 - 200	02/06/24 07:45	02/07/24 21:49	1
M2-8:2 FTS	81		37 - 200	02/06/24 07:45	02/07/24 21:49	1
13C4 PFBA	61		22 - 174	02/06/24 07:45	02/07/24 21:49	1
13C5 PFPeA	73		33 - 196	02/06/24 07:45	02/07/24 21:49	1
13C8 PFOS	75		59 - 155	02/06/24 07:45	02/07/24 21:49	1
13C8 FOSA	63		10 - 155	02/06/24 07:45	02/07/24 21:49	1
13C3 PFHxS	76		48 - 169	02/06/24 07:45	02/07/24 21:49	1

Method: EPA 537.1 - EPA 537.1, Ver 1.0 Nov 2018

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
NEtFOSAA	1.8	U	1.8	ng/L		02/05/24 13:52	02/07/24 16:03	1
NMeFOSAA	1.8	U	1.8	ng/L		02/05/24 13:52	02/07/24 16:03	1
Perfluorobutanesulfonic acid	1.8	U	1.8	ng/L		02/05/24 13:52	02/07/24 16:03	1
Perfluorodecanoic acid	1.8	U	1.8	ng/L		02/05/24 13:52	02/07/24 16:03	1
Perfluorododecanoic acid	1.8	U	1.8	ng/L		02/05/24 13:52	02/07/24 16:03	1
Perfluoroheptanoic acid	1.8	U	1.8	ng/L		02/05/24 13:52	02/07/24 16:03	1
Perfluorohexanesulfonic acid	1.8	U	1.8	ng/L		02/05/24 13:52	02/07/24 16:03	1
Perfluorohexanoic acid	1.8	U	1.8	ng/L		02/05/24 13:52	02/07/24 16:03	1
Perfluorononanoic acid	1.8	U	1.8	ng/L		02/05/24 13:52	02/07/24 16:03	1
Perfluorooctanesulfonic acid	1.8	U	1.8	ng/L		02/05/24 13:52	02/07/24 16:03	1
Perfluorooctanoic acid	1.8	U	1.8	ng/L		02/05/24 13:52	02/07/24 16:03	1
Perfluorotetradecanoic acid	1.8	U	1.8	ng/L		02/05/24 13:52	02/07/24 16:03	1
Perfluorotridecanoic acid	1.8	U	1.8	ng/L		02/05/24 13:52	02/07/24 16:03	1
Perfluoroundecanoic acid	1.8	U	1.8	ng/L		02/05/24 13:52	02/07/24 16:03	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C2 PFDA	96		70 - 130	02/05/24 13:52	02/07/24 16:03	1
13C2 PFHxA	112		70 - 130	02/05/24 13:52	02/07/24 16:03	1
d5-NEtFOSAA	94		70 - 130	02/05/24 13:52	02/07/24 16:03	1

Client Sample Results

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-159500-1

Client Sample ID: LTB01-240201

Lab Sample ID: 410-159500-5

Date Collected: 02/01/24 00:00

Matrix: Water

Date Received: 02/02/24 09:50

Method: EPA 537 (Mod) - EPA 537 Version 1.1 modified

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
6:2 Fluorotelomer sulfonic acid	1.9	U	1.9	ng/L		02/06/24 07:45	02/07/24 22:03	1
8:2 Fluorotelomer sulfonic acid	1.9	U	1.9	ng/L		02/06/24 07:45	02/07/24 22:03	1
Perfluorobutanoic acid	1.9	U	1.9	ng/L		02/06/24 07:45	02/07/24 22:03	1
Perfluorodecanesulfonic acid	1.9	U	1.9	ng/L		02/06/24 07:45	02/07/24 22:03	1
Perfluoroheptanesulfonic acid	1.9	U	1.9	ng/L		02/06/24 07:45	02/07/24 22:03	1
Perfluorooctanesulfonamide	1.9	U	1.9	ng/L		02/06/24 07:45	02/07/24 22:03	1
Perfluoropentanoic acid	1.9	U	1.9	ng/L		02/06/24 07:45	02/07/24 22:03	1

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
M2-6:2 FTS	82		40 - 200	02/06/24 07:45	02/07/24 22:03	1
M2-8:2 FTS	82		37 - 200	02/06/24 07:45	02/07/24 22:03	1
13C4 PFBA	68		22 - 174	02/06/24 07:45	02/07/24 22:03	1
13C5 PFPeA	74		33 - 196	02/06/24 07:45	02/07/24 22:03	1
13C8 PFOS	76		59 - 155	02/06/24 07:45	02/07/24 22:03	1
13C8 FOSA	66		10 - 155	02/06/24 07:45	02/07/24 22:03	1
13C3 PFHxS	77		48 - 169	02/06/24 07:45	02/07/24 22:03	1

Method: EPA 537.1 - EPA 537.1, Ver 1.0 Nov 2018

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
NEtFOSAA	1.9	U	1.9	ng/L		02/05/24 13:52	02/07/24 16:14	1
NMeFOSAA	1.9	U	1.9	ng/L		02/05/24 13:52	02/07/24 16:14	1
Perfluorobutanesulfonic acid	1.9	U	1.9	ng/L		02/05/24 13:52	02/07/24 16:14	1
Perfluorodecanoic acid	1.9	U	1.9	ng/L		02/05/24 13:52	02/07/24 16:14	1
Perfluorododecanoic acid	1.9	U	1.9	ng/L		02/05/24 13:52	02/07/24 16:14	1
Perfluoroheptanoic acid	1.9	U	1.9	ng/L		02/05/24 13:52	02/07/24 16:14	1
Perfluorohexanesulfonic acid	1.9	U	1.9	ng/L		02/05/24 13:52	02/07/24 16:14	1
Perfluorohexanoic acid	1.9	U	1.9	ng/L		02/05/24 13:52	02/07/24 16:14	1
Perfluorononanoic acid	1.9	U	1.9	ng/L		02/05/24 13:52	02/07/24 16:14	1
Perfluorooctanesulfonic acid	1.9	U	1.9	ng/L		02/05/24 13:52	02/07/24 16:14	1
Perfluorooctanoic acid	1.9	U	1.9	ng/L		02/05/24 13:52	02/07/24 16:14	1
Perfluorotetradecanoic acid	1.9	U	1.9	ng/L		02/05/24 13:52	02/07/24 16:14	1
Perfluorotridecanoic acid	1.9	U	1.9	ng/L		02/05/24 13:52	02/07/24 16:14	1
Perfluoroundecanoic acid	1.9	U	1.9	ng/L		02/05/24 13:52	02/07/24 16:14	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C2 PFDA	102		70 - 130	02/05/24 13:52	02/07/24 16:14	1
13C2 PFHxA	107		70 - 130	02/05/24 13:52	02/07/24 16:14	1
d5-NEtFOSAA	100		70 - 130	02/05/24 13:52	02/07/24 16:14	1

Surrogate Summary

Client: CT Male Associates DPC
 Project/Site: Hoosick Falls WTP

Job ID: 410-159500-1

Method: EPA 537.1 - EPA 537.1, Ver 1.0 Nov 2018

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)		
		PFDA (70-130)	PFHxA (70-130)	d5NEFOS (70-130)
410-159500-1	GAC INFLUENT	115	119	96
410-159500-1 - DL	GAC INFLUENT	96	93	94
410-159500-2	GAC MIDFLUENT	100	103	97
410-159500-3	GAC EFFLUENT	96	109	95
410-159500-4	FTB01-240201	96	112	94
410-159500-5	LTB01-240201	102	107	100
LCS 410-470091/2-A	Lab Control Sample	91	98	90
LCSD 410-470091/3-A	Lab Control Sample Dup	96	100	91
MB 410-470091/1-A	Method Blank	94	100	90

Surrogate Legend

PFDA = 13C2 PFDA

PFHxA = 13C2 PFHxA

d5NEFOS = d5-NEtFOSAA



Isotope Dilution Summary

Client: CT Male Associates DPC
 Project/Site: Hoosick Falls WTP

Job ID: 410-159500-1

Method: 537 (Mod) - EPA 537 Version 1.1 modified

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Isotope Dilution Recovery (Acceptance Limits)						
		M262FTS (40-200)	M282FTS (37-200)	PFBA (22-174)	PFPeA (33-196)	C8PFOS (59-155)	PFOSA (10-155)	C3PFHS (48-169)
410-159500-1	GAC INFLUENT	90	91	73	86	79	59	94
410-159500-2	GAC MIDFLUENT	81	82	50	54	76	58	77
410-159500-3	GAC EFFLUENT	84	83	37	44	80	53	80
410-159500-4	FTB01-240201	80	81	61	73	75	63	76
410-159500-5	LTB01-240201	82	82	68	74	76	66	77
LCS 410-470360/2-A	Lab Control Sample	78	81	65	72	72	63	76
LCSD 410-470360/3-A	Lab Control Sample Dup	80	77	61	73	75	63	76
MB 410-470360/1-A	Method Blank	80	86	63	70	73	63	72

Surrogate Legend

- M262FTS = M2-6:2 FTS
- M282FTS = M2-8:2 FTS
- PFBA = 13C4 PFBA
- PFPeA = 13C5 PFPeA
- C8PFOS = 13C8 PFOS
- PFOSA = 13C8 FOSA
- C3PFHS = 13C3 PFHxS

QC Sample Results

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-159500-1

Method: 537 (Mod) - EPA 537 Version 1.1 modified

Lab Sample ID: MB 410-470360/1-A
Matrix: Water
Analysis Batch: 470945

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 470360

Analyte	MB	MB	RL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier						
6:2 Fluorotelomer sulfonic acid	2.0	U	2.0	ng/L		02/06/24 07:45	02/07/24 20:14	1
8:2 Fluorotelomer sulfonic acid	2.0	U	2.0	ng/L		02/06/24 07:45	02/07/24 20:14	1
Perfluorobutanoic acid	2.0	U	2.0	ng/L		02/06/24 07:45	02/07/24 20:14	1
Perfluorodecanesulfonic acid	2.0	U	2.0	ng/L		02/06/24 07:45	02/07/24 20:14	1
Perfluoroheptanesulfonic acid	2.0	U	2.0	ng/L		02/06/24 07:45	02/07/24 20:14	1
Perfluorooctanesulfonamide	2.0	U	2.0	ng/L		02/06/24 07:45	02/07/24 20:14	1
Perfluoropentanoic acid	2.0	U	2.0	ng/L		02/06/24 07:45	02/07/24 20:14	1

Isotope Dilution	MB	MB	Limits	Prepared	Analyzed	Dil Fac
	%Recovery	Qualifier				
M2-6:2 FTS	80		40 - 200	02/06/24 07:45	02/07/24 20:14	1
M2-8:2 FTS	86		37 - 200	02/06/24 07:45	02/07/24 20:14	1
13C4 PFBA	63		22 - 174	02/06/24 07:45	02/07/24 20:14	1
13C5 PFPeA	70		33 - 196	02/06/24 07:45	02/07/24 20:14	1
13C8 PFOS	73		59 - 155	02/06/24 07:45	02/07/24 20:14	1
13C8 FOSA	63		10 - 155	02/06/24 07:45	02/07/24 20:14	1
13C3 PFHxS	72		48 - 169	02/06/24 07:45	02/07/24 20:14	1

Lab Sample ID: LCS 410-470360/2-A
Matrix: Water
Analysis Batch: 470945

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 470360

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
8:2 Fluorotelomer sulfonic acid	24.5	19.9		ng/L		81	55 - 134
Perfluorobutanoic acid	25.6	24.7		ng/L		96	58 - 130
Perfluorodecanesulfonic acid	24.7	20.6		ng/L		83	55 - 130
Perfluoroheptanesulfonic acid	24.4	22.0		ng/L		90	59 - 130
Perfluorooctanesulfonamide	25.6	26.3		ng/L		103	67 - 132
Perfluoropentanoic acid	25.6	22.5		ng/L		88	60 - 130

Isotope Dilution	LCS	LCS	Limits
	%Recovery	Qualifier	
M2-6:2 FTS	78		40 - 200
M2-8:2 FTS	81		37 - 200
13C4 PFBA	65		22 - 174
13C5 PFPeA	72		33 - 196
13C8 PFOS	72		59 - 155
13C8 FOSA	63		10 - 155
13C3 PFHxS	76		48 - 169

Lab Sample ID: LCSD 410-470360/3-A
Matrix: Water
Analysis Batch: 470945

Client Sample ID: Lab Control Sample Dup
Prep Type: Total/NA
Prep Batch: 470360

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
8:2 Fluorotelomer sulfonic acid	24.5	22.1		ng/L		90	55 - 134	10	30
Perfluorobutanoic acid	25.6	23.6		ng/L		92	58 - 130	4	30
Perfluorodecanesulfonic acid	24.7	22.2		ng/L		90	55 - 130	8	30
Perfluoroheptanesulfonic acid	24.4	22.5		ng/L		92	59 - 130	2	30

QC Sample Results

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-159500-1

Method: 537 (Mod) - EPA 537 Version 1.1 modified (Continued)

Lab Sample ID: LCSD 410-470360/3-A
Matrix: Water
Analysis Batch: 470945

Client Sample ID: Lab Control Sample Dup
Prep Type: Total/NA
Prep Batch: 470360

Analyte	Spike	LCS	LCS	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
	Added	Result	Qualifier						
Perfluorooctanesulfonamide	25.6	27.9		ng/L		109	67 - 132	6	30
Perfluoropentanoic acid	25.6	23.2		ng/L		91	60 - 130	3	30

Isotope Dilution	LCS	LCS	Limits
	%Recovery	Qualifier	
M2-6:2 FTS	80		40 - 200
M2-8:2 FTS	77		37 - 200
13C4 PFBA	61		22 - 174
13C5 PFPeA	73		33 - 196
13C8 PFOS	75		59 - 155
13C8 FOSA	63		10 - 155
13C3 PFHxS	76		48 - 169

Method: EPA 537.1 - EPA 537.1, Ver 1.0 Nov 2018

Lab Sample ID: MB 410-470091/1-A
Matrix: Water
Analysis Batch: 470885

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 470091

Analyte	MB	MB	RL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier						
NEtFOSAA	2.0	U	2.0	ng/L		02/05/24 13:52	02/07/24 11:13	1
NMeFOSAA	2.0	U	2.0	ng/L		02/05/24 13:52	02/07/24 11:13	1
Perfluorobutanesulfonic acid	2.0	U	2.0	ng/L		02/05/24 13:52	02/07/24 11:13	1
Perfluorodecanoic acid	2.0	U	2.0	ng/L		02/05/24 13:52	02/07/24 11:13	1
Perfluorododecanoic acid	2.0	U	2.0	ng/L		02/05/24 13:52	02/07/24 11:13	1
Perfluoroheptanoic acid	2.0	U	2.0	ng/L		02/05/24 13:52	02/07/24 11:13	1
Perfluorohexanesulfonic acid	2.0	U	2.0	ng/L		02/05/24 13:52	02/07/24 11:13	1
Perfluorohexanoic acid	2.0	U	2.0	ng/L		02/05/24 13:52	02/07/24 11:13	1
Perfluorononanoic acid	2.0	U	2.0	ng/L		02/05/24 13:52	02/07/24 11:13	1
Perfluorooctanesulfonic acid	2.0	U	2.0	ng/L		02/05/24 13:52	02/07/24 11:13	1
Perfluorooctanoic acid	2.0	U	2.0	ng/L		02/05/24 13:52	02/07/24 11:13	1
Perfluorotetradecanoic acid	2.0	U	2.0	ng/L		02/05/24 13:52	02/07/24 11:13	1
Perfluorotridecanoic acid	2.0	U	2.0	ng/L		02/05/24 13:52	02/07/24 11:13	1
Perfluoroundecanoic acid	2.0	U	2.0	ng/L		02/05/24 13:52	02/07/24 11:13	1

Surrogate	MB	MB	Limits	Prepared	Analyzed	Dil Fac
	%Recovery	Qualifier				
13C2 PFDA	94		70 - 130	02/05/24 13:52	02/07/24 11:13	1
13C2 PFHxA	100		70 - 130	02/05/24 13:52	02/07/24 11:13	1
d5-NEtFOSAA	90		70 - 130	02/05/24 13:52	02/07/24 11:13	1

Lab Sample ID: LCS 410-470091/2-A
Matrix: Water
Analysis Batch: 470885

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 470091

Analyte	Spike	LCS	LCS	Unit	D	%Rec	%Rec Limits
	Added	Result	Qualifier				
NEtFOSAA	60.0	51.6		ng/L		86	70 - 130
NMeFOSAA	60.0	53.7		ng/L		89	70 - 130
Perfluorobutanesulfonic acid	53.1	53.1		ng/L		100	70 - 130
Perfluorodecanoic acid	60.0	57.2		ng/L		95	70 - 130
Perfluorododecanoic acid	60.0	54.9		ng/L		92	70 - 130

Eurofins Lancaster Laboratories Environment Testing, LLC

QC Sample Results

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-159500-1

Method: EPA 537.1 - EPA 537.1, Ver 1.0 Nov 2018 (Continued)

Lab Sample ID: LCS 410-470091/2-A

Matrix: Water

Analysis Batch: 470885

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 470091

Analyte	Spike	LCS	LCS	Unit	D	%Rec	%Rec
	Added	Result	Qualifier				
Perfluoroheptanoic acid	60.0	61.3		ng/L		102	70 - 130
Perfluorohexanesulfonic acid	54.7	51.8		ng/L		95	70 - 130
Perfluorohexanoic acid	60.0	62.8		ng/L		105	70 - 130
Perfluorononanoic acid	60.0	59.7		ng/L		99	70 - 130
Perfluorooctanesulfonic acid	55.5	52.9		ng/L		95	70 - 130
Perfluorooctanoic acid	60.0	59.7		ng/L		100	70 - 130
Perfluorotetradecanoic acid	60.0	56.1		ng/L		94	70 - 130
Perfluorotridecanoic acid	60.0	54.9		ng/L		92	70 - 130
Perfluoroundecanoic acid	60.0	52.3		ng/L		87	70 - 130

Surrogate	LCS	LCS	Limits
	%Recovery	Qualifier	
13C2 PFDA	91		70 - 130
13C2 PFHxA	98		70 - 130
d5-NEtFOSAA	90		70 - 130

Lab Sample ID: LCSD 410-470091/3-A

Matrix: Water

Analysis Batch: 470885

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

Prep Batch: 470091

Analyte	Spike	LCSD	LCSD	Unit	D	%Rec	%Rec	RPD	Limit
	Added	Result	Qualifier						
NEtFOSAA	60.0	54.3		ng/L		90	70 - 130	5	30
NMeFOSAA	60.0	53.2		ng/L		89	70 - 130	1	30
Perfluorobutanesulfonic acid	53.1	53.4		ng/L		101	70 - 130	1	30
Perfluorodecanoic acid	60.0	58.4		ng/L		97	70 - 130	2	30
Perfluorododecanoic acid	60.0	54.1		ng/L		90	70 - 130	2	30
Perfluoroheptanoic acid	60.0	63.3		ng/L		106	70 - 130	3	30
Perfluorohexanesulfonic acid	54.7	53.8		ng/L		98	70 - 130	4	30
Perfluorohexanoic acid	60.0	61.6		ng/L		103	70 - 130	2	30
Perfluorononanoic acid	60.0	60.3		ng/L		100	70 - 130	1	30
Perfluorooctanesulfonic acid	55.5	50.2		ng/L		90	70 - 130	5	30
Perfluorooctanoic acid	60.0	60.0		ng/L		100	70 - 130	0	30
Perfluorotetradecanoic acid	60.0	53.4		ng/L		89	70 - 130	5	30
Perfluorotridecanoic acid	60.0	54.9		ng/L		92	70 - 130	0	30
Perfluoroundecanoic acid	60.0	61.0		ng/L		102	70 - 130	15	30

Surrogate	LCSD	LCSD	Limits
	%Recovery	Qualifier	
13C2 PFDA	96		70 - 130
13C2 PFHxA	100		70 - 130
d5-NEtFOSAA	91		70 - 130

QC Association Summary

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-159500-1

LCMS

Prep Batch: 470091

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
410-159500-1	GAC INFLUENT	Total/NA	Water	537.1 DW Prep	
410-159500-1 - DL	GAC INFLUENT	Total/NA	Water	537.1 DW Prep	
410-159500-2	GAC MIDFLUENT	Total/NA	Water	537.1 DW Prep	
410-159500-3	GAC EFFLUENT	Total/NA	Water	537.1 DW Prep	
410-159500-4	FTB01-240201	Total/NA	Water	537.1 DW Prep	
410-159500-5	LTB01-240201	Total/NA	Water	537.1 DW Prep	
MB 410-470091/1-A	Method Blank	Total/NA	Water	537.1 DW Prep	
LCS 410-470091/2-A	Lab Control Sample	Total/NA	Water	537.1 DW Prep	
LCSD 410-470091/3-A	Lab Control Sample Dup	Total/NA	Water	537.1 DW Prep	

Prep Batch: 470360

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
410-159500-1	GAC INFLUENT	Total/NA	Water	SPE	
410-159500-2	GAC MIDFLUENT	Total/NA	Water	SPE	
410-159500-3	GAC EFFLUENT	Total/NA	Water	SPE	
410-159500-4	FTB01-240201	Total/NA	Water	SPE	
410-159500-5	LTB01-240201	Total/NA	Water	SPE	
MB 410-470360/1-A	Method Blank	Total/NA	Water	SPE	
LCS 410-470360/2-A	Lab Control Sample	Total/NA	Water	SPE	
LCSD 410-470360/3-A	Lab Control Sample Dup	Total/NA	Water	SPE	

Analysis Batch: 470885

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
410-159500-1	GAC INFLUENT	Total/NA	Water	EPA 537.1	470091
410-159500-2	GAC MIDFLUENT	Total/NA	Water	EPA 537.1	470091
410-159500-3	GAC EFFLUENT	Total/NA	Water	EPA 537.1	470091
410-159500-4	FTB01-240201	Total/NA	Water	EPA 537.1	470091
410-159500-5	LTB01-240201	Total/NA	Water	EPA 537.1	470091
MB 410-470091/1-A	Method Blank	Total/NA	Water	EPA 537.1	470091
LCS 410-470091/2-A	Lab Control Sample	Total/NA	Water	EPA 537.1	470091
LCSD 410-470091/3-A	Lab Control Sample Dup	Total/NA	Water	EPA 537.1	470091

Analysis Batch: 470945

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
410-159500-1	GAC INFLUENT	Total/NA	Water	537 (Mod)	470360
410-159500-2	GAC MIDFLUENT	Total/NA	Water	537 (Mod)	470360
410-159500-3	GAC EFFLUENT	Total/NA	Water	537 (Mod)	470360
410-159500-4	FTB01-240201	Total/NA	Water	537 (Mod)	470360
410-159500-5	LTB01-240201	Total/NA	Water	537 (Mod)	470360
MB 410-470360/1-A	Method Blank	Total/NA	Water	537 (Mod)	470360
LCS 410-470360/2-A	Lab Control Sample	Total/NA	Water	537 (Mod)	470360
LCSD 410-470360/3-A	Lab Control Sample Dup	Total/NA	Water	537 (Mod)	470360

Analysis Batch: 471243

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
410-159500-1 - DL	GAC INFLUENT	Total/NA	Water	EPA 537.1	470091

Lab Chronicle

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-159500-1

Client Sample ID: GAC INFLUENT

Lab Sample ID: 410-159500-1

Date Collected: 02/01/24 09:45

Matrix: Water

Date Received: 02/02/24 09:50

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Batch Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	SPE			470360	WQ8R	ELLE	02/06/24 07:45
Total/NA	Analysis	537 (Mod)		1	470945	R7RE	ELLE	02/07/24 21:09
Total/NA	Prep	537.1 DW Prep			470091	DX7G	ELLE	02/05/24 13:52
Total/NA	Analysis	EPA 537.1		1	470885	DCS9	ELLE	02/07/24 15:28
Total/NA	Prep	537.1 DW Prep	DL		470091	DX7G	ELLE	02/05/24 13:52
Total/NA	Analysis	EPA 537.1	DL	10	471243	DCS9	ELLE	02/08/24 03:00

Client Sample ID: GAC MIDFLUENT

Lab Sample ID: 410-159500-2

Date Collected: 02/01/24 09:50

Matrix: Water

Date Received: 02/02/24 09:50

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Batch Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	SPE			470360	WQ8R	ELLE	02/06/24 07:45
Total/NA	Analysis	537 (Mod)		1	470945	R7RE	ELLE	02/07/24 21:22
Total/NA	Prep	537.1 DW Prep			470091	DX7G	ELLE	02/05/24 13:52
Total/NA	Analysis	EPA 537.1		1	470885	DCS9	ELLE	02/07/24 15:39

Client Sample ID: GAC EFFLUENT

Lab Sample ID: 410-159500-3

Date Collected: 02/01/24 09:55

Matrix: Water

Date Received: 02/02/24 09:50

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Batch Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	SPE			470360	WQ8R	ELLE	02/06/24 07:45
Total/NA	Analysis	537 (Mod)		1	470945	R7RE	ELLE	02/07/24 21:36
Total/NA	Prep	537.1 DW Prep			470091	DX7G	ELLE	02/05/24 13:52
Total/NA	Analysis	EPA 537.1		1	470885	DCS9	ELLE	02/07/24 15:51

Client Sample ID: FTB01-240201

Lab Sample ID: 410-159500-4

Date Collected: 02/01/24 10:00

Matrix: Water

Date Received: 02/02/24 09:50

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Batch Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	SPE			470360	WQ8R	ELLE	02/06/24 07:45
Total/NA	Analysis	537 (Mod)		1	470945	R7RE	ELLE	02/07/24 21:49
Total/NA	Prep	537.1 DW Prep			470091	DX7G	ELLE	02/05/24 13:52
Total/NA	Analysis	EPA 537.1		1	470885	DCS9	ELLE	02/07/24 16:03

Client Sample ID: LTB01-240201

Lab Sample ID: 410-159500-5

Date Collected: 02/01/24 00:00

Matrix: Water

Date Received: 02/02/24 09:50

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Batch Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	SPE			470360	WQ8R	ELLE	02/06/24 07:45
Total/NA	Analysis	537 (Mod)		1	470945	R7RE	ELLE	02/07/24 22:03
Total/NA	Prep	537.1 DW Prep			470091	DX7G	ELLE	02/05/24 13:52
Total/NA	Analysis	EPA 537.1		1	470885	DCS9	ELLE	02/07/24 16:14

Lab Chronicle

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-159500-1

Laboratory References:

ELLE = Eurofins Lancaster Laboratories Environment Testing, LLC, 2425 New Holland Pike, Lancaster, PA 17601, TEL (717)656-2300

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16

Accreditation/Certification Summary

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-159500-1

Laboratory: Eurofins Lancaster Laboratories Environment Testing, LLC

Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below.

Authority	Program	Identification Number	Expiration Date
New York	NELAP	10670	04-01-24

The following analytes are included in this report, but the laboratory is not certified by the governing authority. This list may include analytes for which the agency does not offer certification.

Analysis Method	Prep Method	Matrix	Analyte
537 (Mod)	SPE	Water	6:2 Fluorotelomer sulfonic acid
537 (Mod)	SPE	Water	8:2 Fluorotelomer sulfonic acid
537 (Mod)	SPE	Water	Perfluorobutanoic acid
537 (Mod)	SPE	Water	Perfluorodecanesulfonic acid
537 (Mod)	SPE	Water	Perfluoroheptanesulfonic acid
537 (Mod)	SPE	Water	Perfluorooctanesulfonamide
537 (Mod)	SPE	Water	Perfluoropentanoic acid



Method Summary

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-159500-1

Method	Method Description	Protocol	Laboratory
537 (Mod)	EPA 537 Version 1.1 modified	EPA	ELLE
EPA 537.1	EPA 537.1, Ver 1.0 Nov 2018	EPA	ELLE
537.1 DW Prep	Extraction of Perfluorinated Alkyl Acids	EPA	ELLE

Protocol References:

EPA = US Environmental Protection Agency

Laboratory References:

ELLE = Eurofins Lancaster Laboratories Environment Testing, LLC, 2425 New Holland Pike, Lancaster, PA 17601, TEL (717)656-2300



Sample Summary

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-159500-1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
410-159500-1	GAC INFLUENT	Water	02/01/24 09:45	02/02/24 09:50
410-159500-2	GAC MIDFLUENT	Water	02/01/24 09:50	02/02/24 09:50
410-159500-3	GAC EFFLUENT	Water	02/01/24 09:55	02/02/24 09:50
410-159500-4	FTB01-240201	Water	02/01/24 10:00	02/02/24 09:50
410-159500-5	LTB01-240201	Water	02/01/24 00:00	02/02/24 09:50

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16

E
24
LE
PI



name

Chain of Custody Record



410-159500 Chain of Custody

Client Contact Jonathan Dippert <i>K. Mike Moirine</i>		Sampler <i>C. Omsick</i>	Lab PM Hobart, Paul	Carrier Tracking No(s)	COC No 410-77606-21525 2																																																																		
Company CT Male Associates DPC		Phone	E Mail Paul.Hobart@eurofinsus.com	State of Origin <i>NY</i>	Page Page 2 of 2 <i>1 of 1</i>																																																																		
Address 50 Century Hill Dr		Analysis Requested			Job #																																																																		
City Latham		Due Date Requested:	<table border="1"> <tr> <td>Field Filtered Sample (Yes or No)</td> <td>Perform MS/MSD (Yes or No)</td> <td>PFAS_IDA - (MOD) 7 PFAS Compounds</td> <td>537_DW - 14 PFAS Drinking Water List</td> <td>537_DW - 14 PFAS Drinking Water List</td> </tr> <tr> <td><i>N</i></td> <td><i>N</i></td> <td><i>Y</i></td> <td><i>N</i></td> <td><i>N</i></td> </tr> </table>			Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	PFAS_IDA - (MOD) 7 PFAS Compounds	537_DW - 14 PFAS Drinking Water List	537_DW - 14 PFAS Drinking Water List	<i>N</i>	<i>N</i>	<i>Y</i>	<i>N</i>	<i>N</i>																																																								
Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	PFAS_IDA - (MOD) 7 PFAS Compounds				537_DW - 14 PFAS Drinking Water List	537_DW - 14 PFAS Drinking Water List																																																																
<i>N</i>	<i>N</i>	<i>Y</i>				<i>N</i>	<i>N</i>																																																																
State, Zip NY, 12110		TAT Requested (days): <i>Standard</i>				Preservation Codes:																																																																	
Phone		Compliance Project: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<table border="0"> <tr> <td>A - HCL</td> <td>M - Hexane</td> </tr> <tr> <td>B - NaOH</td> <td>N - None</td> </tr> <tr> <td>C - Zn Acetate</td> <td>O - AsNaO2</td> </tr> <tr> <td>D - Nitric Acid</td> <td>P - Na2O4S</td> </tr> <tr> <td>E - NaHSO4</td> <td>Q - Na2S2O3</td> </tr> <tr> <td>F - MeOH</td> <td>R - Na2S2O8</td> </tr> <tr> <td>G - Amchlor</td> <td>S - H2SO4</td> </tr> <tr> <td>H - Ascorbic Acid</td> <td>T - TSP Dodecahydrate</td> </tr> <tr> <td>I - Ice</td> <td>U - Acetone</td> </tr> <tr> <td>J - DI Water</td> <td>V - MCAA</td> </tr> <tr> <td>K - EDTA</td> <td>W - pH 4.5</td> </tr> <tr> <td>L - EDA</td> <td>Y - Trizma</td> </tr> <tr> <td></td> <td>Z - other (specify)</td> </tr> </table>			A - HCL	M - Hexane	B - NaOH	N - None	C - Zn Acetate	O - AsNaO2	D - Nitric Acid	P - Na2O4S	E - NaHSO4	Q - Na2S2O3	F - MeOH	R - Na2S2O8	G - Amchlor	S - H2SO4	H - Ascorbic Acid	T - TSP Dodecahydrate	I - Ice	U - Acetone	J - DI Water	V - MCAA	K - EDTA	W - pH 4.5	L - EDA	Y - Trizma		Z - other (specify)																																								
A - HCL	M - Hexane																																																																						
B - NaOH	N - None																																																																						
C - Zn Acetate	O - AsNaO2																																																																						
D - Nitric Acid	P - Na2O4S																																																																						
E - NaHSO4	Q - Na2S2O3																																																																						
F - MeOH	R - Na2S2O8																																																																						
G - Amchlor	S - H2SO4																																																																						
H - Ascorbic Acid	T - TSP Dodecahydrate																																																																						
I - Ice	U - Acetone																																																																						
J - DI Water	V - MCAA																																																																						
K - EDTA	W - pH 4.5																																																																						
L - EDA	Y - Trizma																																																																						
	Z - other (specify)																																																																						
Email jdippert@ctmale.com <i>K. Moirine@ctmale.com</i>		PO #	Total Number of containers																																																																				
Project Name Hoosick Falls WTP		Purchase Order not required	Special Instructions/Note:																																																																				
Site <i>144756</i>		WO #																																																																					
Project # 41000511		SSOW#	<table border="1"> <thead> <tr> <th>Sample Identification</th> <th>Sample Date</th> <th>Sample Time</th> <th>Sample Type (C=comp, G=grab)</th> <th>Matrix (W=water, S=solid, O=waste/soil, B1=tissue, A=air)</th> <th>Field Filtered Sample (Yes or No)</th> <th>Perform MS/MSD (Yes or No)</th> <th>PFAS_IDA - (MOD) 7 PFAS Compounds</th> <th>537_DW - 14 PFAS Drinking Water List</th> <th>537_DW - 14 PFAS Drinking Water List</th> <th>Total Number of containers</th> </tr> </thead> <tbody> <tr> <td><i>GAC INFLUENT</i></td> <td><i>2/1/24</i></td> <td><i>0945</i></td> <td><i>G</i></td> <td><i>Water</i></td> <td><i>N</i></td> <td><i>N</i></td> <td><i>Y</i></td> <td><i>N</i></td> <td><i>N</i></td> <td><i>8</i></td> </tr> <tr> <td><i>GAC MIDFLUENT</i></td> <td><i>↓</i></td> <td><i>0950</i></td> <td><i>↓</i></td> <td><i>Water</i></td> <td><i>↓</i></td> <td><i>↓</i></td> <td><i>Y</i></td> <td><i>↓</i></td> <td><i>↓</i></td> <td><i>4</i></td> </tr> <tr> <td><i>GAC EFFLUENT</i></td> <td><i>↓</i></td> <td><i>0955</i></td> <td><i>↓</i></td> <td><i>Water</i></td> <td><i>↓</i></td> <td><i>↓</i></td> <td><i>Y</i></td> <td><i>↓</i></td> <td><i>↓</i></td> <td><i>4</i></td> </tr> <tr> <td><i>FTB01-240201</i></td> <td><i>↓</i></td> <td><i>1000</i></td> <td><i>↓</i></td> <td><i>↓</i></td> <td><i>↓</i></td> <td><i>↓</i></td> <td><i>Y</i></td> <td><i>↓</i></td> <td><i>↓</i></td> <td><i>4</i></td> </tr> <tr> <td><i>LTB01-240201</i></td> <td><i>↓</i></td> <td><i>-</i></td> <td><i>↓</i></td> <td><i>↓</i></td> <td><i>↓</i></td> <td><i>↓</i></td> <td><i>Y</i></td> <td><i>↓</i></td> <td><i>↓</i></td> <td><i>4</i></td> </tr> </tbody> </table>			Sample Identification	Sample Date	Sample Time	Sample Type (C=comp, G=grab)	Matrix (W=water, S=solid, O=waste/soil, B1=tissue, A=air)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	PFAS_IDA - (MOD) 7 PFAS Compounds	537_DW - 14 PFAS Drinking Water List	537_DW - 14 PFAS Drinking Water List	Total Number of containers	<i>GAC INFLUENT</i>	<i>2/1/24</i>	<i>0945</i>	<i>G</i>	<i>Water</i>	<i>N</i>	<i>N</i>	<i>Y</i>	<i>N</i>	<i>N</i>	<i>8</i>	<i>GAC MIDFLUENT</i>	<i>↓</i>	<i>0950</i>	<i>↓</i>	<i>Water</i>	<i>↓</i>	<i>↓</i>	<i>Y</i>	<i>↓</i>	<i>↓</i>	<i>4</i>	<i>GAC EFFLUENT</i>	<i>↓</i>	<i>0955</i>	<i>↓</i>	<i>Water</i>	<i>↓</i>	<i>↓</i>	<i>Y</i>	<i>↓</i>	<i>↓</i>	<i>4</i>	<i>FTB01-240201</i>	<i>↓</i>	<i>1000</i>	<i>↓</i>	<i>↓</i>	<i>↓</i>	<i>↓</i>	<i>Y</i>	<i>↓</i>	<i>↓</i>	<i>4</i>	<i>LTB01-240201</i>	<i>↓</i>	<i>-</i>	<i>↓</i>	<i>↓</i>	<i>↓</i>	<i>↓</i>	<i>Y</i>	<i>↓</i>	<i>↓</i>	<i>4</i>
Sample Identification	Sample Date	Sample Time				Sample Type (C=comp, G=grab)	Matrix (W=water, S=solid, O=waste/soil, B1=tissue, A=air)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	PFAS_IDA - (MOD) 7 PFAS Compounds	537_DW - 14 PFAS Drinking Water List	537_DW - 14 PFAS Drinking Water List	Total Number of containers																																																										
<i>GAC INFLUENT</i>	<i>2/1/24</i>	<i>0945</i>	<i>G</i>	<i>Water</i>	<i>N</i>	<i>N</i>	<i>Y</i>	<i>N</i>	<i>N</i>	<i>8</i>																																																													
<i>GAC MIDFLUENT</i>	<i>↓</i>	<i>0950</i>	<i>↓</i>	<i>Water</i>	<i>↓</i>	<i>↓</i>	<i>Y</i>	<i>↓</i>	<i>↓</i>	<i>4</i>																																																													
<i>GAC EFFLUENT</i>	<i>↓</i>	<i>0955</i>	<i>↓</i>	<i>Water</i>	<i>↓</i>	<i>↓</i>	<i>Y</i>	<i>↓</i>	<i>↓</i>	<i>4</i>																																																													
<i>FTB01-240201</i>	<i>↓</i>	<i>1000</i>	<i>↓</i>	<i>↓</i>	<i>↓</i>	<i>↓</i>	<i>Y</i>	<i>↓</i>	<i>↓</i>	<i>4</i>																																																													
<i>LTB01-240201</i>	<i>↓</i>	<i>-</i>	<i>↓</i>	<i>↓</i>	<i>↓</i>	<i>↓</i>	<i>Y</i>	<i>↓</i>	<i>↓</i>	<i>4</i>																																																													
Possible Hazard Identification <input type="checkbox"/> Non Hazard <input type="checkbox"/> Flammable <input type="checkbox"/> Skin Irritant <input type="checkbox"/> Poison B <input type="checkbox"/> Unknown <input type="checkbox"/> Radiological		Sample Disposal (A fee may be assessed if samples are retained longer than 1 month) <input type="checkbox"/> Return To Client <input type="checkbox"/> Disposal By Lab <input type="checkbox"/> Archive For _____ Months																																																																					
Deliverable Requested I, II, III, IV, Other (specify) <i>Asp-B Equi I</i>		Special Instructions/OC Requirements																																																																					
Empty Kit Relinquished by		Date	Time	Method of Shipment																																																																			
Relinquished by <i>Christina</i>	Date/Time <i>2/1/24 1510</i>	Company <i>CTM</i>	Received by	Date/Time	Company																																																																		
Relinquished by	Date/Time	Company	Received by	Date/Time	Company																																																																		
Relinquished by	Date/Time	Company	Received by <i>Ma</i>	Date/Time <i>2/1/24 9:50</i>	Company <i>ERT</i>																																																																		
Custody Seals Intact <input type="checkbox"/> Yes <input type="checkbox"/> No	Custody Seal No	Cooler Temperature(s) °C and Other Remarks <i>R: 1.2 C: 1.2</i>																																																																					

119



Login Sample Receipt Checklist

Client: CT Male Associates DPC

Job Number: 410-159500-1

Login Number: 159500

List Source: Eurofins Lancaster Laboratories Environment Testing, LLC

List Number: 1

Creator: Santiago, Nathaniel

Question	Answer	Comment
The cooler's custody seal is intact.	True	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	
Cooler Temperature acceptable, where thermal pres is required ($\leq 6C$, not frozen).	True	
Cooler Temperature is recorded.	True	
WV: Container Temp acceptable, where thermal pres is required ($\leq 6C$, not frozen).	N/A	
WV: Container Temperature is recorded.	N/A	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the containers received and the COC.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
There is sufficient vol. for all requested analyses.	True	
Is the Field Sampler's name present on COC?	True	
Sample custody seals are intact.	True	
VOA sample vials do not have headspace >6mm in diameter (none, if from WV)?	N/A	